







**PLUMBING MATERIALS**

- A. SANITARY PIPING:**  
(WHERE NOT OTHERWISE SPECIFIED THROUGHOUT THE DRAWING SET, WASTE, DRAIN AND VENT PIPING SHALL BE PER LOCAL CODE AND AUTHORITY HAVING JURISDICTION.)
1. UNDERSLAB DRAIN PIPING SHALL BE SCHEDULE 40 PVC.
  2. HOT WATER PIPING SHALL BE SCHEDULE 40 PVC. VENT PIPING ABOVE FLOOR 2" OR SMALLER MAY BE GALVANIZED STEEL.
  3. CONDENSATE PIPING SHALL BE TYPE "L" HARD DRAWN COPPER TUBE WITH 95-5 TIN-ANTIMONY SOLDERED JOINTS AND WROUGHT COPPER FITTINGS WITH DELECTRIC SEPARATION BETWEEN DISSIMILAR METALS. CONDENSATE PIPING BELOW ROOF DECK MAY BE PVC. PROVIDE SHARKBITE TRANSITION FROM PVC TO COPPER.
  4. INSULATE ALL HORIZONTAL RIMS OF PIPING LOCATED IN CEILING SPACES OF TENANTS IN SPACES BELOW WHEN APPLICABLE. INSULATION TO BE AS SPECIFIED FOR WATER PIPING. PROVIDE LINE-ITEM B-D TO UTILIZE PVC. OBTAIN APPROVAL FROM INSPECTOR PRIOR TO INSTALLATION THAT PVC IS ALLOWED FOR THE SPECIFIC HVAC LAYOUT FOR THIS PROJECT.
  5. INSULATION SHALL BE 1" POLYISOCYANURATE (PI) INSULATION.
- B. POTABLE WATER PIPING:**
1. ALL HOT AND COLD WATER SUPPLY PIPING, WHERE ALLOWED BY A.H.J. AND OWNER SHALL BE CPVC OR PEX.
  2. WATER PIPING IN CEILING SPACE AND WITHIN WALLS MAY BE TYPE "L" COPPER OR PEX, INSTALLED PER MANUFACTURER'S INSTRUCTIONS. PROVIDE SHARK-BITE TRANSITIONS, OR SOLDERED JOINTS, TO ALL COPPER PIPING.
  3. ABOVE-GRADE TYPE "L" ANNEALED TEMPERED COPPER TUBE FOR PIPE SIZES 2 INCHES AND SMALLER. BRAZE ALL JOINTS.
  4. WHERE APPLICABLE, TRANSITIONS BETWEEN COPPER AND PLASTIC PIPE SHALL BE MADE BY SHARKBITE OR SIMILAR TRANSITIONS, RATED FOR USE WITH SUCH MATERIALS AS ARE BEING USED.
  5. ABS PIPE MAY BE USED IN LEU OF PVC.
- C. GAS PIPING:**
1. GAS LINES SHALL BE BLACK STEEL, SCHEDULE 40, ASTM A-120, WITH WALLEABLE THREADED FITTINGS FOR 2" AND SMALLER, AND WITH WELDED JOINTS FOR 2-1/2" AND LARGER.
  2. GAS PIPING EXPOSED ON ROOF MUST BE PAINTED WITH RUST-INHIBITING PAINT.
- \*THIS MATERIALS LIST REPRESENTS THE MINIMUM SPECIFICATIONS SET FORTH BY THE MEP ENGINEER. CONTACT LANDLORD'S REPRESENTATIVE PRIOR TO BEGINNING CONSTRUCTION TO VERIFY IF THERE ARE ANY ADDITIONAL OR MORE STRINGENT REQUIREMENTS BEYOND THESE.

**PLUMBING WATER SUPPLY FIXTURE UNITS**

CALCULATION ASSUMES 2-1/2" WATER LINE WITH WATER SERVING THE BUILDING WITH 72 PSI STATIC PRESSURE.

1.30 WFSU FOR CYCLE BAR TOWEL  
UTILIZING THE 2013 CPC, TABLE 610.4:  
1-1/2" LINE WITH 120 WFSU

REFER TO SHEET P1.0 FOR RISER AND FLOOR PLAN WITH WFSU AD EACH MAIN AND BRANCH WATER LINES.


**BRANCH 1**

A: 1 WC = 26 FU  
B: 1 WC (26) + 1 SHD (2) = 28 FU  
C: 1 WC (26) + 2 SHD (4) + 1 UR (20) = 50 FU  
D: 1 WC (26) + 2 SHD (4) + 1 UR (20) + 1 LAV (2) = 52 FU  
E: 1 WC (26) + 2 SHD (4) + 1 UR (20) + 2 LAV (4) = 58 FU  
F: 1 WC (26) + 2 SHD (4) + 1 UR (20) + 2 LAV (4) + 1 UR (20) = 84 FU  
G: 1 WC (26) + 2 SHD (4) + 1 UR (20) + 2 LAV (4) + 1 UR (20) + 1 UR (20) = 100 FU  
H: 1 WC (26) + 2 SHD (4) + 1 UR (20) + 2 LAV (4) + 1 UR (20) + 1 UR (20) + 1 UR (20) = 116 FU  
I: 1 WC (26) + 2 SHD (4) + 1 UR (20) + 2 LAV (4) + 1 UR (20) + 1 UR (20) + 1 UR (20) + 1 UR (20) = 132 FU  
J: 1 WC (26) + 2 SHD (4) + 1 UR (20) + 2 LAV (4) + 1 UR (20) + 1 UR (20) + 1 UR (20) + 1 UR (20) + 1 UR (20) = 148 FU  
K: 1 WC (26) + 2 SHD (4) + 1 UR (20) + 2 LAV (4) + 1 UR (20) + 1 UR (20) + 1 UR (20) + 1 UR (20) + 1 UR (20) + 1 UR (20) = 164 FU  
L: 1 WC (26) + 2 SHD (4) + 1 UR (20) + 2 LAV (4) + 1 UR (20) + 1 UR (20) + 1 UR (20) + 1 UR (20) + 1 UR (20) + 1 UR (20) + 1 UR (20) = 180 FU

**BRANCH 2**

A: 1 DF = 2 FU  
B: 1 DF (2) + MS (2) = 4 FU  
C: 1 DF (2) + MS (2) + 1 WASH (10) = 14 FU  
D: 1 DF (2) + MS (2) + 1 WASH (10) + MS (2) = 18 FU

TOTAL: BRANCH 1 (116 FU) + BRANCH 2 (14 FU) = 130 WFSU



1. Floor Assembly - Min. 4-1/2 in. (114 mm) thick reinforced lightweight or normal weight 100-150 psi (1000-2400 kg/m<sup>3</sup>) concrete.  
1A. Floor Assembly - (Optional, Not Shown) - 2 in. (51 mm) thick reinforced lightweight or normal weight 100-150 psi (1000-2400 kg/m<sup>3</sup>) concrete. The fire-rated floor assembly shall be constructed of the materials listed below.  
A. Concrete - Min. 4-1/2 in. (114 mm) thick reinforced lightweight or normal weight 100-150 psi (1000-2400 kg/m<sup>3</sup>) concrete.  
B. Steel Floor and Form Units - Composite or non-composite max. 3 in. (76 mm) deep galv steel fluted units as specified in the individual Floor-Ceiling Design.  
2. Through Penetrants - One metallic pipe, conduit or tubing to be installed within the firestop device. Pipe, conduit or tubing to be rigidly supported on both sides of floor assembly. The following types of pipe, conduit or tubing may be used:  
A. Steel Pipe - Nom 6 in. (152 mm) diam (or smaller) Schedule 10 (or heavier) steel pipe.  
B. Non-Steel Pipe - Nom 6 in. (152 mm) diam (or smaller) Schedule 10 (or heavier) steel pipe.  
C. Conduit - Nom 4 in. (102 mm) diam (or smaller) steel electrical metallic conduit.  
D. Conduit - Nom 2 in. (51 mm) diam (or smaller) rigid electrical metallic conduit.  
E. Copper Tubing - Nom 2 in. (51 mm) diam (or smaller) Type L (or heavier) copper tubing.  
F. Copper Pipe - Nom 2 in. (51 mm) diam (or smaller) Regular (or heavier) copper pipe.  
The firestop device and metallic penetrant shall be sized as follows:  
\* \* \* L Rating applies only to CP-550-F device and only when the room diam of pipe equals size of device (2 in. diam pipe in 2" device etc.). L Rating does not apply to CP-550N device.

**Hiiti Firestop Systems**  
Reproduced by H.L.T.I., Inc. Courtesy of Underwriters Laboratories, Inc. February 27, 2008

**System No. FA-1091**  
F Rating - 4 Hr  
T Rating - 172 Hr  
L Rating At Ambient - 1 CFM/sq ft (See Item 2)  
L Rating At 400 F - Less Than 1 CFM/sq ft (See Item 2)  
W Rating - Class 1 (See Item 4)

3. Firestop Device - Cast in place firestop device permanently embedded during concrete placement or grouted in concrete floor assembly in accordance with accompanying installation instructions. The device may extend a max. of 2 in. (51 mm) above the top surface of the concrete. H.L.T.I. CONSTRUCTION CHEMICALS, DIV OF H.L.T.I.  
HC - CP-600N-752J5; CP-600N-1104; CP-600N-1505; CP-600P-2; CP-600P-3; CP-600P-4; CP-600P-5; CP-600P-6; CP-600P-7; CP-600P-8; CP-600P-9; CP-600P-10; CP-600P-11; CP-600P-12; CP-600P-13; CP-600P-14; CP-600P-15; CP-600P-16; CP-600P-17; CP-600P-18; CP-600P-19; CP-600P-20; CP-600P-21; CP-600P-22; CP-600P-23; CP-600P-24; CP-600P-25; CP-600P-26; CP-600P-27; CP-600P-28; CP-600P-29; CP-600P-30; CP-600P-31; CP-600P-32; CP-600P-33; CP-600P-34; CP-600P-35; CP-600P-36; CP-600P-37; CP-600P-38; CP-600P-39; CP-600P-40; CP-600P-41; CP-600P-42; CP-600P-43; CP-600P-44; CP-600P-45; CP-600P-46; CP-600P-47; CP-600P-48; CP-600P-49; CP-600P-50; CP-600P-51; CP-600P-52; CP-600P-53; CP-600P-54; CP-600P-55; CP-600P-56; CP-600P-57; CP-600P-58; CP-600P-59; CP-600P-60; CP-600P-61; CP-600P-62; CP-600P-63; CP-600P-64; CP-600P-65; CP-600P-66; CP-600P-67; CP-600P-68; CP-600P-69; CP-600P-70; CP-600P-71; CP-600P-72; CP-600P-73; CP-600P-74; CP-600P-75; CP-600P-76; CP-600P-77; CP-600P-78; CP-600P-79; CP-600P-80; CP-600P-81; CP-600P-82; CP-600P-83; CP-600P-84; CP-600P-85; CP-600P-86; CP-600P-87; CP-600P-88; CP-600P-89; CP-600P-90; CP-600P-91; CP-600P-92; CP-600P-93; CP-600P-94; CP-600P-95; CP-600P-96; CP-600P-97; CP-600P-98; CP-600P-99; CP-600P-100; CP-600P-101; CP-600P-102; CP-600P-103; CP-600P-104; CP-600P-105; CP-600P-106; CP-600P-107; CP-600P-108; CP-600P-109; CP-600P-110; CP-600P-111; CP-600P-112; CP-600P-113; CP-600P-114; CP-600P-115; CP-600P-116; CP-600P-117; CP-600P-118; CP-600P-119; CP-600P-120; CP-600P-121; CP-600P-122; CP-600P-123; CP-600P-124; CP-600P-125; CP-600P-126; CP-600P-127; CP-600P-128; CP-600P-129; CP-600P-130; CP-600P-131; CP-600P-132; CP-600P-133; CP-600P-134; CP-600P-135; CP-600P-136; CP-600P-137; CP-600P-138; CP-600P-139; CP-600P-140; CP-600P-141; CP-600P-142; CP-600P-143; CP-600P-144; CP-600P-145; CP-600P-146; CP-600P-147; CP-600P-148; CP-600P-149; CP-600P-150; CP-600P-151; CP-600P-152; CP-600P-153; CP-600P-154; CP-600P-155; CP-600P-156; CP-600P-157; CP-600P-158; CP-600P-159; CP-600P-160; CP-600P-161; CP-600P-162; CP-600P-163; CP-600P-164; CP-600P-165; CP-600P-166; CP-600P-167; CP-600P-168; CP-600P-169; CP-600P-170; CP-600P-171; CP-600P-172; CP-600P-173; CP-600P-174; CP-600P-175; CP-600P-176; CP-600P-177; CP-600P-178; CP-600P-179; CP-600P-180; CP-600P-181; CP-600P-182; CP-600P-183; CP-600P-184; CP-600P-185; CP-600P-186; CP-600P-187; CP-600P-188; CP-600P-189; CP-600P-190; CP-600P-191; CP-600P-192; CP-600P-193; CP-600P-194; CP-600P-195; CP-600P-196; CP-600P-197; CP-600P-198; CP-600P-199; CP-600P-200; CP-600P-201; CP-600P-202; CP-600P-203; CP-600P-204; CP-600P-205; CP-600P-206; CP-600P-207; CP-600P-208; CP-600P-209; CP-600P-210; CP-600P-211; CP-600P-212; CP-600P-213; CP-600P-214; CP-600P-215; CP-600P-216; CP-600P-217; CP-600P-218; CP-600P-219; CP-600P-220; CP-600P-221; CP-600P-222; CP-600P-223; CP-600P-224; CP-600P-225; CP-600P-226; CP-600P-227; CP-600P-228; CP-600P-229; CP-600P-230; CP-600P-231; CP-600P-232; CP-600P-233; CP-600P-234; CP-600P-235; CP-600P-236; CP-600P-237; CP-600P-238; CP-600P-239; CP-600P-240; CP-600P-241; CP-600P-242; CP-600P-243; CP-600P-244; CP-600P-245; CP-600P-246; CP-600P-247; CP-600P-248; CP-600P-249; CP-600P-250; CP-600P-251; CP-600P-252; CP-600P-253; CP-600P-254; CP-600P-255; CP-600P-256; CP-600P-257; CP-600P-258; CP-600P-259; CP-600P-260; CP-600P-261; CP-600P-262; CP-600P-263; CP-600P-264; CP-600P-265; CP-600P-266; CP-600P-267; CP-600P-268; CP-600P-269; CP-600P-270; CP-600P-271; CP-600P-272; CP-600P-273; CP-600P-274; CP-600P-275; CP-600P-276; CP-600P-277; CP-600P-278; CP-600P-279; CP-600P-280; CP-600P-281; CP-600P-282; CP-600P-283; CP-600P-284; CP-600P-285; CP-600P-286; CP-600P-287; CP-600P-288; CP-600P-289; CP-600P-290; CP-600P-291; CP-600P-292; CP-600P-293; CP-600P-294; CP-600P-295; CP-600P-296; CP-600P-297; CP-600P-298; CP-600P-299; CP-600P-300; CP-600P-301; CP-600P-302; CP-600P-303; CP-600P-304; CP-600P-305; CP-600P-306; CP-600P-307; CP-600P-308; CP-600P-309; CP-600P-310; CP-600P-311; CP-600P-312; CP-600P-313; CP-600P-314; CP-600P-315; CP-600P-316; CP-600P-317; CP-600P-318; CP-600P-319; CP-600P-320; CP-600P-321; CP-600P-322; CP-600P-323; CP-600P-324; CP-600P-325; CP-600P-326; CP-600P-327; CP-600P-328; CP-600P-329; CP-600P-330; CP-600P-331; CP-600P-332; CP-600P-333; CP-600P-334; CP-600P-335; CP-600P-336; CP-600P-337; CP-600P-338; CP-600P-339; CP-600P-340; CP-600P-341; CP-600P-342; CP-600P-343; CP-600P-344; CP-600P-345; CP-600P-346; CP-600P-347; CP-600P-348; CP-600P-349; CP-600P-350; CP-600P-351; CP-600P-352; CP-600P-353; CP-600P-354; CP-600P-355; CP-600P-356; CP-600P-357; CP-600P-358; CP-600P-359; CP-600P-360; CP-600P-361; CP-600P-362; CP-600P-363; CP-600P-364; CP-600P-365; CP-600P-366; CP-600P-367; CP-600P-368; CP-600P-369; CP-600P-370; CP-600P-371; CP-600P-372; CP-600P-373; CP-600P-374; CP-600P-375; CP-600P-376; CP-600P-377; CP-600P-378; CP-600P-379; CP-600P-380; CP-600P-381; CP-600P-382; CP-600P-383; CP-600P-384; CP-600P-385; CP-600P-386; CP-600P-387; CP-600P-388; CP-600P-389; CP-600P-390; CP-600P-391; CP-600P-392; CP-600P-393; CP-600P-394; CP-600P-395; CP-600P-396; CP-600P-397; CP-600P-398; CP-600P-399; CP-600P-400; CP-600P-401; CP-600P-402; CP-600P-403; CP-600P-404; CP-600P-405; CP-600P-406; CP-600P-407; CP-600P-408; CP-600P-409; CP-600P-410; CP-600P-411; CP-600P-412; CP-600P-413; CP-600P-414; CP-600P-415; CP-600P-416; CP-600P-417; CP-600P-418; CP-600P-419; CP-600P-420; CP-600P-421; CP-600P-422; CP-600P-423; CP-600P-424; CP-600P-425; CP-600P-426; CP-600P-427; CP-600P-428; CP-600P-429; CP-600P-430; CP-600P-431; CP-600P-432; CP-600P-433; CP-600P-434; CP-600P-435; CP-600P-436; CP-600P-437; CP-600P-438; CP-600P-439; CP-600P-440; CP-600P-441; CP-600P-442; CP-600P-443; CP-600P-444; CP-600P-445; CP-600P-446; CP-600P-447; CP-600P-448; CP-600P-449; CP-600P-450; CP-600P-451; CP-600P-452; CP-600P-453; CP-600P-454; CP-600P-455; CP-600P-456; CP-600P-457; CP-600P-458; CP-600P-459; CP-600P-460; CP-600P-461; CP-600P-462; CP-600P-463; CP-600P-464; CP-600P-465; CP-600P-466; CP-600P-467; CP-600P-468; CP-600P-469; CP-600P-470; CP-600P-471; CP-600P-472; CP-600P-473; CP-600P-474; CP-600P-475; CP-600P-476; CP-600P-477; CP-600P-478; CP-600P-479; CP-600P-480; CP-600P-481; CP-600P-482; CP-600P-483; CP-600P-484; CP-600P-485; CP-600P-486; CP-600P-487; CP-600P-488; CP-600P-489; CP-600P-490; CP-600P-491; CP-600P-492; CP-600P-493; CP-600P-494; CP-600P-495; CP-600P-496; CP-600P-497; CP-600P-498; CP-600P-499; CP-600P-500; CP-600P-501; CP-600P-502; CP-600P-503; CP-600P-504; CP-600P-505; CP-600P-506; CP-600P-507; CP-600P-508; CP-600P-509; CP-600P-510; CP-600P-511; CP-600P-512; CP-600P-513; CP-600P-514; CP-600P-515; CP-600P-516; CP-600P-517; CP-600P-518; CP-600P-519; CP-600P-520; CP-600P-521; CP-600P-522; CP-600P-523; CP-600P-524; CP-600P-525; CP-600P-526; CP-600P-527; CP-600P-528; CP-600P-529; CP-600P-530; CP-600P-531; CP-600P-532; CP-600P-533; CP-600P-534; CP-600P-535; CP-600P-536; CP-600P-537; CP-600P-538; CP-600P-539; CP-600P-540; CP-600P-541; CP-600P-542; CP-600P-543; CP-600P-544; CP-600P-545; CP-600P-546; CP-600P-547; CP-600P-548; CP-600P-549; CP-600P-550; CP-600P-551; CP-600P-552; CP-600P-553; CP-600P-554; CP-600P-555; CP-600P-556; CP-600P-557; CP-600P-558; CP-600P-559; CP-600P-560; CP-600P-561; CP-600P-562; CP-600P-563; CP-600P-564; CP-600P-565; CP-600P-566; CP-600P-567; CP-600P-568; CP-600P-569; CP-600P-570; CP-600P-571; CP-600P-572; CP-600P-573; CP-600P-574; CP-600P-575; CP-600P-576; CP-600P-577; CP-600P-578; CP-600P-579; CP-600P-580; CP-600P-581; CP-600P-582; CP-600P-583; CP-600P-584; CP-600P-585; CP-600P-586; CP-600P-587; CP-600P-588; CP-600P-589; CP-600P-590; CP-600P-591; CP-600P-592; CP-600P-593; CP-600P-594; CP-600P-595; CP-600P-596; CP-600P-597; CP-600P-598; CP-600P-599; CP-600P-600; CP-600P-601; CP-600P-602; CP-600P-603; CP-600P-604; CP-600P-605; CP-600P-606; CP-600P-607; CP-600P-608; CP-600P-609; CP-600P-610; CP-600P-611; CP-600P-612; CP-600P-613; CP-600P-614; CP-600P-615; CP-600P-616; CP-600P-617; CP-600P-618; CP-600P-619; CP-600P-620; CP-600P-621; CP-600P-622; CP-600P-623; CP-600P-624; CP-600P-625; CP-600P-626; CP-600P-627; CP-600P-628; CP-600P-629; CP-600P-630; CP-600P-631; CP-600P-632; CP-600P-633; CP-600P-634; CP-600P-635; CP-600P-636; CP-600P-637; CP-600P-638; CP-600P-639; CP-600P-640; CP-600P-641; CP-600P-642; CP-600P-643; CP-600P-644; CP-600P-645; CP-600P-646; CP-600P-647; CP-600P-648; CP-600P-649; CP-600P-650; CP-600P-651; CP-600P-652; CP-600P-653; CP-600P-654; CP-600P-655; CP-600P-656; CP-600P-657; CP-600P-658; CP-600P-659; CP-600P-660; CP-600P-661; CP-600P-662; CP-600P-663; CP-600P-664; CP-600P-665; CP-600P-666; CP-600P-667; CP-600P-668; CP-600P-669; CP-600P-670; CP-600P-671; CP-600P-672; CP-600P-673; CP-600P-674; CP-600P-675; CP-600P-676; CP-600P-677; CP-600P-678; CP-600P-679; CP-600P-680; CP-600P-681; CP-600P-682; CP-600P-683; CP-600P-684; CP-600P-685; CP-600P-686; CP-600P-687; CP-600P-688; CP-600P-689; CP-600P-690; CP-600P-691; CP-600P-692; CP-600P-693; CP-600P-694; CP-600P-695; CP-600P-696; CP-600P-697; CP-600P-698; CP-600P-699; CP-600P-700; CP-600P-701; CP-600P-702; CP-600P-703; CP-600P-704; CP-600P-705; CP-600P-706; CP-600P-707; CP-600P-708; CP-600P-709; CP-600P-710; CP-600P-711; CP-600P-712; CP-600P-713; CP-600P-714; CP-600P-715; CP-600P-716; CP-600P-717; CP-600P-718; CP-600P-719; CP-600P-720; CP-600P-721; CP-600P-722; CP-600P-723; CP-600P-724; CP-600P-725; CP-600P-726; CP-600P-727; CP-600P-728; CP-600P-729; CP-600P-730; CP-600P-731; CP-600P-732; CP-600P-733; CP-600P-734; CP-600P-735; CP-600P-736; CP-600P-737; CP-600P-738; CP-600P-739; CP-600P-740; CP-600P-741; CP-600P-742; CP-600P-743; CP-600P-744; CP-600P-745; CP-600P-746; CP-600P-747; CP-600P-748; CP-600P-749; CP-600P-750; CP-600P-751; CP-600P-752; CP-600P-753; CP-600P-754; CP-600P-755; CP-600P-756; CP-600P-757; CP-600P-758; CP-600P-759; CP-600P-760; CP-600P-761; CP-600P-762; CP-600P-763; CP-600P-764; CP-600P-765; CP-600P-766; CP-600P-767; CP-600P-768; CP-600P-769; CP-600P-770; CP-600P-771; CP-600P-772; CP-600P-773; CP-600P-774; CP-600P-775; CP-600P-776; CP-600P-777; CP-600P-778; CP-600P-779; CP-600P-780; CP-600P-781; CP-600P-782; CP-600P-783; CP-600P-784; CP-600P-785; CP-600P-786; CP-600P-787; CP-600P-788; CP-600P-789; CP-600P-790; CP-600P-791; CP-600P-792; CP-600P-793; CP-600P-794; CP-600P-795; CP-600P-796; CP-600P-797; CP-600P-798; CP-600P-799; CP-600P-800; CP-600P-801; CP-600P-802; CP-600P-803; CP-600P-804; CP-600P-805; CP-600P-806; CP-600P-807; CP-600P-808; CP-600P-809; CP-600P-810; CP-600P-811; CP-600P-812; CP-600P-813; CP-600P-814; CP-600P-815; CP-600P-816; CP-600P-817; CP-600P-818; CP-600P-819; CP-600P-820; CP-600P-821; CP-600P-822; CP-600P-823; CP-600P-824; CP-600P-825; CP-600P-826; CP-600P-827; CP-600P-828; CP-600P-829; CP-600P-830; CP-600P-831; CP-600P-832; CP-600P-833; CP-600P-834; CP-6







TABLE 6-5-5. DUCT SUPPORT PART 1 - VERTICAL DUCTS

MAXIMUM SIDE OF RECTANGULAR DUCT	METAL STRAP OR ANGLE BRACKET	MAXIMUM DIAMETER OF ROUND DUCTS	STRAPS
ON ROOF ON EXTERIOR OF BUILDING	C, V <sup>2</sup> AND W	I	A AND W
ATTICS, GARAGES AND CRAWL SPACES	A AND V <sup>2</sup>	II	B AND W
IN WALLS, WITHIN FLOOR-CEILING SPACES <sup>1</sup>	A AND V <sup>2</sup>	III	C AND W
WITH THE CONDITIONED SPACE OR IN BESEMENTS; RETURN DUCTS IN AIR PLENUMS	A AND V <sup>2</sup>	I	A
CEMENT SLAB OR WITHIN GROUND	A AND V <sup>2</sup>	II	A
		III	B

- NOTE: WHERE DUCTS ARE USED FOR BOTH HEATING AND COOLING, THE MINIMUM INSULATION SHALL BE AS REQUIRED FOR THE MOST RESTRICTIVE CONDITION.
- HEATING DEGREE DAYS:
    - ZONE I BELOW 4500 D.D.
    - ZONE II 4501 TO 8000 D.D.
    - ZONE III OVER 8000 D.D.
  - VAPOR RETARDERS SHALL BE INSTALLED ON SUPPLY DUCTS IN SPACES VENTED TO THE OUTSIDE IN GEOGRAPHIC AREAS WHERE THE SUMMER DEW POINT TEMPERATURE BASED ON THE 2-1/2% COLUMN OF DRY-BULB AND MEAN COINCIDENT WET-BULB TEMPERATURE EXCEEDS 60° DEG. F.
    - INSULATION MAY BE OMITTED ON THAT PORTION OF A DUCT WHICH IS LOCATED WITHIN A WALL OR FLOOR CEILING SPACE WHERE:
      - BOTH SIDES OF THE SPACE ARE EXPOSED TO CONDITIONED AIR.
      - THE SPACE IS NOT VENTILATED.
      - THE SPACE IS NOT USED AS A RETURN PLENUM.
      - THE SPACE IS NOT EXPOSED TO UNCONDITIONED AIR.
    - CEILING WHICH FORM PLENUMS NEED NOT BE INSULATED.
  - INSULATION TYPES:
    - A. MATERIAL WITH AN INSTALLED CONDUCTANCE OF 0.48 OR THE EQUIVALENT THERMAL RESISTANCE OF 2.1.
      - EXAMPLE OF MATERIALS CAPABLE OF MEETING THE ABOVE REQUIREMENTS:
        - 1 INCH 60 LB/CU. FT. MINERAL FIBER, ROCK, SLAG OR GLASS BLANKETS.
        - 1/2 INCH, 1.5 TO 3 LB/CU. FT. MINERAL FIBER BLANKET DUCT LINER.
        - 1/2 INCH, 3 TO 10 LB/CU. FT. MINERAL FIBER BOARD.
    - B. MATERIAL WITH AN INSTALLED CONDUCTANCE OF 0.24 OR THE EQUIVALENT THERMAL RESISTANCE OF 4.2.
      - EXAMPLE OF MATERIALS CAPABLE OF MEETING THE ABOVE REQUIREMENTS:
        - 2 INCH 0.60 LB/CU. FT. MINERAL FIBER BLANKETS.
        - 1/2 INCH, 1.5 TO 3 LB/CU. FT. MINERAL FIBER BLANKET DUCT LINER.
        - 1/2 INCH, 3 TO 10 LB/CU. FT. MINERAL FIBER BOARD.
    - C. MATERIAL WITH AN INSTALLED CONDUCTANCE OF 0.16 OR THE EQUIVALENT THERMAL RESISTANCE OF 6.3.
      - EXAMPLE OF MATERIALS CAPABLE OF MEETING THE ABOVE REQUIREMENTS:
        - 3 INCH 0.60 LB/CU. FT. MINERAL FIBER BLANKETS.
        - 1/2 INCH, 1.5 TO 3 LB/CU. FT. MINERAL FIBER BLANKET DUCT LINER.
        - 1/2 INCH, 3 TO 10 LB/CU. FT. MINERAL FIBER BOARD.
    - D. VAPOR RETARDERS: MATERIAL WITH A PERM RATING NOT EXCEEDING 0.5 PERM. ALL JOINTS TO BE SEALED.
    - E. APPROVED WEATHER PROOF BARRIER.
- THE EXAMPLE OF MATERIALS LISTED UNDER EACH TYPE IS NOT MEANT TO LIMIT OTHER AVAILABLE THICKNESS AND DENSITY COMBINATIONS WITH THE EQUIVALENT INSTALLED CONDUCTANCE OR RESISTANCE BASED ON THE INSULATION ONLY.

HVAC Load Calculation - Fitness Center 6/21/2017 Bishops - San Jose, CA

Heating Load Analysis: DB = 35.7  
 Sensible Heat Load: Design Temp = 70

H\_sensible\_OA = 1.08 \* cfm \* delta T  
 H\_sensible\_OA = 1.08 \* cfm \* delta T  
 H\_sensible\_walls = A \* U \* dt  
 H\_sensible\_floor = A \* U \* dt  
 H\_sensible\_roof = A \* U \* dt  
 H\_sensible\_window\_conductance = A\_glass \* U \* dt  
 H\_sensible\_window\_transmittance = A\_glass \* ShCo \* Et

H\_latent\_OA = 0.68 \* q \* delta w\_gains  
 H\_latent\_people = 250 \* # people

Lighting Load (watts) = 1392 (from Comcheck T24 / FlaCom)  
 Occupant Load = 38 (Auto Populate - from ASHRAE calculation)  
 Grains L.A. = 57.7 (72.2 is for saturated air at 58°)  
 Outside Air Ventilation = 415 (Auto Populate - from ASHRAE calculation)  
 Roof / Floor Area = 928 (Auto Populate - from ASHRAE calculation)  
 Wall Height - Average = 16.2 (Auto Populate - from ASHRAE calculation)  
 Perimeter (unconditioned) = 2268  
 Window Length = 18 (Auto Populate - from ASHRAE calculation)  
 Window Area = 160.2  
 Shading Factor = 1 (0 = none, 1.0 = fully shaded)  
 U-value Walls = (R\_net) = 0.052632 Average Wall  
 R-floor = (R\_net) = 1  
 U-floor = 1  
 R-roof = (R\_net) = 100 Residential Above  
 U-roof = 0.01 Average Roof  
 SHCo = 0.76 (use 1.1 for 1-pane glass; use 0.55 for double pane glass, energy star windows can be 0.55 max.)  
 Et = incident solar radiation

Total Cooling Load: 29360.29  
 Space Load - Tonnage Required: 2.46691 tons  
 Safety Factor (10%): 32296.32  
 Space Load - Recommended Tonnage: 2.69136 tons


Mechanical contractor shall verify existing HVAC Unit meets the above minimum requirement.

Square footage per ton - baseline (lower bound) 197.8104  
 Square footage per ton - baseline (upper bound) 372.2878

TABLE 6-5-4. DUCT INSULATION SCHEDULE 2016 CALIFORNIA MECHANICAL CODE

DUCT LOCATION	INSULATION TYPES MECHANICALLY CODED	HEATING ZONE ?	INSULATION TYPES HEATING ONLY
ON ROOF ON EXTERIOR OF BUILDING	C, V <sup>2</sup> AND W	I	A AND W
ATTICS, GARAGES AND CRAWL SPACES	A AND V <sup>2</sup>	II	B AND W
IN WALLS, WITHIN FLOOR-CEILING SPACES <sup>1</sup>	A AND V <sup>2</sup>	III	C AND W
WITH THE CONDITIONED SPACE OR IN BESEMENTS; RETURN DUCTS IN AIR PLENUMS	A AND V <sup>2</sup>	I	A
CEMENT SLAB OR WITHIN GROUND	A AND V <sup>2</sup>	II	B
		III	B


02 DUCT INSULATION AND SUPPORT  
 SCALE: 1/4"=1'-0"



1" X 16 GA. MIN (DUCTS OVER 2 SQ. FT.) MAX. 700 LBS. 1" X 18 GA. MIN (DUCTS UNDER 2 SQ. FT.) MAX. 450 LBS. FOR DUCTS OVER 4\"/>

DUCTWORK SUPPORT DETAIL NOT TO SCALE

MAX. SIDE INCHES	ALUMINUM MIN. B & S GAUGE
THROUGH 12	24 (0.020 IN.)
13 THROUGH 30	22 (0.025 IN.)
31 THROUGH 54	20 (0.032 IN.)
55 THROUGH 84	18 (0.040 IN.)
OVER 84	20 (0.040 IN.)
	18 (0.052 IN.)



NOTE: DISTANCE BETWEEN DUCT HANGERS SHALL BE IN ACCORDANCE WITH THE RULES OF THE AGENCIES HAVING JURISDICTION.

ROUND DUCT SUPPORT DETAIL NOT TO SCALE

DIAMETER INCHES	SPRICAL SEAM DUCT STEEL MIN. GALV. SHT. GAUGE	ROUND DUCTS LONGITUDINAL SEAM DUCT STEEL MIN. GALV. SHT. GAUGE	FITTINGS STEEL MIN. GALV. SHT. GAUGE
THROUGH 12	28 (0.019 IN.)	26 (0.022 IN.)	26 (0.022 IN.)
13 THROUGH 18	26 (0.022 IN.)	24 (0.028 IN.)	24 (0.028 IN.)
19 THROUGH 26	24 (0.028 IN.)	22 (0.034 IN.)	22 (0.034 IN.)
29 THROUGH 36	22 (0.034 IN.)	20 (0.040 IN.)	20 (0.040 IN.)
37 THROUGH 52	20 (0.040 IN.)	18 (0.052 IN.)	18 (0.052 IN.)

01 DUCTWORK SUPPORT DETAIL  
 SCALE: 1/4"=1'-0"

Space Load - Tonnage Required: 2.46691 tons  
 Space Load - Recommended Tonnage: 2.69136 tons

Mechanical contractor shall verify existing HVAC Unit meets the above minimum requirement.

Square footage per ton - baseline (lower bound) 197.8104  
 Square footage per ton - baseline (upper bound) 372.2878











DO NOT SCALE DRAWINGS  
CONTRACTOR TO VERIFY  
ALL EXISTING CONDITIONS AND  
DIMENSIONS - NOTIFY ARCHITECT  
OF ANY DISCREPANCIES PRIOR  
TO BEGINNING CONSTRUCTION

NO REVISION

ISSUE

ISSUE FOR PERMIT 09/18/17  
Peter A. Leptuch, P.E.  
CA-M33700/CA-E18072  
1236 Golden Eagle Ct  
Aubrey, TX 76227  
(940) 735-5127



PROJECT NUMBER  
**C170357**

SHEET NUMBER

**M23**  
MECHANICAL  
TITLE 24  
DATE OF THIS PERMIT: 09/18/17

STATE OF CALIFORNIA  
CALIFORNIA ENERGY COMMISSION  
MECHANICAL  
WATER HEATING SYSTEM GENERAL INFORMATION  
Project Name: **Bishops** Permit Number: **9/12/2017** (Page 2 of 3)

1. I, Peter A. Leptuch, P.E., certify that this Certificate of Compliance documentation is accurate and complete.  
2. The information provided on this Certificate of Compliance is true and correct.  
3. I understand that I am responsible for the building design or system design identified on this Certificate of Compliance (Responsible Designer).  
4. The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application.  
5. I understand that I am responsible for making any corrections to the information provided on this Certificate of Compliance that may be made available with the building permit application.  
6. I understand that I am responsible for providing a copy of this Certificate of Compliance to the enforcement agency for all applicable inspections. I understand that a completed copy of this Certificate of Compliance is required to be included with the documents submitted by the contractor to the building department at occupancy.

Responsible Designer Name: **Peter A. Leptuch** License: **M33700**  
Address: **1236 Golden Eagle Court** City: **Aubrey, TX 76227**  
Phone: **(940) 735-5127**

STATE OF CALIFORNIA  
CALIFORNIA ENERGY COMMISSION  
MECHANICAL  
WATER HEATING SYSTEM GENERAL INFORMATION  
Project Name: **Bishops** Permit Number: **9/12/2017** (Page 3 of 3)

**A. GENERAL INFORMATION/SYSTEM INFORMATION**  
01. Water Heater System Name: **A. O. Smith Water Products DEL 50**  
02. Water Heater System Configuration: **Non-Central**  
03. Water Heater System Type:  
04. Building Type:  
05. Total Number of Water Heaters in Systems: **1**  
06. Central Drive Distribution Type: **N/A**  
07. Dwelling Unit Distribution Type: **All Pipes Ins**

**B. WATER HEATER INFORMATION**  
01. Water Heater Type: **Small Storage Electric**  
02. Fuel Type: **Electric Res**  
03. Manufacturer Name: **A O Smith Water Products DEL 50**  
04. Model Number:  
05. Number of Identical Water Heaters: **1**  
06. Installed Water Heater System Efficiency: **1.00**  
07. Required Minimum Efficiency: **1.00**  
08. Standby Loss Percent or Standby Loss Total: **0.750**  
09. First-Fixage: **20.478**  
10. Recirculation:  
11. Water Heater Tank Storage Volume:  
12. Exterior Insulation on Water Heater:  
13. Volume of Insulation on Hot Water Storage:  
14. Internal Insulation on Supplemental Storage:  
15. Exterior Insulation on Supplemental Storage:

**C. PLUMBING COMPLIANCE FORMS & WORKSHEETS**  
For detailed instructions on the use of this and all Energy Standard compliance documents, refer to the 2018 Residential Manual.  
Note: The Enforcement Agency may require all compliance documents to be incorporated onto the building plans.  
YES NO Doc/Worksheet # Title  
01  NRC-PUB-01-E Certificate of Compliance, Declaration. Required on plans for all submissions.  
02  NRC-PUB-01-E Certificate of Installation. Required on plans for all submissions.  
03  NRC-PUB-01-E Certificate of Installation. Required on central systems in high-rise residential, hotel/motel application.  
04  NRC-PUB-03-E Certificate of Installation, required on single dwelling unit systems in high-rise residential, hotel/motel application.  
05  NRC-PUB-21-H Certificate of Installation, required on HERS verified central systems in high-rise residential, hotel/motel application.  
06  NRC-PUB-22-H Certificate of Installation, required on HERS verified single dwelling unit systems in high-rise residential, hotel/motel application.  
07  NRC-5TH-01-E Certificate of Installation, required on any solar water heating.













**TITLE 24 NOTE:**  
 INDOOR LIGHTING CONTROLS SHALL BE INSTALLED IN ACCORDANCE WITH TITLE 24, PART 6, SECTION 130.1.  
 A. ALL LUMINAIRES SHALL BE FUNCTIONALLY CONTROLLED WITH MANUALLY SWITCHED ON AND OFF LIGHTING CONTROLS. CONTROLS SHALL BE READILY ACCESSIBLE, AND OPERATED WITH A MANUAL SWITCH THAT IS LOCATED IN THE SAME ROOM OR AREA WITH THE LIGHTING FIXTURES. CONTROLS SHALL ALLOW MANUAL ON-OFF FUNCTIONALITY AND IS CAPABLE OF MANUALLY CONTROLLING LIGHTING THROUGH ALL LIGHTING CONTROL STEPS THAT ARE REQUIRED IN SECTION 130.1(E).  
 B. MULTI-LEVEL LIGHTING CONTROLS. THE GENERAL LIGHTING OF ANY ENCLOSED AREA 100 SQ. FT. OR LARGER, WITH A CONNECTED LIGHTING LOAD THAT EXCEEDS 0.5 WATTS PER SQUARE FOOT SHALL MEET THE FOLLOWING REQUIREMENTS:  
 1. LIGHTING SHALL HAVE THE REQUIRED NUMBER OF CONTROL STEPS AND MEET THE UNIFORMITY REQUIREMENTS IN ACCORDANCE WITH TABLE 130.1-A AND  
 2. MULTI-LEVEL LIGHTING CONTROLS SHALL NOT OVERRIDE THE FUNCTIONALITY OF OTHER LIGHTING CONTROLS REQUIRED FOR COMPLIANCE WITH SECTIONS 130.1(A), AND (C) THROUGH (E) AND  
 3. EACH LUMINAIRE SHALL BE CONTROLLED BY AT LEAST ONE OF THE FOLLOWING METHODS:  
 A. MANUAL DIMMING MEETING THE APPLICABLE REQUIREMENTS OF SECTION 130.1(A)  
 B. LUMEN MAINTENANCE AS DEFINED IN SECTION 100.1  
 C. TUNING AS DEFINED IN SECTION 100.1  
 D. AUTOMATIC DAYLIGHTING CONTROLS IN ACCORDANCE WITH SECTION 130.1(D)  
 E. DEMAND RESPONSIVE LIGHTING CONTROLS IN ACCORDANCE WITH SECTION 130.1(E)  
 C. IN ADDITIONAL TO LIGHTING CONTROLS INSTALLED IN ACCORDANCE WITH SECTION 130.1(A) THROUGH (E), ALL INSTALLED INDOOR LIGHTING SHALL BE EQUIPPED WITH CONTROLS THAT MEET THE FOLLOWING REQUIREMENTS:  
 A. SHALL BE CONTROLLED WITH AN OCCUPANT SENSING CONTROLLER THAT AUTOMATICALLY CONTROL SENSING FROM THE BUILDING SYSTEM OR OTHER CONTROL CAPABLE OF AUTOMATICALLY SHUTTING OFF ALL OF THE LIGHTING WHEN THE SPACE IS TYPICALLY UNOCCUPIED; AND  
 B. SEPARATE CONTROLS FOR THE LIGHTING ON EACH FLOOR.  
 C. SEPARATE CONTROLS FOR A SPACE ENCLOSED BY A CEILING HEIGHT PARTITION NOT EXCEEDING 5000 SQ. FT. (WALLS 20,000 SQ. FT.), [EXCEPTIONS FOR 24/265 FACILITIES, EQUIPMENT ROOMS, ETC.], AND  
 D. SEPARATE CONTROLS FOR GENERAL, DISPLAY, ORNAMENTAL, AND DISPLAY CASE LIGHTING.  
 D. DAYLIGHT ZONES ARE REQUIRED. (SEE T-24 FOR ADDITIONAL INFORMATION)  
 E. DEMAND RESPONSIVE CONTROLS.  
 LIGHTING POWER IN BUILDINGS LARGER THAN 10,000 SQ. FT. SHALL BE CAPABLE OF BEING AUTOMATICALLY REDUCED IN RESPONSE TO A DEMAND RESPONSE SIGNAL; SO THAT THE BUILDING'S TOTAL LIGHTING POWER CAN BE LOWERED BY A MINIMUM OF 15 PERCENT BELOW THE TOTAL LIGHTING POWER. DEMAND RESPONSE LIGHTING SHALL BE INSTALLED IN A MANNER CONSISTENT WITH UNIFORM LEVEL OF ILLUMINATION REQUIREMENTS IN TABLE 130.1-A.  
 THE ABOVE REQUIRES AN AUTOMATED LIGHTING CONTROL SYSTEM THAT ALL UNOCCUPIED CIRCUITS ARE ROUTED THROUGH THE CONTROLLER.  
 AND... ALL LIGHT FIXTURES SHALL BE COMPATIBLE WITH SAID CONTROLLER.  
 A LIGHTING CONTROL SYSTEM SHALL BE AS SPECIFIED IN THE LIGHTING CONTROL PANEL SCHEDULE. IT IS RECOMMENDED THAT LIGHT FIXTURES AND LIGHTING CONTROL PANEL BE FROM A SINGLE VENDOR THAT VERIFIES COMPATIBILITY OF ALL COMPONENTS AND OFFERS COMMISSIONING OF THE BUILT SYSTEM.

WHEN BUILDING SIGN POWER IS ROUTED THROUGH LANDLORD'S CONTROL SYSTEM, AND SHOW WINDOW RECEPTACLES ARE NOT REQUIRED, AND THE CLIENT DOES NOT WANT RECEPTACLES, THE CLIENT SHALL PROVIDE A PHOTOCELL IN THE CONTROL PANEL, THEN A 4-POLE LOP MAY BE USED (RE4BD-104).  
 PROVIDE PHOTOCELL INPUT TO SIGNAL FOR SIGN CIRCUIT AND S/W CIRCUIT TO ENERGIZE AND DEENERGIZE THE SIGN CIRCUIT BY A.H.J. PHOTOCELL IS NOT REQUIRED, WHEN TIME CLOCK IS ASTRONOMICAL TYPE.

LIGHTING CONTROL PANEL SPECIFICATION:		NOTES
MANUF.	MODEL	
LEVITON	EZ-MAX ROBED-000	8-SPACE, CONTROLS LOW AND LINE VOLTAGE CIRCUITS. LOP CONTAINS AN INTEGRAL TIME CLOCK

- LIGHTING CONTROL PANEL ZONES**
1. TRACK
  2. 110V SOURCES
  3. LOW VOLTAGE PENDANT/ MS
  4. CONTROLLABLE OUTLET
  5. SIGN
  6. S/W RECEPTACLE #1
  7. S/W RECEPTACLE #2
  8. SPARE

**AMPACITY REQD CALCS**

LIGHTING	3.80	KVA X 125 % =	4.8 KVA
RECEPTACLE TOTAL	5.68	KVA	
1ST	10.00	KVA X 100 % =	5.7 KVA
REMAIN	0.00	KVA X 50 % =	0.0 KVA
TOTAL	0.00	KVA X 100 % =	0.0 KVA
LARGEST	0.00	KVA X 125 % =	0.0 KVA
REMAIN	0.00	KVA X 100 % =	0.0 KVA
AC	13.05	KVA X 100 % =	13.1 KVA
HEATING	0.00	KVA X 100 % =	0.0 KVA
LOOKED-OUT LOAD	0.00	KVA X 100 % =	0.0 KVA
KITCHEN	0.00	KVA X 65 % =	0.0 KVA
MISCELLANEOUS	14.86	KVA X 100 % =	14.9 KVA
TOTAL			= 38.3 KVA

**PANELBOARD SCHEDULE - 'LA' (NEW)**

DCKT #	TRIP	MANK	125A MCB	VOLTAGE: 208/120				PHASE	MOUNTING	RECESSED	AC	42KVAIC	DCKT POLE #
				LOAD (KVA)	LOAD (KVA)	LOAD (KVA)	LOAD (KVA)						
1	201	201	201	0.4	0.4	0.4	0.4	10	10	10	10	2	
2	201	201	201	0.4	0.4	0.4	0.4	10	10	10	10	2	
3	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
4	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
5	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
6	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
7	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
8	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
9	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
10	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
11	201	201	201	0.4	0.4	0.4	0.4	10	10	10	10	2	
12	201	201	201	0.4	0.4	0.4	0.4	10	10	10	10	2	
13	201	201	201	0.4	0.4	0.4	0.4	10	10	10	10	2	
14	201	201	201	0.4	0.4	0.4	0.4	10	10	10	10	2	
15	201	201	201	0.5	0.5	0.5	0.5	10	10	10	10	2	
16	201	201	201	0.5	0.5	0.5	0.5	10	10	10	10	2	
17	302	302	302	0.2	0.2	0.2	0.2	10	10	10	10	2	
18	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
19	201	201	201	1.0	1.0	1.0	1.0	10	10	10	10	2	
20	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
21	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
22	201	201	201	0.4	0.4	0.4	0.4	10	10	10	10	2	
23	201	201	201	0.4	0.4	0.4	0.4	10	10	10	10	2	
24	201	201	201	1.3	1.3	1.3	1.3	10	10	10	10	2	
25	201	201	201	0.4	0.4	0.4	0.4	10	10	10	10	2	
26	201	201	201	0.4	0.4	0.4	0.4	10	10	10	10	2	
27	201	201	201	0.4	0.4	0.4	0.4	10	10	10	10	2	
28	201	201	201	0.4	0.4	0.4	0.4	10	10	10	10	2	
29	201	201	201	0.4	0.4	0.4	0.4	10	10	10	10	2	
30	201	201	201	1.7	1.7	1.7	1.7	10	10	10	10	2	
31	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
32	201	201	201	1.5	1.5	1.5	1.5	10	10	10	10	2	
33	255	255	255	3.0	3.0	3.0	3.0	10	10	10	10	2	
34	201	201	201	1.7	1.7	1.7	1.7	10	10	10	10	2	
35	201	201	201	1.5	1.5	1.5	1.5	10	10	10	10	2	
36	201	201	201	1.5	1.5	1.5	1.5	10	10	10	10	2	
37	201	201	201	1.5	1.5	1.5	1.5	10	10	10	10	2	
38	201	201	201	1.5	1.5	1.5	1.5	10	10	10	10	2	
39	201	201	201	1.2	1.2	1.2	1.2	10	10	10	10	2	
40	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
41	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
42	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
43	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
44	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
45	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
46	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
47	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
48	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
49	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
50	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
51	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
52	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
53	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
54	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
55	201	201	201	0.2	0.2	0.2	0.2	10	10	10	10	2	
RECEPTACLES (KVA)		3.8	1.2	1.8	0.8	0.0	0.0	11.7	2.6	4.1	0.0	3.2	
RECEPTACLES (KVA)		5.7										37.4	
MOTORS (KVA)		0.0										102.8	
AC (KVA)		13.1										102.8	
HEATING (KVA)		0.0										0.0	
KITCHEN (KVA)		0.0										0.0	
MISCELLANEOUS (KVA)		14.9										102.4	

**NOTE:** BREAKERS PROTECTING MULTIPLE WIRE BRANCH CIRCUITS SHALL BE EQUIPPED WITH A PAD-LOCK DEVICE SO THAT CIRCUITS CAN BE DISCONNECTED SMALL FACILITY.  
 \* PROVIDE MCB TYPE CIRCUIT BREAKER  
 \* BALANCE ALL PANELS TO WITHIN 10%

**AMPACITY REQD CALCS**

LIGHTING	3.80	KVA X 125 % =	4.8 KVA
RECEPTACLE TOTAL	5.68	KVA	
1ST	10.00	KVA X 100 % =	5.7 KVA
REMAIN	0.00	KVA X 50 % =	0.0 KVA
TOTAL	0.00	KVA X 100 % =	0.0 KVA
LARGEST	0.00	KVA X 125 % =	0.0 KVA
REMAIN	0.00	KVA X 100 % =	0.0 KVA
AC	13.05	KVA X 100 % =	13.1 KVA
HEATING	0.00	KVA X 100 % =	0.0 KVA
LOOKED-OUT LOAD	0.00	KVA X 100 % =	0.0 KVA
KITCHEN	0.00	KVA X 65 % =	0.0 KVA
MISCELLANEOUS	14.86	KVA X 100 % =	14.9 KVA
TOTAL			= 38.3 KVA

**ONE-LINE RISER NOTES:**


1. PROVIDE LOCK-ON BREAKERS FOR ALL N/E/W AND SECURITY/PHONE CIRCUITS, DUCT DETECTORS, AND TIME CLOCK.
2. USE THIN WIRE INSULATION, 75°C.
3. PROVIDE POWER FOR ANCHORAGE ITEMS AS NEEDED FOR A COMPLETE INSTALL, SUCH AS DUCT DETECTORS, FLUSH VALVES AND FAUCET SENSORS AS NEEDED.
4. AS DUCT DETECTORS, FLUSH VALVES AND FAUCET SENSORS AS NEEDED, THE SUB-PANELS SHALL BE SCOR RATED TO 10 KVA. SAME AS THE MAIN PANEL.
5. SUB-PANEL(S) AND SHALL BE FEED FROM A SERIES RATED BREAKER, OTHERWISE PANEL(S) SHALL BE FULLY RATED WITH SAME SCOR AS ORIGINATING PANEL.
6. ELECTRICAL CONTRACTOR SHALL VERIFY AVAILABLE FAULT WITH UTILITY CO. RATING ORDERING GEAR AND ENERGIZING SERVICE, AND SHALL LABEL GEAR WITH SCOR RATING. A AVAILABLE FAULT AT EACH PIECE OF EQUIPMENT AND DATE CALCULATIONS WERE MADE.
7. PROVIDE ARCFLASH HAZARD WARNING LABELS ON ALL GEAR AS REQUIRED BY N.E.C.
8. DISCONNECTS SHALL BE RATED AT VOLTAGE OF EQUIPMENT SERVED. CONFIRM VOLTAGE AVAILABLE ON SITE PRIOR TO ORDERING EQUIPMENT.
9. ON 480V JOBS, AS NEEDED, PROVIDE SECONDARY DISCONNECT (FUSED) WITHIN 10' OF THE STEP-DOWN TRANSFORMER WHERE SECONDARY CONDUCTOR DISTANCE IS >25' OR MORE. THE CONTRACTOR MAY INSTALL FLEXIBLE METAL CONDUIT TO TERMINATE CIRCUITS, IN SEGMENTS NOT TO EXCEED 5'-0".
10. ALL ELECTRICAL OUTLET SWITCHES IN PRE-RATED WALLS SHALL BE INSTALLED WITH FIRE-RATED BLOCKING PUTTY PADS (TYP.).

**BISHOPS - SAN JOSE, CA**  
 THE BASE BUILDING HAS 480V/208V/120V SERVICE ALREADY STEPPED DOWN TO 208V. THIS SHEET CALLS FOR EXISTING SERVICE.  
 SAN JOSE, CA NOTE:  
 THE SERVICE IS <50KVA. DESEGREGATION OF LOADS IS NOT REQUIRED.  
 SAN JOSE, CA NOTE:  
 THE SPACE IS LESS THAN 10,000 SQ. FT. A DEMAND RESPONSIVE SYSTEM IS NOT REQUIRED.

**BISHOPS PROTOTYPICAL NOTE:**  
 SEE SHEET MEP1.0 FOR POWER FOR ROOF-MOUNTED EQUIPMENT.  
 REVIEW AND APPROVAL BY THE A.H.J. SHALL NOT RELIEVE THE APPLICANT OF THE RESPONSIBILITY OF COMPLIANCE WITH ALL APPLICABLE CODES, INCLUDING ANY REQUESTS MADE BY INSPECTOR ON SITE FOR DEFICIENCIES THAT WERE DISCOVERED AND MUST BE CHECKED REWIR BY THE A.H.J.

**VERIFY SIGN LOCATION AND QUANTITY WITH SEPARATELY PERMITTED SIGN PACKAGE.**  
 LABEL THE TENANT'S DISCONNECT IN 1" LETTERING: "BISHOPS BARBER SHOP - 1 SOUTH MARKET ST."  
 VERIFY WITH UTILITY CO. EXISTING LOADS AND RATING OF TENANTS (IF PRESENT) SERVICE.

**SIGNAGE SHALL COMPLY WITH PERMITTED SIGN PACKAGE. ADJUST WHAT IS SHOWN HERE TO MATCH THE SIGN PACKAGE SET, TYPICAL UNDER A SEPARATE PERMIT.**  
 HOMERUNS AND BRANCH WIRING FOR 20 AMP CIRCUITS SHALL BE AS FOLLOWS:  
 LENGTH: NO.12 AWG, NO.10 AWG, NO.8 AWG, NO.6 AWG  
 1FT TO 50FT: NO.12 AWG, NO.10 AWG, NO.8 AWG, NO.6 AWG  
 51FT TO 100FT: NO.10 AWG, NO.8 AWG, NO.6 AWG  
 101FT TO 150FT: NO.10 AWG, NO.8 AWG, NO.6 AWG  
 151FT TO 300FT: NO.10 AWG, NO.8 AWG, NO.6 AWG  
 EXISTING ELECTRICAL SERVICE: 120/208V, 3 PH, 4 WIRE.  
 THERE WILL BE ONE ADDITIONAL EXISTING 3" CONDUIT WITH PULL STRING THAT WILL REMAIN AS UNUSED SPARE.



**LIGHTING CONTROL PANEL ZONES**

1. TRACK
2. 110V SOURCES
3. LOW VOLTAGE PENDANT/ MS
4. CONTROLLABLE OUTLET
5. SIGN
6. S/W RECEPTACLE #1
7. S/W RECEPTACLE #2
8. SPARE





DO NOT SCALE DRAWINGS  
CONTRACTOR TO VERIFY  
ALL EXISTING CONDITIONS AND  
DIMENSIONS - NOTIFY ARCHITECT  
OF ANY DISCREPANCIES PRIOR  
TO BEGINNING CONSTRUCTION

NO REVISION

ISSUE FOR PERMIT 09/18/17  
Peter A. Lepuch, P.E.  
1206 Golden Eagle Ct  
Aubrey, TX 76227  
(940) 735-5127

PROJECT NUMBER  
**C170357**

SHEET NUMBER  
**E3.0**  
ELECTRICAL  
TITLE 24  
DATE OF THIS PRINTING: 09/18/17

STATE OF CALIFORNIA  
**INDOOR LIGHTING**  
DECLARATION OF COMPLIANCE  
INDOOR LIGHTING  
Project Name: Bishops Date Prepared: 9/12/2017  
MCC-1101.4 (Page 3 of 4)

**C. Declaration of Required Certificates of Acceptance**  
Declare by selecting yes for all of the Certificates that will be submitted. (Printin copies and verify forms as completed and signed.)

YES  NO  Compliance Document/Title

YES  NO  NELA 11-02-A - Must be submitted for occupancy permits and automatic time switch controls.  Field Inspector

YES  NO  NELA 11-03-A - Must be submitted for automatic daylight controls.  Field Inspector

YES  NO  NELA 11-04-A - Must be submitted for demand responsive lighting controls.  Field Inspector

YES  NO  NELA 11-05-A - Must be submitted for institutional lighting power adjustment factor (PM).  Field Inspector

4. Separate lighting schedule must be filed out for conditioned and unconditioned spaces. Included lighting power based on this lighting schedule is only for:

CONDITIONED SPACE  UNCONDITIONED SPACE

5. Indoor Lighting Schedule and Field Inspector Energy Checklist  
 The actual indoor lighting power listed on the next 2 pages includes all installed permits and planned portable lighting systems.  
 When a Complete Building Method is used for compliance, list each different type of luminaire on separate lines.  
 Plans include track lighting in schedule, and submit the track lighting compliance document (MCC-1105.1) when the track lighting is installed.

CA Building Energy Efficiency Standards - 2015 Nonresidential Compliance  
April 2016

STATE OF CALIFORNIA  
**INDOOR LIGHTING**  
DECLARATION OF COMPLIANCE  
INDOOR LIGHTING  
Project Name: Bishops Date Prepared: 9/12/2017  
MCC-1101.4 (Page 4 of 4)

**D. Declaration of Required Certificates of Acceptance**  
Declare by selecting yes for all of the Certificates that will be submitted. (Printin copies and verify forms as completed and signed.)

YES  NO  Compliance Document/Title

YES  NO  NELA 11-02-A - Must be submitted for occupancy permits and automatic time switch controls.  Field Inspector

YES  NO  NELA 11-03-A - Must be submitted for automatic daylight controls.  Field Inspector

YES  NO  NELA 11-04-A - Must be submitted for demand responsive lighting controls.  Field Inspector

YES  NO  NELA 11-05-A - Must be submitted for institutional lighting power adjustment factor (PM).  Field Inspector

4. Separate lighting schedule must be filed out for conditioned and unconditioned spaces. Included lighting power based on this lighting schedule is only for:

CONDITIONED SPACE  UNCONDITIONED SPACE

5. Indoor Lighting Schedule and Field Inspector Energy Checklist  
 The actual indoor lighting power listed on the next 2 pages includes all installed permits and planned portable lighting systems.  
 When a Complete Building Method is used for compliance, list each different type of luminaire on separate lines.  
 Plans include track lighting in schedule, and submit the track lighting compliance document (MCC-1105.1) when the track lighting is installed.

CA Building Energy Efficiency Standards - 2015 Nonresidential Compliance  
April 2016

STATE OF CALIFORNIA  
**INDOOR LIGHTING**  
DECLARATION OF COMPLIANCE  
INDOOR LIGHTING  
Project Name: Bishops Date Prepared: 9/12/2017  
MCC-1101.4 (Page 1 of 4)

**A. General Information**  
Conditioned Floor Area: 1,003  
Unconditioned Floor Area: 0

Building Type:  Nonresidential  Hotel/Alcohol  Unconditioned Spaces

Method of Construction:  New Construction  Addition  Alteration

Method of Compliance:  Area Category  Tabulated

Project Address: 1 South Market Street

**B. Lighting Compliance Documents** (Select yes for each document included)  
 For additional information on the use of this and other energy efficiency standards compliance documents, refer to the Nonresidential Manual published by the California Energy Commission.

YES  NO  CEMC DOC - TITLE

YES  NO  NELA 11-02-A - Must be submitted for occupancy permits and automatic time switch controls. All pages required on plan for all submitted.

YES  NO  NELA 11-03-A - Must be submitted for automatic daylight controls. All pages required on plan for all submitted.

YES  NO  NELA 11-04-A - Must be submitted for demand responsive lighting controls. All pages required on plan for all submitted.

YES  NO  NELA 11-05-A - Must be submitted for institutional lighting power adjustment factor (PM). All pages required on plan for all submitted.

**C. Summary of Allowed Lighting Power**  
Conditioned and unconditioned space lighting must not be combined for compliance.

Item	Installed Lighting Power (Watts)	Watts	Notes
01	NELA 11-02-A, Table 1, page 5	1,109	Installed Lighting Power for Unconditioned Spaces MCC-1105.1, Table 1, page 1
02	NELA 11-02-A, Table 1, page 5	0	Portable Only for Offices MCC-1105.1, Table 1, page 1
03	Adjusted Installed Lighting Power (from 1,109 minus row 02)	0	Minus Lighting Control Credits Adjusted Installed Lighting Power (from 1,109 minus row 02)
04	Complies Only if Installed, Allowed (from row 03)	1,109	Complies Only if Installed, Allowed (from row 03)
05	Alterations with replacement luminaires that have at least 50/50% LED power compared to the original existing luminaires, may be included in the allowed wattage from MCC-1105, page 2.	1,501	Unconditioned MCC-1101.4, page 1

Alterations with replacement luminaires that have at least 50/50% LED power compared to the original existing luminaires, may be included in the allowed wattage from MCC-1105, page 2.

**D. Declaration of Required Certificates of Acceptance**  
Declare by selecting yes for all of the Certificates that will be submitted. (Printin copies and verify forms as completed and signed.)

YES  NO  Compliance Document/Title

YES  NO  NELA 11-02-A - Must be submitted for occupancy permits and automatic time switch controls.  Field Inspector

YES  NO  NELA 11-03-A - Must be submitted for automatic daylight controls.  Field Inspector

YES  NO  NELA 11-04-A - Must be submitted for demand responsive lighting controls.  Field Inspector

YES  NO  NELA 11-05-A - Must be submitted for institutional lighting power adjustment factor (PM).  Field Inspector

4. Separate lighting schedule must be filed out for conditioned and unconditioned spaces. Included lighting power based on this lighting schedule is only for:

CONDITIONED SPACE  UNCONDITIONED SPACE

5. Indoor Lighting Schedule and Field Inspector Energy Checklist  
 The actual indoor lighting power listed on the next 2 pages includes all installed permits and planned portable lighting systems.  
 When a Complete Building Method is used for compliance, list each different type of luminaire on separate lines.  
 Plans include track lighting in schedule, and submit the track lighting compliance document (MCC-1105.1) when the track lighting is installed.

CA Building Energy Efficiency Standards - 2015 Nonresidential Compliance  
April 2016

STATE OF CALIFORNIA  
**INDOOR LIGHTING**  
DECLARATION OF COMPLIANCE  
INDOOR LIGHTING  
Project Name: Bishops Date Prepared: 9/12/2017  
MCC-1101.4 (Page 2 of 4)

**E. Declaration of Required Certificates of Acceptance**  
Declare by selecting yes for all of the Certificates that will be submitted. (Printin copies and verify forms as completed and signed.)

YES  NO  Compliance Document/Title

YES  NO  NELA 11-02-A - Must be submitted for occupancy permits and automatic time switch controls.  Field Inspector

YES  NO  NELA 11-03-A - Must be submitted for automatic daylight controls.  Field Inspector

YES  NO  NELA 11-04-A - Must be submitted for demand responsive lighting controls.  Field Inspector

YES  NO  NELA 11-05-A - Must be submitted for institutional lighting power adjustment factor (PM).  Field Inspector

4. Separate lighting schedule must be filed out for conditioned and unconditioned spaces. Included lighting power based on this lighting schedule is only for:

CONDITIONED SPACE  UNCONDITIONED SPACE

5. Indoor Lighting Schedule and Field Inspector Energy Checklist  
 The actual indoor lighting power listed on the next 2 pages includes all installed permits and planned portable lighting systems.  
 When a Complete Building Method is used for compliance, list each different type of luminaire on separate lines.  
 Plans include track lighting in schedule, and submit the track lighting compliance document (MCC-1105.1) when the track lighting is installed.

CA Building Energy Efficiency Standards - 2015 Nonresidential Compliance  
April 2016

STATE OF CALIFORNIA  
**INDOOR LIGHTING**  
DECLARATION OF COMPLIANCE  
INDOOR LIGHTING  
Project Name: Bishops Date Prepared: 9/12/2017  
MCC-1101.4 (Page 3 of 4)

**F. Declaration of Required Certificates of Acceptance**  
Declare by selecting yes for all of the Certificates that will be submitted. (Printin copies and verify forms as completed and signed.)

YES  NO  Compliance Document/Title

YES  NO  NELA 11-02-A - Must be submitted for occupancy permits and automatic time switch controls.  Field Inspector

YES  NO  NELA 11-03-A - Must be submitted for automatic daylight controls.  Field Inspector

YES  NO  NELA 11-04-A - Must be submitted for demand responsive lighting controls.  Field Inspector

YES  NO  NELA 11-05-A - Must be submitted for institutional lighting power adjustment factor (PM).  Field Inspector

4. Separate lighting schedule must be filed out for conditioned and unconditioned spaces. Included lighting power based on this lighting schedule is only for:

CONDITIONED SPACE  UNCONDITIONED SPACE

5. Indoor Lighting Schedule and Field Inspector Energy Checklist  
 The actual indoor lighting power listed on the next 2 pages includes all installed permits and planned portable lighting systems.  
 When a Complete Building Method is used for compliance, list each different type of luminaire on separate lines.  
 Plans include track lighting in schedule, and submit the track lighting compliance document (MCC-1105.1) when the track lighting is installed.

CA Building Energy Efficiency Standards - 2015 Nonresidential Compliance  
April 2016

STATE OF CALIFORNIA  
**INDOOR LIGHTING**  
DECLARATION OF COMPLIANCE  
INDOOR LIGHTING  
Project Name: Bishops Date Prepared: 9/12/2017  
MCC-1101.4 (Page 4 of 4)

**G. Installed Portable Luminaires in Offices - Description to Section 160.44**  
This section shall be filed out ONLY for portable luminaires in offices (as defined in §160.1). All other planned portable luminaires shall be documented on next page of this compliance document.  
This section is used to determine if portable lighting is planned for any office.  
Fill out a separate line for each different office. Small offices that are together during the same general and portable lighting may be grouped together. This allowance shall not be treated between offices having different lighting systems.

Office/Portable Luminaire Schedule	1	2	3	4	5	6	7	8	9	10
Complete Luminaire Description (If LED, under column, luminaires mounted directly/indirect)										
Watts per luminaire										
Number of luminaires										
Office Location										
Field Inspector										

Total installed portable luminaire watts that are greater than 0.3 W/ft<sup>2</sup> per office: \_\_\_\_\_  
MCC-1101.4, Page 1

CA Building Energy Efficiency Standards - 2015 Nonresidential Compliance  
April 2016

STATE OF CALIFORNIA  
**INDOOR LIGHTING**  
DECLARATION OF COMPLIANCE  
INDOOR LIGHTING  
Project Name: Bishops Date Prepared: 9/12/2017  
MCC-1101.4 (Page 1 of 4)

**H. Indoor Lighting Schedule and Field Inspector Energy Checklist**  
A separate lighting schedule must be filed out for conditioned and unconditioned spaces. Included lighting power based on this lighting schedule is only for:

CONDITIONED SPACE  UNCONDITIONED SPACE

Item	01	02	03	04	05	06	07	08	09
Name or Item Tag									
Complete Luminaire Description (If LED, over dimmable electronic ballast)									
Watts per luminaire									
Number of luminaires									
Location									
Field Inspector									

INSTALLED WATTS PAGE TOTAL: 1,109  
MCC-1101.4, Page 2

CA Building Energy Efficiency Standards - 2015 Nonresidential Compliance  
April 2016





DO NOT SCALE DRAWINGS  
 CONTRACTOR TO VERIFY  
 ALL EXISTING CONDITIONS AND  
 DIMENSIONS-NOTIFY ARCHITECT  
 OF ANY DISCREPANCIES PRIOR  
 TO BEGINNING CONSTRUCTION

NO REVISION

ISSUE FOR PERMIT 09/18/17  
 CA-M-5200/CA-E-19072  
 6401 735-5127  
 Audrey, TX 76227  
 Peter A. Lebach, P.E.  
 1236 Golden Eagle Court  
 Aubrey, TX 76227

PROJECT NUMBER  
**C170357**

SHEET NUMBER

**E31**  
**ELECTRICAL**  
 DATE OF THIS PERMIT: 09/18/17

STATE OF CALIFORNIA  
**INDOOR LIGHTING - LIGHTING CONTROLS**  
 CERTIFICATE OF COMPLIANCE  
 Indoor Lighting - Lighting Controls  
 Project Name: Bishops  
 Date: 09/18/17

**DECLARATION BY THE APPLICANT**  
 I, the undersigned, hereby certify that the information provided in this certificate is true and correct to the best of my knowledge and belief, and that I am a duly licensed professional engineer in the State of California. I understand that a completed signed copy of this certificate is required to be included with the permit application for this building, and that I am responsible for the accuracy of the information provided in this certificate.

**DECLARATION BY THE ENGINEER**  
 I, the undersigned, hereby certify that I am a duly licensed professional engineer in the State of California. I understand that a completed signed copy of this certificate is required to be included with the permit application for this building, and that I am responsible for the accuracy of the information provided in this certificate.

Signature: Peter A. Lebach, P.E.  
 Title: Professional Engineer  
 License No.: E 19072  
 Address: 1236 Golden Eagle Court, Aubrey, TX 76227  
 Phone: (848) 735-5127

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance  
 January 2016

STATE OF CALIFORNIA  
**INDOOR LIGHTING - LIGHTING CONTROLS**  
 CERTIFICATE OF COMPLIANCE  
 Indoor Lighting - Lighting Controls  
 Project Name: Bishops  
 Date: 09/18/17

**A. Mandatory Lighting Control Declaration Statements** (Indicate if the measure applies by checking yes or no below.)

YES	NO	Control Requirements
<input checked="" type="checkbox"/>	<input type="checkbox"/>	Lighting shall be controlled by self-contained lighting control devices which are certified to the Energy Commission according to the Title 20 Appliance Efficiency Regulations in accordance with Section 130.9.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	Lighting shall be controlled by a lighting control system or energy management control system in accordance with Section 130.9. An Installation Certificate shall be submitted in accordance with Section 130.10.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	One or more Track Lighting Linear Control Systems shall be installed which have been certified to the Energy Commission in accordance with Section 130.9 and Section 130.10. Additionally, an Installation Certificate shall be submitted in accordance with Section 130.10.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	All lighting controls and equipment shall comply with the applicable requirements in Section 130.10 and shall be installed in accordance with the manufacturer's instructions in accordance with Section 130.11.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	All luminaires shall be functionally controlled with manually switched ON and OFF lighting controls in accordance with Section 130.11.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	General lighting shall be separately controlled from all other lighting systems in use. Floor and wall lighting, decorative lighting, exit lighting, emergency lighting, and special effects lighting shall each be separately controlled on circuits that are 20 amps or less. When track lighting is used, general lighting, exit lighting, emergency lighting, and special effects lighting shall each be separately controlled, in accordance with Section 130.11(A).
<input checked="" type="checkbox"/>	<input type="checkbox"/>	The general lighting of any enclosed area 200 square feet or larger, with a connected lighting load that exceeds 0.5 watts per square foot shall meet the multi-level lighting control requirements in accordance with Section 130.11(A).
<input checked="" type="checkbox"/>	<input type="checkbox"/>	All installed outdoor lighting shall be equipped with controls that meet the applicable shut OFF control requirements in Section 130.11(A).
<input checked="" type="checkbox"/>	<input type="checkbox"/>	Lighting in all Daylit Zones shall be controlled in accordance with the requirements in Section 130.10 (a) and daylight zones are shown on the plans.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	Lighting power in buildings larger than 10,000 square feet shall be capable of being automatically reduced in response to a detected responsive signal in accordance with Section 130.10 (b).
<input checked="" type="checkbox"/>	<input type="checkbox"/>	Before an occupancy permit is granted for a newly constructed building or area, or a new lighting system serving a building, area, or site is operated for normal use, indoor lighting controls serving the building, area, or site shall be certified as meeting the Acceptance Requirements for Code Compliance in accordance with Section 130.11(A). The controls required to meet the Acceptance Requirements include automatic daylight controls, automatic shut OFF controls, and demand responsive control.

**B. Multiple Pages-Are Used. ENTER SUM TOTAL OF Control Credit for all pages HERE (Sum of all Column 13):** 0  
**Control Credit Total (Sum of all Column 13):** 0  
 Enter Control Credit Total into INCC-1101-E, Page 1.

**1. \$130.10 - Allowance for Controls - Multi Level - Auto Shut-Off - Auto Shut-Off - Mandatory Daylight - \$130.10 - Demand Responsive - \$462.648 = \$462.648**  
**2. Check Table 140-A for control factor. PWA has not yet been approved and unconditioned spaces. As a condition to entry to PWA, an Installation Certificate is also required to be filed out, signed, and submitted.**

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance  
 January 2016

STATE OF CALIFORNIA  
**INDOOR LIGHTING POWER ALLOWANCE**  
 CERTIFICATE OF COMPLIANCE  
 Certificate of Compliance - Indoor Lighting Power Allowance  
 Project Name: Bishops  
 Date: 09/18/17

**A. SUMMARY TOTALS OF LIGHTING POWER ALLOWANCES**

TYPE OF BUILDING (From 140-A Table 140-A)	WATS PER FT <sup>2</sup>	COMPOSITE BLDG. AREA	ALLOWED WATS
Office	1.501	112	1,501
Unconditioned Spaces	0	0	0
<b>TOTAL ALLOWED BUILDING WATS</b>			<b>1,501</b>

**B. COMPLETE BUILDING METHOD LIGHTING POWER ALLOWANCE**

TYPE OF BUILDING (From 140-A Table 140-A)	WATS PER FT <sup>2</sup>	COMPOSITE BLDG. AREA	ALLOWED WATS
Office	1.501	112	1,501
Unconditioned Spaces	0	0	0
<b>TOTAL WATS</b>			<b>1,501</b>

**C-1 AREA CATEGORY METHOD LIGHTING POWER ALLOWANCES**

AREA CATEGORY	WATS PER FT <sup>2</sup>	AREA (FT <sup>2</sup> )	ALLOWED WATS
Office	1.501	112	1,501
Unconditioned Spaces	0	0	0
<b>TOTAL WATS</b>			<b>1,501</b>

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance  
 April 2016

STATE OF CALIFORNIA  
**INDOOR LIGHTING - LIGHTING CONTROLS**  
 CERTIFICATE OF COMPLIANCE  
 Indoor Lighting - Lighting Controls  
 Project Name: Bishops  
 Date: 09/18/17

**A. SUMMARY TOTALS OF LIGHTING POWER ALLOWANCES**

TYPE OF BUILDING (From 140-A Table 140-A)	WATS PER FT <sup>2</sup>	COMPOSITE BLDG. AREA	ALLOWED WATS
Office	1.501	112	1,501
Unconditioned Spaces	0	0	0
<b>TOTAL ALLOWED BUILDING WATS</b>			<b>1,501</b>

**B. COMPLETE BUILDING METHOD LIGHTING POWER ALLOWANCE**

TYPE OF BUILDING (From 140-A Table 140-A)	WATS PER FT <sup>2</sup>	COMPOSITE BLDG. AREA	ALLOWED WATS
Office	1.501	112	1,501
Unconditioned Spaces	0	0	0
<b>TOTAL WATS</b>			<b>1,501</b>

**C-1 AREA CATEGORY METHOD LIGHTING POWER ALLOWANCES**

AREA CATEGORY	WATS PER FT <sup>2</sup>	AREA (FT <sup>2</sup> )	ALLOWED WATS
Office	1.501	112	1,501
Unconditioned Spaces	0	0	0
<b>TOTAL WATS</b>			<b>1,501</b>

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance  
 January 2016

STATE OF CALIFORNIA  
**INDOOR LIGHTING POWER ALLOWANCE**  
 CERTIFICATE OF COMPLIANCE  
 Certificate of Compliance - Indoor Lighting Power Allowance  
 Project Name: Bishops  
 Date: 09/18/17

**A. SUMMARY TOTALS OF LIGHTING POWER ALLOWANCES**

TYPE OF BUILDING (From 140-A Table 140-A)	WATS PER FT <sup>2</sup>	COMPOSITE BLDG. AREA	ALLOWED WATS
Office	1.501	112	1,501
Unconditioned Spaces	0	0	0
<b>TOTAL ALLOWED BUILDING WATS</b>			<b>1,501</b>

**B. COMPLETE BUILDING METHOD LIGHTING POWER ALLOWANCE**

TYPE OF BUILDING (From 140-A Table 140-A)	WATS PER FT <sup>2</sup>	COMPOSITE BLDG. AREA	ALLOWED WATS
Office	1.501	112	1,501
Unconditioned Spaces	0	0	0
<b>TOTAL WATS</b>			<b>1,501</b>

**C-1 AREA CATEGORY METHOD LIGHTING POWER ALLOWANCES**

AREA CATEGORY	WATS PER FT <sup>2</sup>	AREA (FT <sup>2</sup> )	ALLOWED WATS
Office	1.501	112	1,501
Unconditioned Spaces	0	0	0
<b>TOTAL WATS</b>			<b>1,501</b>

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance  
 April 2016

STATE OF CALIFORNIA  
**INDOOR LIGHTING POWER ALLOWANCE**  
 CERTIFICATE OF COMPLIANCE  
 Certificate of Compliance - Indoor Lighting Power Allowance  
 Project Name: Bishops  
 Date: 09/18/17

**A. SUMMARY TOTALS OF LIGHTING POWER ALLOWANCES**

TYPE OF BUILDING (From 140-A Table 140-A)	WATS PER FT <sup>2</sup>	COMPOSITE BLDG. AREA	ALLOWED WATS
Office	1.501	112	1,501
Unconditioned Spaces	0	0	0
<b>TOTAL ALLOWED BUILDING WATS</b>			<b>1,501</b>

**B. COMPLETE BUILDING METHOD LIGHTING POWER ALLOWANCE**

TYPE OF BUILDING (From 140-A Table 140-A)	WATS PER FT <sup>2</sup>	COMPOSITE BLDG. AREA	ALLOWED WATS
Office	1.501	112	1,501
Unconditioned Spaces	0	0	0
<b>TOTAL WATS</b>			<b>1,501</b>

**C-1 AREA CATEGORY METHOD LIGHTING POWER ALLOWANCES**

AREA CATEGORY	WATS PER FT <sup>2</sup>	AREA (FT <sup>2</sup> )	ALLOWED WATS
Office	1.501	112	1,501
Unconditioned Spaces	0	0	0
<b>TOTAL WATS</b>			<b>1,501</b>

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance  
 April 2016



