

March 5, 2013

ADDENDUM NO. 3

Bid Package 13-01R

BROOKSIDE ELEMENTARY SCHOOL – BUILDING B
DSA NO. 03-113415

OAK PARK UNIFIED SCHOOL DISTRICT

OAK PARK, CA

This Addendum is being sent out to all contractors who are current plan holders.

In accordance with the contract documents, Section 00100 Instruction to Bidders: Paragraph 12 - Interpretation of Drawings, Specifications or Contract Documents, the following information or clarifications to the contract documents or drawings is hereby being provided.

All information provided in this Addendum shall become a part of the Contract and Contract Documents for:

Brookside Elementary School – Building B

SPECIFICATIONS

Item No. 1:

Refer to Addendum No. 1, dated February 8, 2013, Specifications Section 10 28 13, Toilet and Bath Accessories, Page 10 28 13-2, Paragraph 2.01, A., 2. and add the following sub-paragraphs:

- g. Dyson, 888-DYSON-AB, www.dyson.com
- h. Kutol, www.kutol.com

Item No. 2:

Refer to Addendum No. 1, dated February 8, 2013, Specifications Section 10 28 13, Toilet and Bath Accessories, Page 10 28 13-3 and revise Paragraph 2.04, B., 2., as follows:

2. Sizes Nominal: 18" x 36"; other sizes as indicated on Drawings.

Item No. 3:

Refer to Addendum No. 1, dated February 8, 2013, Specifications Section 10 28 13, Toilet and Bath Accessories, Page 10 28 13-3 and delete Paragraph 2.04, D. and replace with the following:

- D. Surface Soap Dispensers: Kutol EZ Hand Hygiene No. 9942 BLK, less than 5 lb. force to operate valve.

Item No. 4:

Refer to Addendum No. 1, dated February 8, 2013, Specifications Section 10 28 13, Toilet and Bath Accessories, Page 10 28 13-4 and delete Paragraph 2.04, J. and replace with the following:

- J. Electric Hand Dryer: Dyson Airblade V No. AB12 sprayed nickel finish, surface-mounted. Unit shall extend a maximum of 3-7/8" from wall finish to comply with ADA requirements. District-Furnished, Contractor-Installed. Refer to the attached Product Data Sheet, 2 pages.

Item No. 5:

Refer to Addendum No. 1, dated February 8, 2013, Specifications Section 09 68 13, Carpet Tiles, Page 09 68 13-4, Paragraph 1.5, C., and add the following paragraph:

- 3. Contractor to purchase four additional boxes of carpet tiles, one each of four colors listed below to be turned over to the District:
 - A. One (1) box of SHAW color #62407, Blue
 - B. One (1) box of SHAW color #62350, Green
 - C. One (1) box of SHAW color #62201, Citrus
 - D. One (1) box of SHAW color #62675, Orange

Item No. 6:

Refer to Drawing AD1-A4.61, Details 3, 4 and 7, dated January 7, 2013 for applicable curb and floor attachment details for non-load bearing walls. The new walls replacing the demountable partitions and at the new windows are non-load bearing.

ADDENDUM NO. 3
BROOKSIDE ELEMENTARY SCHOOL – BUILDING B
DSA NO. 03-114189
MARCH 5, 2013

DRAWINGS

Item No. 7:

Refer to Drawing AD1-P2.2A, dated January 7, 2013 and add the attached Drawing AD3-P1, dated March 4, 2013 for missing hose bibbs.

Each Subcontractor providing a proposal for the above mentioned project shall be required to acknowledge this Addendum as stated on the Bid Form – 00210, Page 2 of 4, Section 1.3, Acknowledgement Bid Addenda. Any Contractor who does not acknowledge this Addendum will be deemed Non-Responsive and the bid returned.

For any additional information regarding the Addendum you may contact me at the numbers provided below.

Thank you,

Keith Henderson
District Representative for the Oak Park Unified School District Measure "R"
Program/Construction Manager

Balfour Beatty Construction

email: khenderson@balfourbeattyus.com

dyson airblade V

**AB
12**

Electrical

Input voltage/Frequency: 120V-127V 60 Hz

Rated power: 1400 W

Motor type: Dyson digital motor – V4 brushless DC Motor

Motor switching rate: 6,100 per second

Motor speed: 92,000 rpm

Operating temperature range: 0°– 40°C

Heater type: None

Standby power consumption: Less than 0.5 W

Construction

Casing construction: Polycarbonate casing

Antimicrobial coating type: AB12 (Sprayed nickel) Antimicrobial additive in paint. AB12 (White) Antimicrobial molded additive

Bacterial reduction rate from external surfaces: Up to 99.9% over 24 hours

Color finish: AB12 Sprayed nickel molded plastic.

AB12 White molded plastic.

Back plate/mounting bracket construction: ABS/PBT Plastic

Exterior screw type: Anti-tamper M4 Pin-Hex

Water ingress protection to IP24

Filter

HEPA filter (Glass fiber and fleece prelayer)

Bacteria removal 99.97% at 0.3 microns

Operation

Proximity capacitive sensor. Touch free operation.

Hand dry time measurement: 12 seconds

(Measurement based on National Sanitation Foundation Protocol P335)

Operation lock-out period: 30 seconds

Airspeed at apertures: 420 mph

Operating airflow: Up to 28 l/s

Logistics

Serial number prefix: AB12 (Sprayed nickel) AR7; AB12 (White) AR6

Single unit order code: AB12 (Sprayed nickel) 25887-01;

AB12 (White) 25878-01

Net weight: AB12 6.17 lb

Packaged weight: AB12 8.81 lb

Packaged dimensions: H5.71 × W17.91 × D10.79 in

Unit barcode: AB12 (Sprayed nickel) 8799 5700 908 0;

AB12 (White) 8799 5700 907 3

Standard warranty

5 year parts and 5 year limited labor warranty



Product range

AB12 Sprayed Nickel

AB12 White



The Carbon Reduction Label is the registered trade mark of the Carbon Trust. The NSF logo is the registered trade mark of NSF International.

For further information please contact Dyson.
888-DYSON-AB • www.dyson.com/handdryers


dyson airblade V

TECHNICAL SPECIFICATION


AB
12



REAR ELEVATION



SIDE ELEVATION



All dimensions shown in inches (+/-0.19 in)

FLOOR

Recommended installation heights from floor

Male	X 52.12 in	Y 51.18 in	Z 36.61 in
Female	X 50.75 in	Y 49.80 in	Z 35.23 in
Child or disabled	X 42.28 in	Y 41.53 in	Z 26.77 in
Child 5-8	X 37.48 in	Y 36.53 in	Z 21.97 in
Child 8-11	X 41.42 in	Y 40.47 in	Z 25.91 in
Child 11-14	X 44.57 in	Y 43.62 in	Z 29.05 in

Machine dimensions

Height 3.93 in Width 15.51 in Depth 9.21 in


Minimum clearance

8.66 in clearance either side and 1.18 in above machine.

Cable entry point from floor


Male	42.87 in
Female	41.50 in
Child or disabled	30.03 in
Child 5-8	28.23 in
Child 8-11	32.17 in
Child 11-14	35.31 in


For further information, please contact Dyson.
888-DYSON-AB • www.dyson.com/handdryers




KEY NOTE:

◆ PROVIDE HOSE BIBB BELOW LAVATORY AT BOY'S AND GIRL'S RESTROOMS..

PLUMBING FIXTURE SCHEDULE			
ROUGH-IN CONNECTIONS			
SYMBOL	DESCRIPTION	COLD WATER	REMARKS
	HOSE BIBB ACORN #8121-CP	3/4"	*ACORN® HOSE VALVES MODEL #8121 BENT NOSE WITH FLANGE WITH LOCK SHIELD BONNET AND REMOVABLE KEY HANDLE. INTERIOR WALL HOSE VALVES CHROME PLATED FINISH. INSTALL AT RESTROOMS BELOW LAVATORY.

PBS

ENGINEERS
 Mechanical and Electrical Consulting Engineers

2100 East Route 66, Suite 101
 Glendora, California 91740-4623
 Tel: (626) 650-0350
 Fax: (626) 650-0352
 WWW.PBSENGINEERS.COM
 Job No. 2010-014-01



Brookside Elementary School Building B (Bid and CA)

REFERENCE: AD1-P2.2A



OAK PARK UNIFIED SCHOOL DISTRICT

DRAWING NO.

DATE: March 4, 2013

AD3-P1

PROJECT NO.: 234808

KPI ARCHITECTS INC.
 ARCHITECTURE, PLANNING, INTERIOR DESIGN
 650 EAST PARKRIDGE AVENUE, SUITE 105
 CORONA, CALIFORNIA 92879-1092
 PHONE: (800) 366-6381 FAX: (877) 493-2059