

**GENERAL NOTES**

- THE CONTRACTOR SHALL PROVIDE ALL MATERIAL, LABOR, TOOLS, EQUIPMENT, TESTING, AND SERVICES NECESSARY FOR A COMPLETE AND OPERABLE ELECTRICAL SYSTEM. THE WORK SHALL INCLUDE, BUT NOT BE LIMITED TO POWER, CONTROL AND GROUNDING CABLE DISCONNECTIONS, LOW AND MEDIUM VOLTAGE EQUIPMENT REMOVAL, RESETTING OF NEW LOW AND MEDIUM VOLTAGE EQUIPMENT, CONNECTION OF POWER, CONTROL, INSTRUMENTATION AND GROUNDING CABLE, TAGGING AND TESTING, AND LEVELING ANCHORING AND SEISMIC BRACING OF NEW EQUIPMENT.
- THE CONTRACTOR SHALL PROVIDE THE MAJOR LONG-DELIVERY, ENGINEERED EQUIPMENT FOR THIS PROJECT. THE CONTRACTOR SHALL BE RESPONSIBLE FOR PICKING UP THIS EQUIPMENT (OR ACCEPTING DELIVERY) AND INSTALLING AT THE JOB SITE. ALL OTHER EQUIPMENT NOT SPECIFICALLY PROVIDED BY THE OWNER SHALL BE PROVIDED BY THE CONTRACTOR. THE CONTRACTOR SHALL BE RESPONSIBLE FOR FURNISHING AND INSTALLING ALL INCIDENTAL ITEMS NOT ACTUALLY SHOWN OR SPECIFIED, BUT WHICH ARE REQUIRED BY STANDARDS, CODES, REGULATIONS AND GOOD PRACTICE TO PROVIDE COMPLETE FUNCTIONAL SYSTEMS.
- ALL MATERIALS AND EQUIPMENT SHALL BE NEW, FREE FROM DEFECTS, OF CURRENT MANUFACTURE, AND OF THE QUALITY SPECIFIED OR SHOWN, AND SHALL BE LISTED AND LABELED BY THE UNDERWRITERS LABORATORIES, INC. (UL) FOR THE PURPOSE FOR WHICH IT IS TO BE USED WHERE SUCH LISTING HAS BEEN ESTABLISHED BY UL. EACH TYPE OF MATERIAL SHALL BE OF THE SAME MANUFACTURE AND QUALITY THROUGHOUT THE WORK. SELECTED MANUFACTURER SHALL HAVE A MINIMUM OF 5 YEARS OF CUSTOMER REFERRALS FOR PRODUCT BEING CONSIDERED.
- THE CONTRACTOR SHALL OBTAIN, PAY AND COMPLY WITH ALL PERMITS AND LICENSES REQUIRED BY LOCAL AUTHORITIES HAVING INSPECTION JURISDICTION, LOCAL ORDINANCES, STATE, AND FEDERAL LEGISLATION. ALL CONSTRUCTION PERMITTING AND FEES REQUIRED SHALL BE BY THE CONTRACTOR.
- CONDUIT SIZES, WIRE SIZES AND THEIR RESPECTIVE LENGTHS ARE ESTIMATED. THE CONTRACTOR SHALL BE RESPONSIBLE FOR WIRE SIZE CHANGES WHEN INSTALLED MOTOR H.P.'S ARE DIFFERENT FROM THOSE SHOWN ON CONTRACT DRAWINGS.
- THE CONTRACTOR SHALL FIELD VERIFY ALL INFORMATION AS SHOWN ON THESE DRAWINGS, AS WELL AS ALL "HOLDS" FOR MISSING INFORMATION NOT SHOWN ON CONTRACT DRAWINGS AND TO CONFIRM ALL OF THE ABOVE WITH THE OWNER'S REPRESENTATIVE. THE CONTRACTOR SHALL MARK-UP A SET OF THESE DRAWINGS FOR "AS BUILT", AND DELIVER TO THE OWNER'S REPRESENTATIVE AFTER ALL WORK HAS BEEN COMPLETED. THE DRAWINGS WERE DEVELOPED FROM PAST RECORD DRAWINGS AND INFORMATION SUPPLIED BY THE OWNER AND MAY NOT REFLECT THE AS-BUILT CONDITIONS. THE CONTRACTOR SHALL FIELD SURVEY ALL EXISTING CONDITIONS AND MAKE ADJUSTMENTS TO SUIT THE FIELD CONDITIONS.
- INSTALLATIONS MAY OCCUR WHILE THE FACILITY IS OPERATING. DURING THIS WORK, THE OWNER'S OPERATING PERSONNEL WILL BE WORKING IN THE FACILITY. THE CONTRACTOR SHALL POST THE AREA FOR SAFETY WHERE WORK IS BEING PERFORMED, AS REQUIRED. POSTING CAN BE WITH THE USE OF BARRICADES AND CONSTRUCTION TAPE ENCOMPASSING THE AREA.
- THE CONTRACTOR SHALL COORDINATE HIS WORK WITH THE OWNER IN ORDER TO KEEP A MINIMUM INTERRUPTION OF EXISTING OPERATIONS AND TO PRECLUDE ANY UNSAFE CONDITIONS.
- THE DE-ENERGIZATION AND RE-ENERGIZATION OF EXISTING CIRCUITS AND ENERGIZATION OF NEW CIRCUITS SHALL BE DONE BY THE ELECTRICAL INSPECTOR. CUTTING OF EXISTING CIRCUITS SHALL BE COORDINATED BY THE ELECTRICAL INSPECTOR.
- DOWNTIME OF THE ELECTRICAL POWER SYSTEM TO THE OPERATING FACILITIES SHALL BE KEPT TO A MINIMUM. POWER OUTAGES TO THE FACILITIES MAY BE LIMITED TO THE WEEKENDS, AND ALL OUTAGES SHALL BE COORDINATED BETWEEN THE CONTRACTOR AND THE OWNER.
- THE CONTRACTOR IS RESPONSIBLE FOR LEAVING THE JOB SITE (AND ANY OTHER AREA USED BY THE CONTRACTOR) IN A CLEAN, SAFE AND ORDERLY CONDITION AT THE END OF EACH WORK DAY AND AT THE CONCLUSION OF THE JOB. ELECTRICAL DISTRIBUTION EQUIPMENT SHALL BE PROTECTED FROM DUST OR MOISTURE WITH PLASTIC SHEETING OVER ANY VENTILATION OPENINGS DURING THE CONSTRUCTION PHASE OF THE WORK. PROVIDE FILTERED AIR (FILTER SHALL NOT PASS A PARTICLE LARGER THAN 90 MICRON IN DIAMETER) TO COOL ANY EQUIPMENT THAT MAY BECOME OVERHEATED WITH THE PLASTIC COVER.
- JUNCTION BOXES SHOWN ON CONTRACT DRAWINGS ARE SHOWN CONCEPTUALLY FOR THE CONDUIT SYSTEM. CONTRACTOR SHALL PROVIDE ADDITIONAL BOXES AS REQUIRED FOR THE CONDUIT SYSTEM. JUNCTION BOXES AND ENCLOSURES SHALL BE SIZED PROPERLY TO COMPLY WITH NEC REQUIREMENTS.
- THE CONTRACTOR SHALL SET AND ANCHOR, CONNECT AND TEST THE NEW EQUIPMENT IN ACCORDANCE WITH THE DRAWINGS, SPECIFICATIONS AND MANUFACTURER RECOMMENDATIONS. USE THE MOST STRICT REQUIREMENT WHERE REQUIREMENTS DIFFER. PERFORM COMPLETE OPERATIONAL TESTS ON ALL COMPONENTS AND ALL OTHER MISCELLANEOUS EQUIPMENT AND ACCESSORIES REQUIRED.
- THE CONTRACTOR SHALL BE RESPONSIBLE FOR COMPLETING ALL REQUIRED ADJUSTMENTS TO MEET FINAL ACCEPTANCE CRITERIA IN ACCORDANCE WITH ALL APPLICABLE SECTIONS OF THE SPECIFICATIONS AND THE OWNER'S REPRESENTATIVE.
- THE CONTRACTOR IS RESPONSIBLE FOR FINAL SYSTEM "SIGN-OFF" TO THE OWNER. THE CONTRACTOR SHALL HAVE NECESSARY DOCUMENTS READY FOR SIGNATURES AT TIME OF
- THE CONTRACTOR SHALL DISPOSE OF ALL SURPLUS, OR SCRAP MATERIALS GENERATED BY THE PROJECT ANY COST OF SUCH DISPOSAL SHALL BE BORNE BY THE CONTRACTOR, AND ANY REVENUE RECEIVED SHALL BELONG TO THE CONTRACTOR.
- ELECTRICAL CONTRACTOR TO COORDINATE WITH GENERAL CONTRACTOR FOR ALL PATCH WORK.
- ALL WIRES SHALL BE THHN/THWN 75°, 600V RATED AND SHALL RUN INSIDE EMT.
- ALL 120V, 20A CIRCUITS SHALL BE 2#12 & 1#12 GROUND U.O.N.
- ALL CONDUITS SHALL BE EMT.
- ALL INSTALLATION SHALL COMPLY WITH THE 2016 CALIFORNIA ELECTRICAL CODE, 2016 CALIFORNIA BUILDING CODE, 2016 CALIFORNIA MECHANICAL CODE, 2016 CALIFORNIA ELECTRICAL CODE, 2016 CALIFORNIA PLUMBING CODE, 2016 CALIFORNIA ENERGY CODE, AND THE 2016 CALIFORNIA FIRE CODE.

**ELECTRICAL SYMBOLS**

SYMBOL	DESCRIPTION
	FLUORESCENT LIGHTING FIXTURE, RECESSED MOUNTED.
	FLUORESCENT LIGHTING FIXTURE, SURFACE OR SUSPENDED.
	INCANDESCENT AND HID LIGHTING FIXTURES, CLG. & WALL MTD.
	FLOOD LIGHTING UNIT.
	EXIT SIGN, DIRECTIONAL ARROWS INDICATED.
	STRIP FLUORESCENT LIGHTING UNIT, SURFACE OR SUSPENDED.
	JUNCTION OR PULL BOX.
	SINGLE PLEX RECEPTACLE, MOUNTED 18" UP UNLESS NOTED OTHERWISE.
	DUPLEX RECEPTACLE, 20A, MOUNTED 18" UP UNLESS NOTED OTHERWISE.
	QUAD RECEPTACLE, 20A. TWO DUPLEX RECEPTACLES GANG MOUNTED.
	DUPLEX RECEPTACLE, 30A, MOUNTED 18" UP UNLESS NOTED OTHERWISE. ALL 30A 120V CIRCUITS SHALL BE 2#10,1#0G,3/4"C.
	GROUND FAULT INTERRUPTING RECEPTACLE.
	WEATHER PROOF GROUND FAULT INTERRUPTING RECEPTACLE.
	CEILING MTD CORD REEL WITH 30 FOOT CORD REEL, HEAVY DUTY STEEL CASE, AND 14/3 SJO CORD AND DUPLEX NEMA #5-15R RECEPTACLE IN A HARD RUBBER BOX. ERICSON MODEL #4143-30-B, OR EQUIVALENT.
	DUPLEX RECEPTACLE IN HANDY BOX MOUNTED ON CONDUIT STUB.
	POLARIZED THREE OR FOUR WIRE RECEPTACLE, RATING NOTED.
	CEILING MOUNTED DUPLEX RECEPTACLE
	CEILING MOUNTED QUAD RECEPTACLE. TWO DUPLEX GANG MOUNTED
	FLUSH FLOOR MOUNTED 20A QUAD RECEPTACLE. WITH ALL REQUIRED FITTINGS AND BRASS COVER. VERIFY FLOOR COVERING AND TYPE, U.O.N.
	NEMA TWISTLOCK RECEPTACLE L5-20 (120V, 1P)
	SINGLE POLE SWITCH MOUNTED 48" UP UNLESS NOTED OTHERWISE.
	TWO POLE, THREE WAY, FOUR WAY SWITCHES MTD. 48" UP UNLESS NOTED OTHERWISE.
	KEY OPERATED SWITCH, PILOT LIGHT SWITCH, MTD. 48" UP UNLESS NOTED OTHERWISE.
	NUMBER DENOTES SINGLE POLE SWITCHES GANG MOUNTED.
	TELEPHONE OUTLET MTD. 18" UP UNLESS NOTED OTHERWISE.
	COMPUTER
	COMBINATION TELEPHONE/DATA OUTLET, MTD. 18" UP UNLESS NOTED OTHERWISE.
	FLUSH FLOOR MOUNTED COMBINATION VOICE/DATA OUTLET WITH ALL REQUIRED FITTINGS AND BRASS COVER. VERIFY THE FLOOR COVERING AND TYPE, U.O.N.
	CIRCUIT IDENTIFICATION, PANELBOARD ID - CIRCUIT NUMBER. ALL 20A 120V CIRCUITS SHALL BE 2#12,1#2G,3/4"C. ALL 30A 120V CIRCUITS SHALL BE 2#10,1#0G,3/4"C.
	TIME SWITCH, PHOTO-ELECTRIC SWITCH.
	MANUAL MOTOR STARTER-DISCONNECT SWITCH.
	MOTOR DISCONNECT OR FUSED SAFETY SWITCH.
	MOTOR.
	ELECTRICAL PANELBOARDS, SURFACE AND FLUSH MOUNTED.
	DENOTES "WEATHER PROOF".
	DENOTES "GENERAL, MECHANICAL, & ELECTRICAL CONTRACTORS".
	DENOTES LIGHTING FIXTURE ON NIGHT LIGHT CIRCUIT.
	DENOTES LIGHTING FIXTURE ON EMERGENCY POWER CIRCUIT.
	PLAN NOTE. REFER TO NOTATION ON PLANS.
	FIRE ALARM MANUAL PULL STATION.
	SMOKE DETECTOR.
	FIRE ALARM AUDIO/VISUAL ALARM DEVICE.
	DUPLEX RECEPTACLE 20A ORANGE COLOR-UPS POWER, MOUNTED 18" UP UNLESS NOTED OTHERWISE.
	OCCUPANCY SENSOR
	DAYLIGHT SENSOR

NOTE: ALL SYMBOLS MAY NOT APPEAR ON THE DRAWINGS.

**SCOPE OF WORK**

- PROVIDE LIGHTING AND POWER FOR NEW TENANT BASED ON NEW ARCHITECTURAL FLOOR AND CEILING PLANS.

**SHEET INDEX**


SHEET NO.	DESCRIPTION
E-0.0	GENERAL NOTES, SYMBOLS, SHEET INDEX, SINGLE LINE DIAGRAM
E-0.1	PANEL SCHEDULE
E-1.0	ELECTRICAL LIGHTING PLAN
E-1.1	LIGHTING CONTROL ZONES
E-1.2	DAYLIGHT ZONES AND LIGHTING CONTROL SCHEDULE
E-2.0	ELECTRICAL POWER PLAN
E-3.0	ROOF POWER PLAN
ET24-1	LIGHTING TITLE 24 COMPLIANCE REPORT
ET24-2	LIGHTING TITLE 24 COMPLIANCE REPORT
ET24-3	LIGHTING TITLE 24 COMPLIANCE REPORT
ET24-4	LIGHTING TITLE 24 COMPLIANCE REPORT
ET24-5	LIGHTING TITLE 24 COMPLIANCE REPORT

**GENERAL NOTES:**

- CONTRACTOR TO FIELD-VERIFY AND INFORM THE ENGINEER OF RECORD OF ANY DISCREPANCIES.
- ALL NEW PANELS ARE FULLY RATED. NO SERIES RATING ACCEPTED.

**KEY NOTES:**

- COORDINATE WITH SCE SERVICE PLANNER AND REMOVE THE EXISTING PANEL AND METER.
- COORDINATE WITH SCE SERVICE PLANNER AND UPSIZE THE EXISTING SERVICE TO 200A @ 120/208V, 3PH, 4W.



**VOLTAGE DROP TABLE**



FROM	TO	WIRE SIZE	LENGTH (FT)	LOAD (A)	REF. VOLTAGE	V.D. (V)	V.D. (%)
METER	PANEL A	4/0	90	127	208V-3PH	0.97	0.47
METER	PANEL B	1	50	27	208V-3PH	0.29	0.17
METER	PANEL C	4/0	47	137	208V-3PH	0.55	0.26
PANEL B	B-2	12	116	9	120V-1PH	3.29	2.74
PANEL A	A-11	12	130	5	120V-1PH	2.06	1.72
PANEL A	A-35	10	90	15	120V-1PH	2.70	2.25
PANEL A	A-17	10	85	13	120V-1PH	2.21	1.84

THE MAXIMUM COMBINED VOLTAGE DROP ON BOTH INSTALLED FEEDER CONDUCTORS AND BRANCH CIRCUIT CONDUCTORS TO THE FARTHEST CONNECTED LOAD OR OUTLET SHALL NOT EXCEED 5 PERCENT.

2016072  
RECEIVED  
MAY 28 2019  
City of Santa Ana

CSG CONSULTANTS  
THESE PLANS AND DETAILS ARE APPROVED  
THE APPROVAL OF THESE PLANS SHALL NOT BE CONSTRUED TO BE A PERMIT FOR ANY VIOLATION OF ANY CODE OR ORDINANCE  
JUN 03 2019  
BY: [Signature]

ISSUE	DATE
PC CMT	4/24/19



CONCENTRA  
3100 W, WARNER AVE, SUITE 100  
SANTA ANA, CA 92704

PROJECT NO. 18E 30046
DRAWN/REVIEWED DP/HK
DATE/ISSUE TBD
SHEET TITLE GENERAL NOTES, SYMBOLS, PANEL SCHEDULES
SHEET NO. E-0.0

2016 7692

**(N) PANEL A**

VOLTS: 120/208V PHASE: 3 A.I.C. RATING: 10,000 AMP MAIN: 200A  
 MOUNTING: RECESSED WIRE: 4 BUSSING: 225A

LOAD	A-VA	B-VA	C-VA	BKR	CT	CT BKR	A-VA	B-VA	C-VA	* LOAD
CHECK-IN / CHECK-OUT	R 1080			20/1	1	2	20/1	1080		R EXAM 102 AND 103
PROCEDURE 1	R	540		20/1	3	4	20/1		1080	R EXAM 104 AND 105
LAB	R		900	20/1	5	6	20/1		1080	R EXAM 114 AND 117
PT	R 540			20/1	7	8	20/1	1080		R EXAM 112 AND 113
PT	R	540		20/1	9	10	20/1		540	R BAT
PT	R		540	20/1	11	12	20/1		540	R AUDIO
PT	R 540			20/1	13	14	20/1	720		R OFFICE AND FILE ROOM
PT CHECK-IN	R	1080		20/1	15	16	20/1		540	R PROCEDURE 2
BREAK RM GARGABE DISPOSAL	R		1500	20/1	17	18	20/1		1200	R RECEPTION COPIER
BREAK RM GEN. REC.	R 540			20/1	19	20	20/1	720		R HALLWAY 129 AND 137
BREAK RM COFFEE MAKER	R	1200		20/1	21	22	20/1		360	R RESTROOM 131
BREAK RM MICROWAVE	R		1200	20/1	23	24	20/1		1440	R WORK AREA
BREAK RM FRIGE	R 540			15/1	25	26	20/1	1080		R PHYSICIAN'S STATION
WAITING AREA COFFEE MACHINE	R	1500		20/1	27	28	20/1		1800	C PHONE SYSTEM
RECEPTION - WAITING RM REC	R		1440	20/1	29	30	20/1		1800	R SERVER
PROCEDURE 1 FLOOR OUTLET	R 1800			20/1	31	32	20/1	540		R ROOFTOP RECEPTACLES
PROCEDURE 2 FLOOR OUTLET	R	1800		20/1	33	34	20/1		1500	R TV
PT FLOOR OUTLET	R		1800	20/1	35	36	20/1		540	R WAITING ROOM
WATER HEATER	N 3994			40/3	37	38	20/1	720		R X-RAY GEN. REC.
	N	3994			39	40	60/2		4368	N X-RAY
	N		3994		41	42				N X-RAY
PHASE TOTALS:	14974	20842	22342	58158	=TOTAL CONNECTED LOAD,VA (FOR DEMAND LOAD SEE BELOW)					
PHASE AMPERES:	41.6	57.9	62.0							

\*DEMAND LOAD CALCULATION:  
 L=LIGHTING LOADS: 1.25 X 0 = 0 VA  
 C=CONTINUOUS LOADS, OTHER: 1.25 X 1800 = 2250 VA  
 M=MOTOR LOADS (INCL LGST): 1.00 X 0 = 0 VA  
 LARGEST, VA: 0.25 X 0 = 0 VA  
 R=RECEPTACLES: 1ST 10K: 1.00 X 10000 = 10000 VA  
 BALANCE: 0.50 X 25640 = 12820 VA  
 K=KITCHEN LOADS: QTY: 0 1.00 X 0 = 0 VA  
 N=NONCONTINUOUS LOADS, OTHER: 1.00 X 20719 = 20719 VA  
 TOTAL N.E.C. DEMAND LOAD = 45789 VA = 127.1 AMPERES

**(N) PANEL B**

VOLTS: 120/208V PHASE: 3 A.I.C. RATING: 10,000 AMP MAIN: 100A  
 MOUNTING: RECESSED WIRE: 4 BUSSING: 125A

LOAD	A-VA	B-VA	C-VA	BKR	CT	CT BKR	A-VA	B-VA	C-VA	* LOAD
EXAM AND PROCEDURE ROOMS	L 854			20/1	1	2	20/1	915		L PT AREA
OFFICE AREAS	L	976		20/1	3	4	20/1		732	L CHECK-IN AND WAITING AREA
HALLWAYS	L		671	20/1	5	6	15/1		568	L RESTROOMS
HALLWAYS	L 671			20/1	7	8	15/1	24		L EMERGENCY LIGHT
				20/1	9	10	20/1			
				20/1	11	12	20/1			
				20/1	13	14	20/1			
				20/1	15	16	20/1			
				17	18					
				19	20	60/3	1173			N (N) PANEL B1
				21	22					N
				23	24					N
PHASE TOTALS:	3637	2881	2412	8930	=TOTAL CONNECTED LOAD,VA (FOR DEMAND LOAD SEE BELOW)					
PHASE AMPERES:	10.1	8.0	6.7							

\*DEMAND LOAD CALCULATION:  
 L=LIGHTING LOADS: 1.25 X 5411 = 6764 VA  
 C=CONTINUOUS LOADS, OTHER: 1.25 X 0 = 0 VA  
 M=MOTOR LOADS (INCL LGST): 1.00 X 0 = 0 VA  
 LARGEST, VA: 0.25 X 0 = 0 VA  
 R=RECEPTACLES: 1ST 10K: 1.00 X 0 = 0 VA  
 BALANCE: 0.50 X 0 = 0 VA  
 K=KITCHEN LOADS: QTY: 0 1.00 X 0 = 0 VA  
 N=NONCONTINUOUS LOADS, OTHER: 1.00 X 3520 = 3520 VA  
 TOTAL N.E.C. DEMAND LOAD = 10284 VA = 28.5 AMPERES

**(N) PANEL C**

VOLTS: 120/208V PHASE: 3 A.I.C. RATING: 10,000 AMP MAIN: 200A  
 MOUNTING: RECESSED WIRE: 4 BUSSING: 225A

LOAD	A-VA	B-VA	C-VA	BKR	CT	CT BKR	A-VA	B-VA	C-VA	* LOAD
HP 1	M 3038			30/3	1	2	15/2	1456		M FC1
	M	3038			3	4		1456		M
	M		3038		5	6	15/2		1456	M FC2
HP 2	M 1741			25/3	7	8		1456		M
	M	1741			9	10	15/3		1681	M FC3
	M		1741		11	12			1681	M
HP 3	M 4803			60/3	13	14		1681		M
	M	4803			15	16	15/1		168	M EF1-2-3
	M		4803		17	18	15/1		112	M EF 4-5
RTU 1	M 4659			60/2	19	20				M
	M	4659			21	22				M
					23	24				M
					25	26				M
					27	28				M
					29	30				M
					31	32				M
					33	34				M
					35	36				M
					37	38				M
					39	40				M
					41	42				M
PHASE TOTALS:	18835	17547	12832	49214	=TOTAL CONNECTED LOAD,VA (FOR DEMAND LOAD SEE BELOW)					
PHASE AMPERES:	52.3	48.7	35.6							

\*DEMAND LOAD CALCULATION:  
 L=LIGHTING LOADS: 1.25 X 0 = 0 VA  
 C=CONTINUOUS LOADS, OTHER: 1.25 X 0 = 0 VA  
 M=MOTOR LOADS (INCL LGST): 1.00 X 49214 = 49214 VA  
 LARGEST, VA: 0.25 X 0 = 0 VA  
 R=RECEPTACLES: 1ST 10K: 1.00 X 0 = 0 VA  
 BALANCE: 0.50 X 0 = 0 VA  
 K=KITCHEN LOADS: QTY: 0 1.00 X 0 = 0 VA  
 N=NONCONTINUOUS LOADS, OTHER: 1.00 X 0 = 0 VA  
 TOTAL N.E.C. DEMAND LOAD = 49214 VA = 136.6 AMPERES

**(N) PANEL B1**



VOLTS: 120/208V PHASE: 3 A.I.C. RATING: 10,000 AMP MAIN: 60A  
 MOUNTING: RECESSED WIRE: 4 BUSSING: 60A

LOAD	A-VA	B-VA	C-VA	BKR	CT	CT BKR	A-VA	B-VA	C-VA	* LOAD
PT CHECK IN	R 1500			20/1	1	2	20/1	540		R STORAGE ROOM
HALLWAY	R	940		20/1	3	4				R
RESTROOM HALLWAY	R		540	20/1	5	6				R
				20/1	7	8				R
					9	10				R
					11	12				R
					13	14				R
					15	16				R
					17	18				R
					19	20				R
					21	22				R
					23	24				R
					25	26				R
					27	28				R
					29	30				R
PHASE TOTALS:	2040	940	540	3520	=TOTAL CONNECTED LOAD,VA (FOR DEMAND LOAD SEE BELOW)					
PHASE AMPERES:	5.7	2.6	1.5							

\*DEMAND LOAD CALCULATION:  
 L=LIGHTING LOADS: 1.25 X 0 = 0 VA  
 C=CONTINUOUS LOADS, OTHER: 1.25 X 0 = 0 VA  
 M=MOTOR LOADS (INCL LGST): 1.00 X 0 = 0 VA  
 LARGEST, VA: 0.25 X 0 = 0 VA  
 R=RECEPTACLES: 1ST 10K: 1.00 X 3520 = 3520 VA  
 BALANCE: 0.50 X 0 = 0 VA  
 K=KITCHEN LOADS: QTY: 0 1.00 X 0 = 0 VA  
 N=NONCONTINUOUS LOADS, OTHER: 1.00 X 0 = 0 VA  
 TOTAL N.E.C. DEMAND LOAD = 3520 VA = 9.8 AMPERES

**PANEL SCHEDULE**

GENERAL NOTES:  
 1- ALL NEW PANELS ARE FULLY RATED. NO SERIES RATING ACCEPTED.




CONCENTRA  
 3100 W, WARNER AVE, SUITE 100  
 SANTA ANA, CA 92704

CSG CONSULTANTS  
 THESE PLANS AND DETAILS ARE APPROVED  
 THE APPROVAL OF THESE PLANS SHALL NOT BE CONSTRUED TO BE A PERMIT FOR ANY VIOLATION OF ANY CODE OR ORDINANCE  
 JUN 03 2019

BY: *[Signature]*  
 THESE PLANS SHALL BE ON THE JOB FOR ALL REQUESTED INSPECTIONS.

PROJECT NO. 18E 30046
DRAWN/REVIEWED DP/HK
DATE/ISSUE TBD
SHEET TITLE PANEL SCHEDULES
SHEET NO. E-0.1





**ELECTRICAL LIGHTING PLAN** N  
 SCALE: 3/16"=1'-0"

**GENERAL NOTES:**

- 1- PROVIDE SWITCH AND RECEPTACLE MOUNTING HEIGHTS PER STATE OF CALIFORNIA ACCESSIBLE REQUIREMENTS.
- 2- EMERGENCY LIGHT FIXTURES AND EXIT SIGNS SHALL BE EQUIPPED WITH BACKUP BATTERY TO PROVIDE POWER FOR AT LEAST 90 MIN.
- 3- EMERGENCY LIGHT FIXTURES AND EXIT SIGNS SHALL BE INSTALLED AHEAD OF ANY SWITCHING DEVICE AND BE FED DIRECTLY FROM PROVIDED BRANCH CIRCUIT.
- 4- CONTRACTOR SHALL FOLLOW ARCHITECTURE DRAWINGS FOR THE SPECIFIC TYPE OF EXIT SIGN.
- 5- ALL 20A 120V BRANCH CIRCUITS SHALL BE 2#12, 1#12GND, 3/4"C.
- 6- CONTRACTOR TO COORDINATE WITH THE OWNER/ARCHITECTS FOR THE EXACT FINISH, COLOR TEMPERATURE, AND EXACT MODEL OF THE LIGHT FIXTURES.
- 7- CONTRACTOR TO VERIFY UL LISTING OF ALL FIXTURES PRIOR ORDERING.
- 8- ALL EXISTING LOADS THAT WILL REMAIN OTHER THAN SHOWN IN THIS SET OF DRAWINGS SHALL BE FED FROM NEW PANELS. CONTRACTOR TO GET CLARIFICATION PRIOR TO ANY CONSTRUCTION WORK.

**KEY NOTES:**



- ① PROVIDE NEW WALL MOUNTED ON/OFF DIMMER SWITCH AND CEILING MOUNT OCCUPANCY/PHOTOCELL COMBINED SENSOR. USE POWER PACK nPP16 OR SIMILAR.
- ② PROVIDE WALL MOUNTED DIMMER. ON/OFF OPERATION WILL BE OVERRIDDEN BY CEILING MOUNT OCCUPANCY SENSOR SERVING AS PARTIAL-ON OCCUPANCY SENSOR. USE NLIGHT nPODM-DX OR SIMILAR.
- ③ PROVIDE NEW WALL MOUNTED DIMMER SWITCH WITH INTEGRATED OCCUPANCY AND PHOTOCELL SENSOR PER C.E.C. 2016 REQUIREMENTS. USE NLIGHT nWSX-PDT-LV-DX OR SIMILAR.
- ④ PROVIDE 24"R COVERAGE CEILING MOUNTED OCCUPANCY SENSOR. USE NLIGHT nCM-PDT-10 OR SIMILAR.
- ⑤ PROVIDE 12"R COVERAGE CEILING MOUNTED OCCUPANCY SENSOR. USE NLIGHT nCM-PDT-9 OR SIMILAR.
- ⑥ PROVIDE 24"R COVERAGE CEILING MOUNTED OCCUPANCY AND PHOTOCELL COMBINED SENSOR. USE NLIGHT nCM-PDT-10 (PHOTOCELL ENABLED) OR SIMILAR.
- ⑦ PROVIDE 12"R COVERAGE CEILING MOUNTED OCCUPANCY AND PHOTOCELL COMBINED SENSOR. USE NLIGHT nCM-PDT-9 (PHOTOCELL ENABLED) OR SIMILAR.
- ⑧ PROVIDE WALL MOUNTED DIMMER. ON/OFF OPERATION WILL BE OVERRIDDEN BY CEILING MOUNT OCCUPANCY SENSOR. USE NLIGHT nPODM-DX OR SIMILAR.
- ⑨ PROVIDE 70FEET COVERAGE CEILING MOUNTED HALLWAY OCCUPANCY SENSOR TO SERVE AS PARTIAL-ON OCCUPANCY SENSOR. USE NLIGHT nHW-13 OR SIMILAR.
- ⑩ BOTH SENSORS IN ZONE 10 SHALL BE PROGRAMMED TO WORK TOGETHER.
- ⑪ BOTH SENSORS IN ZONES 9 AND 34 SHALL BE PROGRAMMED TO WORK TOGETHER.
- ⑫ CONDUCTOR SHALL BE 3/4"C, 2#8, 1#10 GND. TO COMPENSATE THE COLTAGE DROP.

**CSG CONSULTANTS**  
 THESE PLANS AND DETAILS ARE  
**APPROVED**  
 THE APPROVAL OF THESE PLANS SHALL NOT  
 BE CONSTRUED TO BE A PERMIT FOR ANY  
 VIOLATION OF ANY CODE OR ORDINANCE.

JUN 03 2019

BY: *[Signature]*  
 THESE PLANS SHALL BE ON THE JOB  
 FOR ALL REQUESTED INSPECTIONS.

LIGHT FIXTURE SCHEDULE										
SYM.	MK.	MANUF.	MODEL NUMBER	DESCRIPTION	MOUNTING	LAMPS	FIX. WATT	FIXTURE QTY.	TOTAL WATTS	VOLT
□	A	LITHONIA	2AVL4-50L-MDR-EZ1-LP840	2'X4' LED LIGHT FIXTURE "AVANTE" SERIES "E" INDICATES EMERGENCY LIGHT WITH 90 MIN BATT.	RECESSED	LED	61W	80	4880W	120
⊕	B	LITHONIA	65BEMW/65SEMW-HL LED-40K	LITHONIA 6" DOWNLIGHT	RECESSED	LED	12W	8	96W	120
⊗	E	LSI	EXL-U-R-1C-ZC/ FC-WB-WH-SD2	EXIT SIGN WITH 90 MINUTES EMERGENCY BATTERY BACK-UP	SURFACE	LED	2W	12	24W	120



CONCENTRA  
 3100 W. WARNER AVE, SUITE 100  
 SANTA ANA, CA 92704

PROJECT NO.  
18E 30046

DRAWN/REVIEWED  
DP/HK

DATE/ISSUE  
TBD

SHEET TITLE  
ELECTRICAL  
LIGHTING PLAN

SHEET NO.  
E-1.0





**ELECTRICAL LIGHTING ZONES**  
SCALE: 3/16"=1'-0"


**CSG CONSULTANTS**  
THESE PLANS AND DETAILS ARE  
**APPROVED**  
THE APPROVAL OF THESE PLANS SHALL NOT  
BE CONSTRUED TO BE A PERMIT FOR ANY  
VIOLATION OF ANY CODE OR ORDINANCE

JUN 03 2019

BY: *[Signature]*  
THESE PLANS SHALL BE ON THE JOB  
FOR ALL REQUESTED INSPECTIONS.

ISSUE DATE

1 PC CMT 4/24/19



CONCENTRA  
3100 W. WARNER AVE, SUITE 100  
SANTA ANA, CA 92704

PROJECT NO.  
18E 30046


DRAWN/REVIEWED  
DP/HK

DATE/ISSUE  
TBD

SHEET TITLE  
ELECTRICAL  
LIGHTING ZONES

SHEET NO.  
E-1.1







**ELECTRICAL DAYLIGHT ZONES**  
 SCALE: 3/16"=1'-0"

**CSG CONSULTANTS**  
 THESE PLANS AND DETAILS ARE  
**APPROVED**  
 THE APPROVAL OF THESE PLANS SHALL NOT  
 BE CONSTRUED TO BE A PERMIT FOR ANY  
 VIOLATION OF ANY CODE OR ORDINANCE

JUN 03 2019

BY: *[Signature]*  
 THESE PLANS SHALL BE ON THE JOB  
 FOR ALL REQUESTED INSPECTIONS.



CONTROL ZONE	Multi-Level Lighting Control		DAYLIGHT HARVESTING CONTROL		AUTO SHUT-OFF CONTROL		CONTROLLED RECEPTACLE
	APPLICABLE	CONTROL TYPE	APPLICABLE	CONTROL TYPE	APPLICABLE	CONTROL TYPE	
Zone 1	Yes	Continuous Dimming	Yes	Ceiling Mount Photocell Sensor	Yes	- Ceiling mount Occupancy Sensor - Time Clock with override	No
Zone 2	Yes	Continuous Dimming	Yes	Ceiling Mount Photocell Sensor	Yes	- Ceiling mount Occupancy Sensor - Time Clock with override	No
Zone 3	Yes	Continuous Dimming	Yes	Ceiling Mount Photocell Sensor	Yes	- Ceiling mount Occupancy Sensor - Time Clock with override	No
Zone 4	Yes	Continuous Dimming	Yes	Ceiling Mount Photocell Sensor	Yes	- Ceiling mount Occupancy Sensor - Time Clock with override	No
Zone 5	Yes	Continuous Dimming	No	Ceiling Mount Photocell Sensor	Yes	- Ceiling mount Occupancy Sensor - Time Clock with override	No
Zone 6	Yes	Continuous Dimming	No	Ceiling Mount Photocell Sensor	Yes	- Ceiling mount Occupancy Sensor - Time Clock with override	No
Zone 7	Yes	Continuous Dimming	Yes	Ceiling Mount Photocell Sensor	Yes	- Ceiling mount Occupancy Sensor - Time Clock with override	No
Zone 8	Yes	Continuous Dimming	Yes	Ceiling Mount Photocell Sensor	Yes	- Ceiling mount Occupancy Sensor - Time Clock with override	No
Zone 9	Yes	Continuous Dimming	No	-	Yes	- Ceiling mount Occupancy Sensor - Time Clock with override	No
Zone 10	Yes	Continuous Dimming	Yes	-	Yes	- Ceiling mount Occupancy Sensor - Time Clock with override	No
Zone 11	Yes	Continuous Dimming	No	-	Yes	- Ceiling mount Occupancy Sensor - Time Clock with override	No
Zone 12	Yes	Continuous Dimming	No	-	Yes	- Wall mount Occupancy Sensor - Time Clock with override	No
Zone 13	Yes	Continuous Dimming	No	-	Yes	- Wall mount Occupancy Sensor - Time Clock with override	No
Zone 14	Yes	Continuous Dimming	No	-	Yes	- Wall mount Occupancy Sensor - Time Clock with override	No

Zone 15	Yes	Continuous Dimming	No	Ceiling Mount Photocell Sensor	Yes	- Ceiling mount Occupancy Sensor - Time Clock with override	No
Zone 16	Yes	Continuous Dimming	No	Ceiling Mount Photocell Sensor	Yes	- Ceiling mount Occupancy Sensor - Time Clock with override	No
Zone 17	Yes	Continuous Dimming	No	Ceiling Mount Photocell Sensor	Yes	- Ceiling mount Occupancy Sensor - Time Clock with override	No
Zone 18	Yes	Continuous Dimming	No	Ceiling Mount Photocell Sensor	Yes	- Ceiling mount Occupancy Sensor - Time Clock with override	No
Zone 19	Yes	Continuous Dimming	No	Ceiling Mount Photocell Sensor	Yes	- Ceiling mount Occupancy Sensor - Time Clock with override	No
Zone 20	Yes	Continuous Dimming	No	Ceiling Mount Photocell Sensor	Yes	- Ceiling mount Occupancy Sensor - Time Clock with override	No
Zone 21	Yes	Continuous Dimming	No	Ceiling Mount Photocell Sensor	Yes	- Ceiling mount Occupancy Sensor - Time Clock with override	No
Zone 22	Yes	Continuous Dimming	No	Ceiling Mount Photocell Sensor	Yes	- Ceiling mount Occupancy Sensor - Time Clock with override	No
Zone 23	Yes	Continuous Dimming	Yes	-	Yes	- Ceiling mount Occupancy Sensor - Time Clock with override	No
Zone 24	Yes	Continuous Dimming	Yes	-	Yes	- Ceiling mount Occupancy Sensor - Time Clock with override	No
Zone 25	Yes	Continuous Dimming	No	-	Yes	- Ceiling mount Occupancy Sensor - Time Clock with override	No
Zone 26	Yes	Continuous Dimming	No	-	Yes	- Wall mount Occupancy Sensor - Time Clock with override	No
Zone 27	Yes	Continuous Dimming	Yes	-	Yes	- Wall mount Occupancy Sensor - Time Clock with override	No
Zone 28	Yes	Continuous Dimming	No	-	Yes	- Wall mount Occupancy Sensor - Time Clock with override	No
Zone 29	Yes	Continuous Dimming	Yes	-	Yes	- Ceiling mount Occupancy Sensor - Time Clock with override	No
Zone 30	Yes	Continuous Dimming	Yes	-	Yes	- Ceiling mount Occupancy Sensor - Time Clock with override	No
Zone 31	Yes	Continuous Dimming	Yes	-	Yes	- Ceiling mount Occupancy Sensor - Time Clock with override	No
Zone 32	Yes	Continuous Dimming	Yes	-	Yes	- Wall mount Occupancy Sensor - Time Clock with override	No
Zone 33	Yes	Continuous Dimming	Yes	-	Yes	- Wall mount Occupancy Sensor - Time Clock with override	No
Zone 34	Yes	Continuous Dimming	Yes	-	Yes	- Wall mount Occupancy Sensor - Time Clock with override	No

CONCENTRA  
 3100 W, WARNER AVE, SUITE 100  
 SANTA ANA, CA 92704

PROJECT NO.  
18E 30046


DRAWN/REVIEWED  
DP/HK

DATE/ISSUE  
TBD

SHEET TITLE  
ELECTRICAL  
DAYLIGHT ZONES

SHEET NO.  
E-1.2





**GENERAL NOTES:**

- 1- PROVIDE SWITCH AND RECEPTACLE MOUNTING HEIGHTS PER STATE OF CALIFORNIA ACCESSIBLE REQUIREMENTS.
- 2- GENERAL CONTRACTOR (G.C.) SHALL NOTIFY ENGINEER OF RECORD OF ANY DISCREPANCIES BETWEEN ELECTRICAL AND ARCHITECTURAL DRAWINGS AND OBTAIN CLARIFICATION BEFORE COMMENCING WORK.
- 3- REFER TO ARCHITECTURAL DRAWINGS FOR THE EXACT LOCATION AND MOUNTING HEIGHT OF POWER OUTLETS, FURNITURE AND EQUIPMENT.
- 4- ALL RECEPTACLES SHALL BE INSTALLED AT 18" ABOVE FINISHED FLOOR UNLESS OTHERWISE NOTED.
- 5- ALL THE WIRING ABOVE THE DROPPED CEILING AND IN THE RATED RETURN AIR PLENUM SHALL BE FIRE RATED.
- 6- ALL 20A 120V BRANCH CIRCUITS SHALL BE 2#12, 1#12GND, 3/4"C. ALL 30A 120V BRANCH CIRCUITS SHALL BE 2#10, 1#10GND, 3/4"C. BRANCH CIRCUITS A-17,27,33,34,35 SHALL BE 2#10, 1#10GND, 3/4"C.

**ELECTRICAL POWER PLAN**  
SCALE: 1/4"=1'-0"

**KEY NOTES:**



- 1 PROVIDE FIRE TREATED BACKBOARD WITH HOME RUN TO BASE BUILDING TELEPHONE ROOM PAINTED TO MATCH WALL. VERIFY CONDUIT SIZE. 4'X8'X 3/4" PLYWOOD BACKBOARD MOUNTED FROM THE CEILING DOWN AND (2) 4" EMT CONDUIT SLEEVES WITH INSULATED BUSHINGS MOUNTED WITH UNISTRUT COMING THROUGH THE CEILING ABOVE THE BOARD, ONE FOOT ABOVE THE CEILING AND ONE FOOT BELOW. A #12 GROUNDING WIRE RUN TO THE SERVER RACK SHALL BE PROVIDED.

- 2 PROVIDE POWER FOR TENANT RICOH MP6001 COPIER/SCANNER. COORDINATE WITH TENANT FOR ANY OTHER REQUIREMENTS.
- 3 PROVIDE PROGRAMMABLE ASTRONOMICAL TIME CLOCK TO CONTROL ALL LIGHT FIXTURES. PROVIDE OVERRIDE (NO MORE THAN 120 MINUTES) FOR AFTER HOURS WORKING.
- 4 PROVIDE FLOOR-MOUNT MEDICAL RATED AFCI OUTLET. COORDINATE WITH TENANT AND TENANT VENDOR FOR THE EXACT LOCATION.
- 5 (E) METER#060642 AND 200A BREAKER
- 6 (E) METER#060643 AND 100A BREAKER
- 7 (E) METER#082081 AND 100A BREAKER

- 8 (E) METER#082080 AND 100A BREAKER
- 9 PROVIDE J-BOX FOR EXHAUST FAN. REFER TO MECHANICAL DRAWINGS FOR THE EXACT LOCATION AND DETAILS.
- 10 PROVIDE MANUAL DISCONNECT FOR CEILING FAN COIL. REFER TO MECHANICAL DRAWINGS FOR THE EXACT LOCATION.
- 11 COORDINATE WITH MANUFACTURER AND PROVIDE POWER FOR IN-DUCT SMOKE DETECTOR. REFER TO MECHANICAL DRAWINGS FOR THE EXACT LOCATION.
- 12 RE-CIRCUIT THE EXISTING X-RAY POWER PER PANEL SCHEDULE ON SHEET E-0.1.

**CSG CONSULTANTS**  
THESE PLANS AND DETAILS ARE **APPROVED**  
THE APPROVAL OF THESE PLANS SHALL NOT BE CONSTRUED TO BE A PERMIT FOR ANY VIOLATION OF ANY CODE OR ORDINANCE  
JUN 03 2019  
BY: *J. K. ...*  
THESE PLANS SHALL BE ON THE JOB FOR ALL REQUESTED INSPECTIONS.


ISSUE	DATE
1 PC CMT	4/24/19



CONCENTRA  
3100 W, WARNER AVE, SUITE 100  
SANTA ANA, CA 92704

PROJECT NO.	18E 30046
DRAWN/REVIEWED	DP/HK
DATE/ISSUE	TBD
SHEET TITLE	ELECTRICAL POWER PLAN
SHEET NO.	E-2.0





CONCENTRA  
 3100 W. WARNER AVE., SUITE 100  
 SANTA ANA, CA 92704


PROJECT NO.  
18E 30046

DRAWN/REVIEWED  
DP/HK

DATE/ISSUE  
TBD

SHEET TITLE  
ROOF  
POWER PLAN

SHEET NO.  
E-3.0



**ELECTRICAL ROOFTOP PLAN**   
 SCALE: 1/4" = 1'-0"

**KEY NOTES:**

- ① CONTRACTOR TO FIELD VERIFY AND RECONNECT THE EXISTING MECHANICAL UNIT TO NEW CIRCUIT ON PANEL C IF REQUIRED.

**GENERAL NOTES:**

1. CONTRACTOR SHALL PROVIDE RECEPTACLES WITHIN 25 FEET OF MECHANICAL EQUIPMENT. RECEPTACLES SHALL HAVE AN ENCLOSURE THAT IS WEATHERPROOF (WP) AND IS LISTED/IDENTIFIED AS "EXTRA DUTY." THE RECEPTACLES SHALL BE LISTED AS THE WEATHER RESISTANT (WR) TYPE AND SHALL BE GFI PROTECTED.
2. ALL ELECTRICAL EQUIPMENT ON ROOFTOP SHALL BE WP/ NEMA 3R TYPE.

**CSC CONSULTANTS**  
 THESE PLANS AND DETAILS ARE  
**APPROVED**  
 THE APPROVAL OF THESE PLANS SHALL NOT  
 BE CONSTRUED TO BE A PERMIT FOR ANY  
 VIOLATION OF ANY CODE OR ORDINANCE

JUN 03 2019

BY:   
 THESE PLANS SHALL BE ON THE JOB  
 FOR ALL REQUESTED INSPECTIONS.



STATE OF CALIFORNIA  
**INDOOR LIGHTING**  
 CEC-NRCC-LTI-01-E (Revised 04/18)

CALIFORNIA ENERGY COMMISSION

CERTIFICATE OF COMPLIANCE NRCC-LTI-01-E  
 Indoor Lighting (Page 1 of 6)  
 Project Name: Concentra Date Prepared: 4/19/2019

**A. General Information**  
 Climate Zone: 8 Conditioned Floor Area: 6,222  
 Unconditioned Floor Area: 0

Building Type:  Nonresidential  High-Rise Residential  Hotel/Motel  
 Schools  Relocatable Public Schools  Conditioned Spaces  Unconditioned Spaces

Phase of Construction:  New Construction  Alteration  
 Addition  Tailored

Method of Compliance:  Complete Building  Area Category  Tailored

Project Address: 3100 W. Warner Ave., Suite 100

**B. Lighting Compliance Documents** (select yes for each document included)  
 For detailed instructions on the use of this and all Energy Efficiency Standards compliance documents, refer to the Nonresidential Manual published by the California Energy Commission.

YES	NO	COMP. DOC.	TITLE
<input checked="" type="checkbox"/>	<input type="checkbox"/>	NRCC-LTI-01-E	Certificate of Compliance. All Pages required on plans for all submittals.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	NRCC-LTI-02-E	Lighting Controls, Certificate of Compliance, and PAF Calculation. All Pages required on plans for all submittals.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	NRCC-LTI-03-E	Indoor Lighting Power Allowance
<input checked="" type="checkbox"/>	<input type="checkbox"/>	NRCC-LTI-04-E	Tailored Method Worksheets
<input type="checkbox"/>	<input checked="" type="checkbox"/>	NRCC-LTI-05-E	Line Voltage Track Lighting Worksheets
<input type="checkbox"/>	<input type="checkbox"/>	NRCC-LTI-06-E	Indoor Lighting Existing Conditions

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance April 2016

STATE OF CALIFORNIA  
**INDOOR LIGHTING**  
 CEC-NRCC-LTI-01-E (Revised 04/18)

CALIFORNIA ENERGY COMMISSION

CERTIFICATE OF COMPLIANCE NRCC-LTI-01-E  
 Indoor Lighting (Page 2 of 6)  
 Project Name: Concentra Date Prepared: 4/19/2019

**C. Summary of Allowed Lighting Power**  
 Conditioned and Unconditioned space Lighting must be combined for compliance

Indoor Lighting Power for Conditioned Spaces			Indoor Lighting Power for Unconditioned Spaces		
Item	Watts	Watts	Item	Watts	Watts
D1	Installed Lighting NRCC-LTI-01-E, Table H, page 5 + 4,807		Installed Lighting NRCC-LTI-01-E, Table H, page 5 + 0		
D2	Portable Only for Offices NRCC-LTI-01-E, Table G, page 4 +				
D3	Minus Lighting Control Credits NRCC-LTI-02-E, page 2 - 0		Minus Lighting Control Credits NRCC-LTI-02-E, page 2 - 0		
D4	Adjusted Installed Lighting Power (row 1 plus row 2 minus row 3) = 4,807		Adjusted Installed Lighting Power (row 1 minus row 3) = 0		
Complies ONLY if Installed < Allowed (Box 04 < Box 05)			Complies ONLY if Installed < Allowed (Box 04 < Box 05)		
Allowed Lighting Power Conditioned NRCC-LTI-03-E, page 1 6,148			Allowed Lighting Power Unconditioned NRCC-LTI-03-E, page 1 0		
Alterations with replacement luminaires that have at least 50/35% lower power compared to the original existing luminaires, may instead use the allowed wattage from NRCC-LTI-05, page 2			Alterations with replacement luminaires that have at least 50/35% lower power compared to the original existing luminaires, may instead use the allowed wattage from NRCC-LTI-05, page 2		

**D. Declaration of Required Certificates of Installation**  
 Declare by selecting yes for all of the Certificates that will be submitted. (Retain copies and verify forms are completed and signed.)

YES	NO	Compliance Document/Title	Field Inspector
<input checked="" type="checkbox"/>	<input type="checkbox"/>	NRCC-LTI-01-E - Must be submitted for all buildings	<input type="checkbox"/> Field Inspector
<input type="checkbox"/>	<input checked="" type="checkbox"/>	NRCC-LTI-02-E - Must be submitted for a lighting control system, or for an Energy Management Control System (EMCS), to be recognized for compliance.	<input type="checkbox"/> Field Inspector
<input type="checkbox"/>	<input checked="" type="checkbox"/>	NRCC-LTI-03-E - Must be submitted for a line-voltage track lighting integral current limiter, or for a supplementary overcurrent protection panel used to energize only line-voltage track lighting, to be recognized for compliance.	<input type="checkbox"/> Field Inspector
<input type="checkbox"/>	<input checked="" type="checkbox"/>	NRCC-LTI-04-E - Must be submitted for two interlocked systems serving an auditorium, a convention center, a conference room, a multipurpose room, or a theater to be recognized for compliance.	<input type="checkbox"/> Field Inspector
<input type="checkbox"/>	<input checked="" type="checkbox"/>	NRCC-LTI-05-E - Must be submitted for a Power Adjustment Factor (PAF) to be recognized for compliance.	<input type="checkbox"/> Field Inspector
<input type="checkbox"/>	<input checked="" type="checkbox"/>	NRCC-LTI-06-E - Must be submitted for additional wattage installed in a video conferencing studio to be recognized for compliance.	<input type="checkbox"/> Field Inspector

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance April 2016

STATE OF CALIFORNIA  
**INDOOR LIGHTING**  
 CEC-NRCC-LTI-01-E (Revised 04/18)

CALIFORNIA ENERGY COMMISSION

CERTIFICATE OF COMPLIANCE NRCC-LTI-01-E  
 Indoor Lighting (Page 3 of 6)  
 Project Name: Concentra Date Prepared: 4/19/2019

**E. Declaration of Required Certificates of Acceptance**  
 Declare by selecting yes for all of the Certificates that will be submitted. (Retain copies and verify forms are completed and signed.)

YES	NO	Compliance Document/Title	Field Inspector
<input checked="" type="checkbox"/>	<input type="checkbox"/>	NRCA-LTI-02-A - Must be submitted for occupancy sensors and automatic time switch controls.	<input type="checkbox"/> Field Inspector
<input checked="" type="checkbox"/>	<input type="checkbox"/>	NRCA-LTI-03-A - Must be submitted for automatic daylight controls.	<input type="checkbox"/> Field Inspector
<input type="checkbox"/>	<input checked="" type="checkbox"/>	NRCA-LTI-04-A - Must be submitted for demand responsive lighting controls.	<input type="checkbox"/> Field Inspector
<input type="checkbox"/>	<input checked="" type="checkbox"/>	NRCA-LTI-05-A - Must be submitted for institutional tuning power adjustment factor (PAF).	<input type="checkbox"/> Field Inspector

A Separate Lighting Schedule Must Be Filled Out for Conditioned and Unconditioned Spaces. Installed Lighting Power listed on this Lighting Schedule is only for:  
 CONDITIONED SPACE  UNCONDITIONED SPACE

**F. Indoor Lighting Schedule and Field Inspection Energy Checklist**  
 The actual indoor lighting power listed on the next 2 pages includes all installed permanent and planned portable lighting systems.  
 When Complete Building Method is used for compliance, list each different type of luminaire on separate lines.  
 When Area Category Method or Tailored Method is used for compliance, list each different type of luminaire by each different function area on separate lines.  
 Also include track lighting in schedule, and submit the track lighting compliance document (NRCC-LTI-05-E) when line-voltage track lighting is installed.

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance April 2016

STATE OF CALIFORNIA  
**INDOOR LIGHTING**  
 CEC-NRCC-LTI-01-E (Revised 04/18)

CALIFORNIA ENERGY COMMISSION

CERTIFICATE OF COMPLIANCE NRCC-LTI-01-E  
 Indoor Lighting (Page 4 of 6)  
 Project Name: Concentra Date Prepared: 4/19/2019

**G. Installed Portable Luminaires in Offices - Exception to Section 240.8(a)**  
 This section shall be filled out ONLY for portable luminaires in offices (As defined in §100.1). All other planned portable luminaires shall be documented on next page of this compliance document.  
 This section is used to determine if greater than 0.3 watts of portable lighting is planned for any office.  
 Fill out a separate line for each different office. Small offices that are typical (having the same general and portable lighting) may be grouped together. This allowance shall not be traded between offices having different lighting systems.

Office Portable Luminaire Schedule							Office Location		Field Inspector	
1	2	3	4	5	6	7	8	9	10	11
Complete Luminaire Description (i.e., LED, under cabinet, furniture mounted direct/indirect)	Watts per luminaire	Number of luminaires	Installed portable luminaire watts in this office (602 x 602)	Square foot of office (604 / 602)	Watts per square foot (604 / 602)	If 602 < 0.3, enter zero; If 602 > 0.3, (604-0.3)	(602 x 602)	Identify Office area in which these portable luminaires are installed	Pass	Fail
									<input type="checkbox"/>	<input type="checkbox"/>
									<input type="checkbox"/>	<input type="checkbox"/>
									<input type="checkbox"/>	<input type="checkbox"/>
									<input type="checkbox"/>	<input type="checkbox"/>
									<input type="checkbox"/>	<input type="checkbox"/>
Total installed portable luminaire watts that are greater than 0.3 W/ft <sup>2</sup> per office:							Enter sum total of all pages into NRCC-LTI-01-E; Page 1			

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance April 2016

STATE OF CALIFORNIA  
**INDOOR LIGHTING**  
 CEC-NRCC-LTI-01-E (Revised 04/18)

CALIFORNIA ENERGY COMMISSION

CERTIFICATE OF COMPLIANCE NRCC-LTI-01-E  
 Indoor Lighting (Page 5 of 6)  
 Project Name: Concentra Date Prepared: 4/19/2019

A Separate Lighting Schedule Must Be Filled Out for Conditioned and Unconditioned Spaces. Installed Lighting Power listed on this Lighting Schedule is only for:  
 CONDITIONED SPACE  UNCONDITIONED SPACE

**H. Indoor Lighting Schedule and Field Inspection Energy Checklist**

Luminaire Schedule	Name or Item Tag	Complete Luminaire Description (i.e., 8 lamp fluorescent troffer, FS278, one dimmable electronic ballast)	Installed Watts					Location	Field Inspector	
			Watts per luminaire	How wattage was determined		Number of luminaires	Total installed Watts in this area (Foot x foot)		Pass	Fail
01	02	03	04	05	06	07	08	09	10	
			CCC Dimmer from field	Approved by (signature)						
A	Lithonia 2' x 4' LED Fixture	61.0	<input checked="" type="checkbox"/>	<input type="checkbox"/>	18	1,098	Corridor/Restroom/Support	<input type="checkbox"/>	<input type="checkbox"/>	
A	Lithonia 2' x 4' LED Fixture	61.0	<input checked="" type="checkbox"/>	<input type="checkbox"/>	10	610	Comp Bldg Office	<input type="checkbox"/>	<input type="checkbox"/>	
A	Lithonia 2' x 4' LED Fixture	61.0	<input checked="" type="checkbox"/>	<input type="checkbox"/>	9	549	Lounge, Recreation	<input type="checkbox"/>	<input type="checkbox"/>	
A	Lithonia 2' x 4' LED Fixture	61.0	<input checked="" type="checkbox"/>	<input type="checkbox"/>	39	2,379	Comp Bldg Hospital/Healthcare	<input type="checkbox"/>	<input type="checkbox"/>	
A	Lithonia 2' x 4' LED Fixture	61.0	<input checked="" type="checkbox"/>	<input type="checkbox"/>	3	183	All Others	<input type="checkbox"/>	<input type="checkbox"/>	
B	Lithonia 6" Downlight	11.0	<input checked="" type="checkbox"/>	<input type="checkbox"/>	8	88	Corridor/Restroom/Support	<input type="checkbox"/>	<input type="checkbox"/>	
			<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	
			<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	
INSTALLED WATTS PAGE TOTAL:						4,807	Enter sum total of all pages into NRCC-LTI-01-E; Page 2			

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance April 2016

STATE OF CALIFORNIA  
**INDOOR LIGHTING**  
 CEC-NRCC-LTI-01-E (Revised 04/18)

CALIFORNIA ENERGY COMMISSION

CERTIFICATE OF COMPLIANCE NRCC-LTI-01-E  
 Indoor Lighting (Page 6 of 6)  
 Project Name: Concentra Date Prepared: 4/19/2019


**DOCUMENTATION AUTHOR'S DECLARATION STATEMENT**  
 I certify that this Certificate of Compliance documentation is accurate and complete.

Documentation Author Name: Duy Pham  
 Signature Date: 4/19/2019  
 Company: Q3 Engineers Inc.  
 Address: 17182 Gothard Street  
 City/State/Zip: Huntington Beach, CA 92647  
 Phone: 714-485-5200 x108

**RESPONSIBLE DESIGNER'S DECLARATION STATEMENT**  
 I certify the following under penalty of perjury, under the laws of the State of California:  
 1. The information provided on this Certificate of Compliance is true and correct.  
 2. I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer).  
 3. The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations.  
 4. The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application.  
 5. I will ensure that a completed signed copy of this Certificate of Compliance shall be made available with the building permit issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy.

Responsible Designer Name: Hiva Kamanger  
 Signature Date: 4/19/2019  
 Company: Q3 Inc.  
 Address: 17182 Gothard Street  
 City/State/Zip: Huntington Beach, CA 92647  
 License: E21432  
 Phone: 714-485-5200 x105

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance April 2016



CONCENTRA  
 3100 W. WARNER AVE. SUITE 100  
 SANTA ANA, CA 92704

CSG CONSULTANTS  
 THESE PLANS AND DETAILS ARE APPROVED  
 THE APPROVAL OF THESE PLANS SHALL NOT BE CONSTRUED TO BE A PERMIT FOR ANY VIOLATION OF ANY CODE OR ORDINANCE  
 JUN 03 2019  
 BY: [Signature]  
 THESE PLANS SHALL BE ON THE JOB FOR ALL REQUESTED INSPECTIONS.

PROJECT NO.  
18E 30046



DRAWN/REVIEWED  
DP/HK

DATE/ISSUE  
TBD

SHEET TITLE  
ELECTRICAL TITLE 24 COMPLIANCE FORMS

SHEET NO.  
ET24-1





CONCENTRA  
 3100 W. WARNER AVE, SUITE 100  
 SANTA ANA, CA 92704

STATE OF CALIFORNIA  
**INDOOR LIGHTING - LIGHTING CONTROLS**  
 CERTIFICATE OF COMPLIANCE  
 Indoor Lighting - Lighting Controls  
 Project Name: Concentra Date Prepared: 4/19/2019

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

**A. Mandatory Lighting Control Declaration Statements** (Indicate if the measure applies by checking yes or no below.)

YES	NO	Control Requirements
<input checked="" type="checkbox"/>	<input type="checkbox"/>	Lighting shall be controlled by self-contained lighting control devices which are certified to the Energy Commission according to the Title 20 Appliance Efficiency Regulations in accordance with Section 110.3.
<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lighting shall be controlled by a lighting control system or energy management control system in accordance with §110.3. An Installation Certificate shall be submitted in accordance with Section 130.4(b).
<input type="checkbox"/>	<input checked="" type="checkbox"/>	One or more Track Lighting Integral Current Limiters shall be installed which have been certified to the Energy Commission in accordance with §110.9 and §130.0. Additionally, an Installation Certificate shall be submitted in accordance with Section 130.4(b).
<input type="checkbox"/>	<input checked="" type="checkbox"/>	A Track Lighting Supplementary Overcurrent Protection Panel shall be installed in accordance with Section 110.9 and Section 130.0. Additionally, an Installation Certificate shall be submitted in accordance with Section 130.4(b).
<input type="checkbox"/>	<input checked="" type="checkbox"/>	All lighting controls and equipment shall comply with the applicable requirements in §110.9 and shall be installed in accordance with the manufacturer's instructions in accordance with Section 130.1.
<input type="checkbox"/>	<input checked="" type="checkbox"/>	All luminaires shall be functionally controlled with manually switched ON and OFF lighting controls in accordance with Section 130.1(a).
<input type="checkbox"/>	<input checked="" type="checkbox"/>	General lighting shall be separately controlled from all other lighting systems in an area. Floor and wall display, window display, case display, ornamental, and special effects lighting shall each be separately controlled on circuits that are 20 amps or less. When track lighting is used, general, display, ornamental, and special effects lighting shall each be separately controlled; in accordance with Section 130.1(a).
<input type="checkbox"/>	<input checked="" type="checkbox"/>	The general lighting of any enclosed area 100 square feet or larger, with a connected lighting load that exceeds 0.5 watts per square foot shall meet the multi-level lighting control requirements in accordance with Section 130.1(b).
<input type="checkbox"/>	<input checked="" type="checkbox"/>	All installed indoor lighting shall be equipped with controls that meet the applicable Shut-Off control requirements in Section 130.1(c).
<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lighting in all Daylit Zones shall be controlled in accordance with the requirements in Section 130.1(d) and daylight zones are shown on the plans.
<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lighting power in buildings larger than 10,000 square feet shall be capable of being automatically reduced in response to a Demand Responsive Signal in accordance with Section 130.1(e).
<input checked="" type="checkbox"/>	<input type="checkbox"/>	Before an occupancy permit is granted for a newly constructed building or area, or a new lighting system serving a building, area, or site is operated for normal use, indoor lighting controls serving the building, area, or site shall be certified as meeting the Acceptance Requirements for Code Compliance in accordance with Section 130.4(a). The controls required to meet the Acceptance Requirements include automatic daylight controls, automatic shut-off controls, and demand responsive controls.

STATE OF CALIFORNIA  
**INDOOR LIGHTING - LIGHTING CONTROLS**  
 CERTIFICATE OF COMPLIANCE  
 Indoor Lighting - Lighting Controls  
 Project Name: Concentra Date Prepared: 4/19/2019

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

**B. Mandatory and Prescriptive Indoor Lighting Control Schedule, PAF Calculation, and Field Inspection Checklist**

A separate document must be filled out for Conditioned and Unconditioned Spaces. This page is used only for the following:  
 CONDITIONED SPACES  UNCONDITIONED SPACES

Lighting Control Schedule	Standards Complying With 1										PAF Credit Calculation 4				
	(✓ all that apply, or enter 'E' if Exempted)										Watts of Controlled Lighting	PAF	Control Credit (C x L)	✓ If Acceptance Test Required	Field Inspector
01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	
Location in Building	Type/Description of Lighting Control (i.e.: occupancy sensor, automatic time switch, dimmer, automatic daylight, etc...)	# of Units	§130.1(a)	§130.0(b)	§130.1(c)	§130.1(d)	§130.1(e)	§140.6(a)	§140.6(d)				Pass	Fail	
Exam Room 8	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Exam Room 6	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Exam Room 6	Automatic Daylighting	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Exam Room 7	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Exam Room 7	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Exam Room 7	Automatic Daylighting	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Control Credit PAGE TOTAL (Sum of Column 13):										0					
IF MULTIPLE PAGES ARE USED, ENTER SUM TOTAL OF Control Credit for all pages HERE (Sum of all Column 13):															
													Enter Control Credit total into NRCC-LT-01-E; Page 1.		

1. §130.1(a) = Manual area controls; §130.0(b) = Multi Level; §130.1(c) = Auto Shut-Off; §130.1(d) = Mandatory Daylight; §130.1(e) = Demand Responsive; §140.6(a) = Additional lighting controls installed to earn a PAF; §140.6(d) = Prescriptive Secondary Sidelit Daylight Controls.  
 2. Check Table 140.6-A for correct Factor. PAFs shall not be traded between conditioned and unconditioned spaces. As a condition to earn a PAF, an Installation Certificate is also required to be filled out, signed, and submitted.

STATE OF CALIFORNIA  
**INDOOR LIGHTING - LIGHTING CONTROLS**  
 CERTIFICATE OF COMPLIANCE  
 Indoor Lighting - Lighting Controls  
 Project Name: Concentra Date Prepared: 4/19/2019

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

**B. Mandatory and Prescriptive Indoor Lighting Control Schedule, PAF Calculation, and Field Inspection Checklist**

A separate document must be filled out for Conditioned and Unconditioned Spaces. This page is used only for the following:  
 CONDITIONED SPACES  UNCONDITIONED SPACES

Lighting Control Schedule	Standards Complying With 1										PAF Credit Calculation 4				
	(✓ all that apply, or enter 'E' if Exempted)										Watts of Controlled Lighting	PAF	Control Credit (C x L)	✓ If Acceptance Test Required	Field Inspector
01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	
Location in Building	Type/Description of Lighting Control (i.e.: occupancy sensor, automatic time switch, dimmer, automatic daylight, etc...)	# of Units	§130.1(a)	§130.0(b)	§130.1(c)	§130.1(d)	§130.1(e)	§140.6(a)	§140.6(d)				Pass	Fail	
Exam Room 8	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Exam Room 8	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Exam Room 8	Automatic Daylighting	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Upper Storage Room	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Upper Storage Room	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Break Room	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Control Credit PAGE TOTAL (Sum of Column 13):										0					
IF MULTIPLE PAGES ARE USED, ENTER SUM TOTAL OF Control Credit for all pages HERE (Sum of all Column 13):															
													Enter Control Credit total into NRCC-LT-01-E; Page 1.		

1. §130.1(a) = Manual area controls; §130.0(b) = Multi Level; §130.1(c) = Auto Shut-Off; §130.1(d) = Mandatory Daylight; §130.1(e) = Demand Responsive; §140.6(a) = Additional lighting controls installed to earn a PAF; §140.6(d) = Prescriptive Secondary Sidelit Daylight Controls.  
 2. Check Table 140.6-A for correct Factor. PAFs shall not be traded between conditioned and unconditioned spaces. As a condition to earn a PAF, an Installation Certificate is also required to be filled out, signed, and submitted.

STATE OF CALIFORNIA  
**INDOOR LIGHTING - LIGHTING CONTROLS**  
 CERTIFICATE OF COMPLIANCE  
 Indoor Lighting - Lighting Controls  
 Project Name: Concentra Date Prepared: 4/19/2019

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

**B. Mandatory and Prescriptive Indoor Lighting Control Schedule, PAF Calculation, and Field Inspection Checklist**

A separate document must be filled out for Conditioned and Unconditioned Spaces. This page is used only for the following:  
 CONDITIONED SPACES  UNCONDITIONED SPACES

Lighting Control Schedule	Standards Complying With 1										PAF Credit Calculation 4				
	(✓ all that apply, or enter 'E' if Exempted)										Watts of Controlled Lighting	PAF	Control Credit (C x L)	✓ If Acceptance Test Required	Field Inspector
01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	
Location in Building	Type/Description of Lighting Control (i.e.: occupancy sensor, automatic time switch, dimmer, automatic daylight, etc...)	# of Units	§130.1(a)	§130.0(b)	§130.1(c)	§130.1(d)	§130.1(e)	§140.6(a)	§140.6(d)				Pass	Fail	
Break Room	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Upper Restroom	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Upper Restroom	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Lab Area	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Lab Area	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Lab Area	Automatic Daylighting	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Control Credit PAGE TOTAL (Sum of Column 13):										0					
IF MULTIPLE PAGES ARE USED, ENTER SUM TOTAL OF Control Credit for all pages HERE (Sum of all Column 13):															
													Enter Control Credit total into NRCC-LT-01-E; Page 1.		

1. §130.1(a) = Manual area controls; §130.0(b) = Multi Level; §130.1(c) = Auto Shut-Off; §130.1(d) = Mandatory Daylight; §130.1(e) = Demand Responsive; §140.6(a) = Additional lighting controls installed to earn a PAF; §140.6(d) = Prescriptive Secondary Sidelit Daylight Controls.  
 2. Check Table 140.6-A for correct Factor. PAFs shall not be traded between conditioned and unconditioned spaces. As a condition to earn a PAF, an Installation Certificate is also required to be filled out, signed, and submitted.

STATE OF CALIFORNIA  
**INDOOR LIGHTING - LIGHTING CONTROLS**  
 CERTIFICATE OF COMPLIANCE  
 Indoor Lighting - Lighting Controls  
 Project Name: Concentra Date Prepared: 4/19/2019

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

**B. Mandatory and Prescriptive Indoor Lighting Control Schedule, PAF Calculation, and Field Inspection Checklist**

A separate document must be filled out for Conditioned and Unconditioned Spaces. This page is used only for the following:  
 CONDITIONED SPACES  UNCONDITIONED SPACES

Lighting Control Schedule	Standards Complying With 1										PAF Credit Calculation 4				
	(✓ all that apply, or enter 'E' if Exempted)										Watts of Controlled Lighting	PAF	Control Credit (C x L)	✓ If Acceptance Test Required	Field Inspector
01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	
Location in Building	Type/Description of Lighting Control (i.e.: occupancy sensor, automatic time switch, dimmer, automatic daylight, etc...)	# of Units	§130.1(a)	§130.0(b)	§130.1(c)	§130.1(d)	§130.1(e)	§140.6(a)	§140.6(d)				Pass	Fail	
Upper Hallway	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Upper Hallway	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Upper Hallway	Automatic Daylighting	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Check In/Check Out Area	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Check In/Check Out Area	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Physical Therapy Area	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Control Credit PAGE TOTAL (Sum of Column 13):										0					
IF MULTIPLE PAGES ARE USED, ENTER SUM TOTAL OF Control Credit for all pages HERE (Sum of all Column 13):															
													Enter Control Credit total into NRCC-LT-01-E; Page 1.		

1. §130.1(a) = Manual area controls; §130.0(b) = Multi Level; §130.1(c) = Auto Shut-Off; §130.1(d) = Mandatory Daylight; §130.1(e) = Demand Responsive; §140.6(a) = Additional lighting controls installed to earn a PAF; §140.6(d) = Prescriptive Secondary Sidelit Daylight Controls.  
 2. Check Table 140.6-A for correct Factor. PAFs shall not be traded between conditioned and unconditioned spaces. As a condition to earn a PAF, an Installation Certificate is also required to be filled out, signed, and submitted.

STATE OF CALIFORNIA  
**INDOOR LIGHTING - LIGHTING CONTROLS**  
 CERTIFICATE OF COMPLIANCE  
 Indoor Lighting - Lighting Controls  
 Project Name: Concentra Date Prepared: 4/19/2019

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

**B. Mandatory and Prescriptive Indoor Lighting Control Schedule, PAF Calculation, and Field Inspection Checklist**

A separate document must be filled out for Conditioned and Unconditioned Spaces. This page is used only for the following:  
 CONDITIONED SPACES  UNCONDITIONED SPACES

Lighting Control Schedule	Standards Complying With 1										PAF Credit Calculation 4				
	(✓ all that apply, or enter 'E' if Exempted)										Watts of Controlled Lighting	PAF	Control Credit (C x L)	✓ If Acceptance Test Required	Field Inspector
01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	
Location in Building	Type/Description of Lighting Control (i.e.: occupancy sensor, automatic time switch, dimmer, automatic daylight, etc...)	# of Units	§130.1(a)	§130.0(b)	§130.1(c)	§130.1(d)	§130.1(e)	§140.6(a)	§140.6(d)				Pass	Fail	
Physical Therapy Area	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Physical Therapy Area	Automatic Daylighting	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Physician Station Hallway P	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Physician Station Hallway P	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Exam Room 5	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Exam Room 5	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Control Credit PAGE TOTAL (Sum of Column 13):										0					
IF MULTIPLE PAGES ARE USED, ENTER SUM TOTAL OF Control Credit for all pages HERE (Sum of all Column 13):															
													Enter Control Credit total into NRCC-LT-01-E; Page 1.		

1. §130.1(a) = Manual area controls; §130.0(b) = Multi Level; §130.1(c) = Auto Shut-Off; §130.1(d) = Mandatory Daylight; §130.1(e) = Demand Responsive; §140.6(a) = Additional lighting controls installed to earn a PAF; §140.6(d) = Prescriptive Secondary Sidelit Daylight Controls.  
 2. Check Table 140.6-A for correct Factor. PAFs shall not be traded between conditioned and unconditioned spaces. As a condition to earn a PAF, an Installation Certificate is also required to be filled out, signed, and submitted.

CSG CONSULTANTS  
 THESE PLANS AND DETAILS ARE APPROVED  
 THE APPROVAL OF THESE PLANS SHALL NOT BE CONSTRUED TO BE A PERMIT FOR ANY VIOLATION OF ANY CODE OR ORDINANCE  
 JUN 03 2019  
 BY: [Signature]



STATE OF CALIFORNIA  
**INDOOR LIGHTING - LIGHTING CONTROLS**  
 CERTIFICATE OF COMPLIANCE  
 Indoor Lighting - Lighting Controls  
 Project Name: Concentra Date Prepared: 4/19/2019  
 NRCC-LT-02-E (Page 2 of 3)

A separate document must be filled out for Conditioned and Unconditioned Spaces. This page is used only for the following:  
 CONDITIONED SPACES  UNCONDITIONED SPACES

**B. Mandatory and Prescriptive Indoor Lighting Control Schedule, PAF Calculation, and Field Inspection Checklist**

Lighting Control Schedule	Standards Complying With <sup>1</sup>										PAF Credit Calculation <sup>2</sup>				
	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15
Location in Building	Type/Description of Lighting Control (i.e., occupancy sensor, automatic time switch, dimmer, automatic daylight, etc.)	# of Units	\$130.1(a)	\$130.0(b)	\$130.1(c)	\$130.1(d)	\$130.1(e)	\$140.6(d)	\$140.6(d)		Watts of Controlled Lighting	PAF	Control Credit (K x L)	✓ If Acceptance Test Required	Field Inspector
Storage Room Above X-Ray	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Storage Room Above X-Ray	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Physician Station Enclosed	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Physician Station Enclosed	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
X-Ray Room	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
X-Ray Room	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Control Credit PAGE TOTAL (Sum of Column 13):											0				
IF MULTIPLE PAGES ARE USED, ENTER SUM TOTAL OF Control Credit for all pages HERE (Sum of all Column 13):											0				
												Enter Control Credit total into NRCC-LT-01-E; Page 1.			

1. \$130.1(a) = Manual area controls; \$130.0(b) = Multi Level; \$130.1(c) = Auto Shut-Off; \$130.1(d) = Mandatory Daylight; \$130.1(e) = Demand Responsive; \$140.6(d) = Additional lighting controls installed to earn a PAF; \$140.6(d) = Prescriptive Secondary Daylight Controls.  
 2. Check Table 140.6-A for correct Factor. PAFs shall not be traded between conditioned and unconditioned spaces. As a condition to earn a PAF, an Installation Certificate is also required to be filled out, signed, and submitted.

STATE OF CALIFORNIA  
**INDOOR LIGHTING - LIGHTING CONTROLS**  
 CERTIFICATE OF COMPLIANCE  
 Indoor Lighting - Lighting Controls  
 Project Name: Concentra Date Prepared: 4/19/2019  
 NRCC-LT-02-E (Page 2 of 3)

A separate document must be filled out for Conditioned and Unconditioned Spaces. This page is used only for the following:  
 CONDITIONED SPACES  UNCONDITIONED SPACES

**B. Mandatory and Prescriptive Indoor Lighting Control Schedule, PAF Calculation, and Field Inspection Checklist**

Lighting Control Schedule	Standards Complying With <sup>1</sup>										PAF Credit Calculation <sup>2</sup>				
	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15
Location in Building	Type/Description of Lighting Control (i.e., occupancy sensor, automatic time switch, dimmer, automatic daylight, etc.)	# of Units	\$130.1(a)	\$130.0(b)	\$130.1(c)	\$130.1(d)	\$130.1(e)	\$140.6(d)	\$140.6(d)		Watts of Controlled Lighting	PAF	Control Credit (K x L)	✓ If Acceptance Test Required	Field Inspector
Work Up Area	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Work Up Area	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
DT 2 Restroom	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
DT 2 Restroom	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
DT 1 Restroom	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
DT 1 Restroom	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Control Credit PAGE TOTAL (Sum of Column 13):											0				
IF MULTIPLE PAGES ARE USED, ENTER SUM TOTAL OF Control Credit for all pages HERE (Sum of all Column 13):											0				
												Enter Control Credit total into NRCC-LT-01-E; Page 1.			

1. \$130.1(a) = Manual area controls; \$130.0(b) = Multi Level; \$130.1(c) = Auto Shut-Off; \$130.1(d) = Mandatory Daylight; \$130.1(e) = Demand Responsive; \$140.6(d) = Additional lighting controls installed to earn a PAF; \$140.6(d) = Prescriptive Secondary Daylight Controls.  
 2. Check Table 140.6-A for correct Factor. PAFs shall not be traded between conditioned and unconditioned spaces. As a condition to earn a PAF, an Installation Certificate is also required to be filled out, signed, and submitted.

STATE OF CALIFORNIA  
**INDOOR LIGHTING - LIGHTING CONTROLS**  
 CERTIFICATE OF COMPLIANCE  
 Indoor Lighting - Lighting Controls  
 Project Name: Concentra Date Prepared: 4/19/2019  
 NRCC-LT-02-E (Page 2 of 3)

A separate document must be filled out for Conditioned and Unconditioned Spaces. This page is used only for the following:  
 CONDITIONED SPACES  UNCONDITIONED SPACES

**B. Mandatory and Prescriptive Indoor Lighting Control Schedule, PAF Calculation, and Field Inspection Checklist**

Lighting Control Schedule	Standards Complying With <sup>1</sup>										PAF Credit Calculation <sup>2</sup>				
	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15
Location in Building	Type/Description of Lighting Control (i.e., occupancy sensor, automatic time switch, dimmer, automatic daylight, etc.)	# of Units	\$130.1(a)	\$130.0(b)	\$130.1(c)	\$130.1(d)	\$130.1(e)	\$140.6(d)	\$140.6(d)		Watts of Controlled Lighting	PAF	Control Credit (K x L)	✓ If Acceptance Test Required	Field Inspector
Audio Room	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Audio Room	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Ball Room	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Ball Room	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
File Room	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
File Room	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Control Credit PAGE TOTAL (Sum of Column 13):											0				
IF MULTIPLE PAGES ARE USED, ENTER SUM TOTAL OF Control Credit for all pages HERE (Sum of all Column 13):											0				
												Enter Control Credit total into NRCC-LT-01-E; Page 1.			

1. \$130.1(a) = Manual area controls; \$130.0(b) = Multi Level; \$130.1(c) = Auto Shut-Off; \$130.1(d) = Mandatory Daylight; \$130.1(e) = Demand Responsive; \$140.6(d) = Additional lighting controls installed to earn a PAF; \$140.6(d) = Prescriptive Secondary Daylight Controls.  
 2. Check Table 140.6-A for correct Factor. PAFs shall not be traded between conditioned and unconditioned spaces. As a condition to earn a PAF, an Installation Certificate is also required to be filled out, signed, and submitted.

STATE OF CALIFORNIA  
**INDOOR LIGHTING - LIGHTING CONTROLS**  
 CERTIFICATE OF COMPLIANCE  
 Indoor Lighting - Lighting Controls  
 Project Name: Concentra Date Prepared: 4/19/2019  
 NRCC-LT-02-E (Page 2 of 3)

A separate document must be filled out for Conditioned and Unconditioned Spaces. This page is used only for the following:  
 CONDITIONED SPACES  UNCONDITIONED SPACES

**B. Mandatory and Prescriptive Indoor Lighting Control Schedule, PAF Calculation, and Field Inspection Checklist**

Lighting Control Schedule	Standards Complying With <sup>1</sup>										PAF Credit Calculation <sup>2</sup>				
	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15
Location in Building	Type/Description of Lighting Control (i.e., occupancy sensor, automatic time switch, dimmer, automatic daylight, etc.)	# of Units	\$130.1(a)	\$130.0(b)	\$130.1(c)	\$130.1(d)	\$130.1(e)	\$140.6(d)	\$140.6(d)		Watts of Controlled Lighting	PAF	Control Credit (K x L)	✓ If Acceptance Test Required	Field Inspector
Cad Office	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Cad Office	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Procedure Room #1	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Procedure Room #1	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Procedure Room #1	Automatic Daylighting	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Leftmost Storage Room	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Control Credit PAGE TOTAL (Sum of Column 13):											0				
IF MULTIPLE PAGES ARE USED, ENTER SUM TOTAL OF Control Credit for all pages HERE (Sum of all Column 13):											0				
												Enter Control Credit total into NRCC-LT-01-E; Page 1.			

1. \$130.1(a) = Manual area controls; \$130.0(b) = Multi Level; \$130.1(c) = Auto Shut-Off; \$130.1(d) = Mandatory Daylight; \$130.1(e) = Demand Responsive; \$140.6(d) = Additional lighting controls installed to earn a PAF; \$140.6(d) = Prescriptive Secondary Daylight Controls.  
 2. Check Table 140.6-A for correct Factor. PAFs shall not be traded between conditioned and unconditioned spaces. As a condition to earn a PAF, an Installation Certificate is also required to be filled out, signed, and submitted.

STATE OF CALIFORNIA  
**INDOOR LIGHTING - LIGHTING CONTROLS**  
 CERTIFICATE OF COMPLIANCE  
 Indoor Lighting - Lighting Controls  
 Project Name: Concentra Date Prepared: 4/19/2019  
 NRCC-LT-02-E (Page 2 of 3)

A separate document must be filled out for Conditioned and Unconditioned Spaces. This page is used only for the following:  
 CONDITIONED SPACES  UNCONDITIONED SPACES

**B. Mandatory and Prescriptive Indoor Lighting Control Schedule, PAF Calculation, and Field Inspection Checklist**

Lighting Control Schedule	Standards Complying With <sup>1</sup>										PAF Credit Calculation <sup>2</sup>				
	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15
Location in Building	Type/Description of Lighting Control (i.e., occupancy sensor, automatic time switch, dimmer, automatic daylight, etc.)	# of Units	\$130.1(a)	\$130.0(b)	\$130.1(c)	\$130.1(d)	\$130.1(e)	\$140.6(d)	\$140.6(d)		Watts of Controlled Lighting	PAF	Control Credit (K x L)	✓ If Acceptance Test Required	Field Inspector
Leftmost Storage Room	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Leftmost Storage Room	Automatic Daylighting	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Restroom Under X-Ray Roc	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Restroom Under X-Ray Roc	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Telecom Room	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Telecom Room	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Control Credit PAGE TOTAL (Sum of Column 13):											0				
IF MULTIPLE PAGES ARE USED, ENTER SUM TOTAL OF Control Credit for all pages HERE (Sum of all Column 13):											0				
												Enter Control Credit total into NRCC-LT-01-E; Page 1.			

1. \$130.1(a) = Manual area controls; \$130.0(b) = Multi Level; \$130.1(c) = Auto Shut-Off; \$130.1(d) = Mandatory Daylight; \$130.1(e) = Demand Responsive; \$140.6(d) = Additional lighting controls installed to earn a PAF; \$140.6(d) = Prescriptive Secondary Daylight Controls.  
 2. Check Table 140.6-A for correct Factor. PAFs shall not be traded between conditioned and unconditioned spaces. As a condition to earn a PAF, an Installation Certificate is also required to be filled out, signed, and submitted.


STATE OF CALIFORNIA  
**INDOOR LIGHTING - LIGHTING CONTROLS**  
 CERTIFICATE OF COMPLIANCE  
 Indoor Lighting - Lighting Controls  
 Project Name: Concentra Date Prepared: 4/19/2019  
 NRCC-LT-02-E (Page 2 of 3)

A separate document must be filled out for Conditioned and Unconditioned Spaces. This page is used only for the following:  
 CONDITIONED SPACES  UNCONDITIONED SPACES

**B. Mandatory and Prescriptive Indoor Lighting Control Schedule, PAF Calculation, and Field Inspection Checklist**

Lighting Control Schedule	Standards Complying With <sup>1</sup>										PAF Credit Calculation <sup>2</sup>				
	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15
Location in Building	Type/Description of Lighting Control (i.e., occupancy sensor, automatic time switch, dimmer, automatic daylight, etc.)	# of Units	\$130.1(a)	\$130.0(b)	\$130.1(c)	\$130.1(d)	\$130.1(e)	\$140.6(d)	\$140.6(d)		Watts of Controlled Lighting	PAF	Control Credit (K x L)	✓ If Acceptance Test Required	Field Inspector
Procedure Room #2	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Procedure Room #2	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Procedure Room #2	Automatic Daylighting	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Lower Hallway	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Lower Hallway	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Exam Room 4	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					
Control Credit PAGE TOTAL (Sum of Column 13):											0				
IF MULTIPLE PAGES ARE USED, ENTER SUM TOTAL OF Control Credit for all pages HERE (Sum of all Column 13):											0				
												Enter Control Credit total into NRCC-LT-01-E; Page 1.			

1. \$130.1(a) = Manual area controls; \$130.0(b) = Multi Level; \$130.1(c) = Auto Shut-Off; \$130.1(d) = Mandatory Daylight; \$130.1(e) = Demand Responsive; \$140.6(d) = Additional lighting controls installed to earn a PAF; \$140.6(d) = Prescriptive Secondary Daylight Controls.  
 2. Check Table 140.6-A for correct Factor. PAFs shall not be traded between conditioned and unconditioned spaces. As a condition to earn a PAF, an Installation Certificate is also required to be filled out, signed, and submitted.



CONCENTRA  
 3100 W. WARNER AVE., SUITE 100  
 SANTA ANA, CA 92704

CSG CONSULTANTS  
 THESE PLANS AND DETAILS ARE APPROVED  
 THE APPROVAL OF THESE PLANS SHALL NOT BE CONSTRUED TO BE A PERMIT FOR ANY VIOLATION OF ANY CODE OR ORDINANCE  
 JUN 03 2019  
 BY: [Signature]  
 THESE PLANS SHALL BE ON THE JOB FOR ALL REQUESTED INSPECTIONS.

PROJECT NO.  
18E 30046

DRAWN/REVIEWED  
DP/HK

DATE/ISSUE  
TBD

SHEET TITLE  
ELECTRICAL TITLE 24 COMPLIANCE FORMS

SHEET NO.  
ET24-3



STATE OF CALIFORNIA  
**INDOOR LIGHTING - LIGHTING CONTROLS**  
 DECORATED (REVISED 01/16)  
 CERTIFICATE OF COMPLIANCE  
 Indoor Lighting - Lighting Controls  
 Project Name: Concentra Date Prepared: 4/19/2019  
 NRCC-LTI-02-E (Page 2 of 3)

A separate document must be filed out for Conditioned and Unconditioned Spaces. This page is used only for the following:  
 CONDITIONED SPACES  UNCONDITIONED SPACES

**B. Mandatory and Prescriptive Indoor Lighting Control Schedule, PAF Calculation, and Field Inspection Checklist**

Lighting Control Schedule	Standards Complying With <sup>1</sup>										PAF Credit Calculation <sup>2</sup>					
	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	
Location in Building	Type/Description of Lighting Control (i.e., occupancy sensor, automatic time switch, dimmer, automatic daylight, etc.)	# of Units	\$130.1(a)	\$130.0(b)	\$130.1(c)	\$130.1(d)	\$130.1(e)	\$140.6(a)	\$140.6(b)	\$140.6(c)	Watts of Controlled Lighting	PAF	Control Credit (KCAL)	Acceptance Test Required	Field Inspector	
Exam Room 4	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	
Exam Room 4	Automatic Daylighting	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	
Exam Room 3	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	
Exam Room 3	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	
Exam Room 3	Automatic Daylighting	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	
Exam Room 2	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	
Control Credit PAGE TOTAL (Sum of Column 13):											0					
IF MULTIPLE PAGES ARE USED, ENTER SUM TOTAL OF Control Credit for all pages HERE (Sum of all Column 13):											0	Enter Control Credit total into NRCC-LTI-01-E, Page 1.				

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

STATE OF CALIFORNIA  
**INDOOR LIGHTING - LIGHTING CONTROLS**  
 DECORATED (REVISED 01/16)  
 CERTIFICATE OF COMPLIANCE  
 Indoor Lighting - Lighting Controls  
 Project Name: Concentra Date Prepared: 4/19/2019  
 NRCC-LTI-02-E (Page 2 of 3)

A separate document must be filed out for Conditioned and Unconditioned Spaces. This page is used only for the following:  
 CONDITIONED SPACES  UNCONDITIONED SPACES

**B. Mandatory and Prescriptive Indoor Lighting Control Schedule, PAF Calculation, and Field Inspection Checklist**

Lighting Control Schedule	Standards Complying With <sup>1</sup>										PAF Credit Calculation <sup>2</sup>					
	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	
Location in Building	Type/Description of Lighting Control (i.e., occupancy sensor, automatic time switch, dimmer, automatic daylight, etc.)	# of Units	\$130.1(a)	\$130.0(b)	\$130.1(c)	\$130.1(d)	\$130.1(e)	\$140.6(a)	\$140.6(b)	\$140.6(c)	Watts of Controlled Lighting	PAF	Control Credit (KCAL)	Acceptance Test Required	Field Inspector	
Exam Room 2	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	
Exam Room 2	Automatic Daylighting	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	
Exam Room 1	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	
Exam Room 1	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	
Exam Room 1	Automatic Daylighting	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	
Lower Restroom	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	
Control Credit PAGE TOTAL (Sum of Column 13):											0					
IF MULTIPLE PAGES ARE USED, ENTER SUM TOTAL OF Control Credit for all pages HERE (Sum of all Column 13):											0	Enter Control Credit total into NRCC-LTI-01-E, Page 1.				

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

STATE OF CALIFORNIA  
**INDOOR LIGHTING - LIGHTING CONTROLS**  
 DECORATED (REVISED 01/16)  
 CERTIFICATE OF COMPLIANCE  
 Indoor Lighting - Lighting Controls  
 Project Name: Concentra Date Prepared: 4/19/2019  
 NRCC-LTI-02-E (Page 2 of 3)

A separate document must be filed out for Conditioned and Unconditioned Spaces. This page is used only for the following:  
 CONDITIONED SPACES  UNCONDITIONED SPACES

**B. Mandatory and Prescriptive Indoor Lighting Control Schedule, PAF Calculation, and Field Inspection Checklist**

Lighting Control Schedule	Standards Complying With <sup>1</sup>										PAF Credit Calculation <sup>2</sup>					
	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	
Location in Building	Type/Description of Lighting Control (i.e., occupancy sensor, automatic time switch, dimmer, automatic daylight, etc.)	# of Units	\$130.1(a)	\$130.0(b)	\$130.1(c)	\$130.1(d)	\$130.1(e)	\$140.6(a)	\$140.6(b)	\$140.6(c)	Watts of Controlled Lighting	PAF	Control Credit (KCAL)	Acceptance Test Required	Field Inspector	
Lower Restroom	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	
Lower Restroom	Automatic Daylighting	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	
Welcome Lounge	Multi Level	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	
Welcome Lounge	Occupancy Sensor	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	
Welcome Lounge	Automatic Daylighting	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	
Control Credit PAGE TOTAL (Sum of Column 13):											0					
IF MULTIPLE PAGES ARE USED, ENTER SUM TOTAL OF Control Credit for all pages HERE (Sum of all Column 13):											0	Enter Control Credit total into NRCC-LTI-01-E, Page 1.				

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

STATE OF CALIFORNIA  
**INDOOR LIGHTING - LIGHTING CONTROLS**  
 DECORATED (REVISED 01/16)  
 CERTIFICATE OF COMPLIANCE  
 Indoor Lighting - Lighting Controls  
 Project Name: Concentra Date Prepared: 4/19/2019  
 NRCC-LTI-02-E (Page 3 of 3)

**DOCUMENTATION AUTHOR'S DECLARATION STATEMENT**

1. I certify that this Certificate of Compliance documentation is accurate and complete.

Documentation Author Name: Duy Pham  
 Signature Date: 4/19/2019  
 Company: C3 Engineers Inc.  
 Address: 17182 Gothard Street, Huntington Beach, CA 92647  
 Phone: 714-465-5200 x108

**RESPONSIBLE DESIGNER'S DECLARATION STATEMENT**

I certify the following under penalty of perjury, under the laws of the State of California:

- The information provided on this Certificate of Compliance is true and correct.
- I am eligible under Division 9 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer).
- The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations.
- The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application.
- I will ensure that a completed signed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy.

Responsible Designer Name: Hiva Kamangar  
 Signature Date: 4/19/2019  
 Company: C3 Inc.  
 Address: 17182 Gothard Street, Huntington Beach, CA 92647  
 License: E21432  
 Phone: 714-465-5200 x105

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

STATE OF CALIFORNIA  
**INDOOR LIGHTING POWER ALLOWANCE**  
 DECORATED (REVISED 01/16)  
 CERTIFICATE OF COMPLIANCE  
 Certificate of Compliance - Indoor Lighting Power Allowance  
 Project Name: Concentra Date Prepared: 4/19/2019  
 NRCC-LTI-03-E (Page 2 of 4)

A separate page must be filed out for Conditioned and Unconditioned Spaces. This page is only for:  
 CONDITIONED spaces  UNCONDITIONED spaces

**A. SUMMARY TOTALS OF LIGHTING POWER ALLOWANCES**

If using Complete Building Method for compliance, use only the total in column (a) as total allowed building watts.  
 If using Area Category Method, Tailored Method, or a combination of Area Category and Tailored Method for compliance, use only the total in column (b) as the total allowed building watts.

	(a)	(b)
01 Complete Building Method Allowed Watts. Documented in section B of NRCC-LTI-03-E (below on this page)		
02 Area Category Method Allowed Watts. Documented in section C-1 of NRCC-LTI-03-E (below on this page)		6,148
03 Tailored Method Allowed Watts. Documented in section A of NRCC-LTI-04-E		0
<b>TOTAL ALLOWED BUILDING WATTS. Enter number into correct cell on NRCC-LTI-01, Page 2, Row 1</b>		6,148

Check here if building contains both conditioned and unconditioned areas.

**B. COMPLETE BUILDING METHOD LIGHTING POWER ALLOWANCE**

01	02	03	04
TYPE OF BUILDING (From §140.6 Table 140.6-B)	WATTS PER FT <sup>2</sup>	COMPLETE BLDG. AREA	ALLOWED WATTS
Total Area:			
Total Watts. Enter: Total Watts into section A, row 1 (Above on this page)			

**C-1 AREA CATEGORY METHOD TOTAL LIGHTING POWER ALLOWANCES**

	Watts
Total from section C-2:	6,148
Total from section C-3:	0
Total Watts. Enter: Total Watts into section A, row 2 (Above on this page)	6,148
For Alterations Only - Reduced lighting power option (Total Allowed Watts x 0.85). Enter this value into section A, row 2 if using this option.	

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance April 2016

STATE OF CALIFORNIA  
**INDOOR LIGHTING POWER ALLOWANCE**  
 DECORATED (REVISED 01/16)  
 CERTIFICATE OF COMPLIANCE  
 Certificate of Compliance - Indoor Lighting Power Allowance  
 Project Name: Concentra Date Prepared: 4/19/2019  
 NRCC-LTI-03-E (Page 2 of 4)

A separate page must be filed out for Conditioned and Unconditioned Spaces. This page is only for:  
 CONDITIONED spaces  UNCONDITIONED spaces



**C-2 AREA CATEGORY METHOD GENERAL LIGHTING POWER ALLOWANCE**

Do not include portable lighting for offices. Portable lighting for offices shall be documented only in Section G of NRCC-LTI-03-E.  
 Separately list lighting for each primary function area as defined in §100.1 of the Standards.

Location in Building	Primary Function Area per Table 140.6-C	02		03		04
		WATTS PER FT <sup>2</sup>	X	AREA (ft <sup>2</sup> )	=	ALLOWED WATTS
Exam Areas	Comp Bldg Hospital/Healthcare	1.21		3,381		4,087
Storage Areas	All Others	0.60		84		84
Lounges	Lounge, Recreation	0.60		839		755
Restrooms	Corridor/Restroom/Support	0.60		267		160
Hallways	Corridor/Restroom/Support	0.60		921		553
Other Areas	Comp Bldg Office	0.60		646		517
<b>TOTALS</b> 6,222						
Enter sum total Area Category allowed watts into section C-1 of NRCC-LTI-03-E (this compliance document)						6,148

WATTS

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance April 2016



CONCENTRA  
 3100 W. WARNER AVE., SUITE 100  
 SANTA ANA, CA 92704

CSG CONSULTANTS  
 THESE PLANS AND DETAILS ARE APPROVED  
 THE APPROVAL OF THESE PLANS SHALL NOT BE CONSTRUED TO BE A PERMIT FOR ANY VIOLATION OF ANY CODE OR ORDINANCE

JUN 03 2019

BY: [Signature]  
 THESE PLANS SHALL BE ON THE JOB FOR ALL REQUESTED INSPECTIONS.

PROJECT NO.  
 18E 30046

DRAWN/REVIEWED  
 DP/HK

DATE/ISSUE  
 TBD

SHEET TITLE  
 ELECTRICAL TITLE 24 COMPLIANCE FORMS

SHEET NO.  
 ET24-4







**GENERAL NOTES**

- THE MECHANICAL CONTRACTOR SHALL FURNISH ALL MATERIALS, LABOR, EQUIPMENT AND ALL CONTRACTUAL EXPENSES REQUIRED FOR THE COMPLETE INSTALLATION OF THE MECHANICAL SYSTEM TO THE SATISFACTION OF THE OWNER, ARCHITECT AND MECHANICAL ENGINEER.
- THE CONTRACT DRAWINGS AND SPECIFICATIONS REPRESENT THE FINISHED WORK. UNLESS OTHERWISE SHOWN, THEY DO NOT INDICATE THE METHOD OF CONSTRUCTION. THE CONTRACTOR SHALL SUPERVISE AND DIRECT THE WORK AND SHALL BE RESPONSIBLE FOR ALL CONSTRUCTION MEANS, METHODS, TECHNIQUES AND PROCEDURES.
- FIELD OBSERVATION AND SUPPORT SERVICES PERFORMED BY THE ENGINEER PRIOR TO, DURING AND AFTER CONSTRUCTION ARE PERFORMED FOR THE PURPOSE OF ACHIEVING QUALITY CONTROL AND SHALL NOT BE CONSTRUED AS SUPERVISION OF CONSTRUCTION.
- THE INSTALLATION SHALL COMPLY WITH AND BE IN ACCORDANCE WITH ALL LEGAL AUTHORITIES AND CODES HAVING JURISDICTION. AS A MINIMUM STANDARD, ALL WORK SHALL MEET THE REQUIREMENTS OF THE 2016 CBC, 2016 CMC CODE, 2016 CEC AND 2016 CPC.
- THE MECHANICAL CONTRACTOR SHALL OBTAIN AND PAY FOR ALL PERMITS, LICENSES, INSPECTIONS AND PLAN CHECKS REQUIRED TO COMPLETE THIS JOB.
- THE MECHANICAL CONTRACTOR SHALL GUARANTEE ALL EQUIPMENT, APPARATUS, ACCESSORIES AS FURNISHED BY HIM OR HIS SUBCONTRACTORS FOR A PERIOD OF ONE YEAR.
- COORDINATE THE SIZE, LOCATION AND SERVICE REQUIREMENTS OF ALL MECHANICAL EQUIPMENT, DUCTWORK AND PIPING WITH THE GENERAL CONTRACTOR, PLUMBING CONTRACTOR, ELECTRICAL CONTRACTOR AND FIRE PROTECTION CONTRACTOR PRIOR TO THE START OF CONSTRUCTION. REPORT ALL UNRESOLVED CONFLICTS TO THE OWNER/ARCHITECT/ENGINEER.
- COORDINATE THE LOCATION OF ALL CEILING OR WALL DIFFUSERS, REGISTERS, GRILLES AND ACCESS OPENINGS WITH THE ARCHITECTURAL REFLECTED CEILING PLANS OR ACTUAL EXISTING FIELD CONDITIONS.
- ALL NEW DUCTWORK SHALL BE MIN. 26 GA. GALVANIZED SHEET METAL, RIGID DUCT GAUGES, CONSTRUCTION, SUPPORTS AND INSTALLATION SHALL BE IN ACCORDANCE WITH THE 2016 CMC, SMACNA STANDARDS AND ASHRAE STANDARDS.
- FLEXIBLE DUCT SHALL BE JOHNS-MANVILLE "MICRO-AIRE J/FLX" TYPE INSULATED FIBERGLASS DUCT OR APPROVED EQUAL. LENGTH SHALL NOT EXCEED SEVEN FEET. CONNECTIONS OF FLEXIBLE DUCT TO ROUND DUCTS OR COLLARS SHALL BE MADE WITH 1/2" WIDE POSITIVE LOCKING STEEL STRAPS. INSTALL "DOUBLE-BANDED" WITH ADJUSTABLE NYLON "ZIP-TIES" (MACHINE APPLIED) TO ENSURE THAT THE INNER DUCT AND OUTER INSULATION PROVIDE AN INDEPENDENT LOCK-TIGHT SEAL AGAINST DUCT LEAKAGE.
- ALL CONCEALED SUPPLY, RETURN AND OUTSIDE AIR DUCTWORK SHALL BE INSULATED WITH JOHNS-MANVILLE "S-SERIES MICRO-LITE WITH FSK" TYPE FIBERGLASS DUCT INSULATION WITH ALUMINUM FOIL FACING OR APPROVED EQUAL. 1" THICK, 0.75 LBS./CU.FT. DENSITY, R=8.0 ALL DUCTWORK IN CONDITIONED SPACE NEED NOT BE INSULATED.
- ALL CUTTING, CURBING, PATCHING, PAINTING, EQUIPMENT PLATFORMS AND STRUCTURAL SUPPORTS OR PLATFORMS SHALL BE PROVIDED BY THE GENERAL CONTRACTOR UNLESS NOTED OTHERWISE.
- MATERIALS EXPOSED WITHIN DUCTS OR PLENUMS SHALL HAVE A FLAME-SPREAD INDEX OF NOT MORE THAN 25 AND A SMOKE-DEVELOPED RATING OF NOT MORE THAN 50 WHEN TESTED IN ACCORDANCE WITH CBC STD. NO. 42-1.
- IN ACCORDANCE WITH(AABC) ASSOCIATED AIR BALANCE COUNCIL STANDARDS PRIOR TO OCCUPANCY THE ENTIRE HVAC SYSTEM SHALL BE BALANCED BY AN INDEPENDENT AIR BALANCE CONTRACTOR. CERTIFICATION SHALL BE PROVIDED BY THE CONTRACTOR. BALANCING SHALL BE BASED ON THE MINIMUM DESIGN TO THIS SYSTEM LISTED IN 5.410.3.2. SYSTEM SHALL ALSO BE BALANCED AS DEFINED BY NATIONAL STANDARDS LISTED IN 5.410.3.3.1 FINAL REPORT MUST BE SIGNED BY CERTIFIED BALANCING CO. AND A O & M MANUAL TO OWNER. PER SECTION 5.410.5.1 A COPY OF INSPECTION & VERIFICATION REPORT SHALL BE GIVEN TO ENFORCING AGENCY.
- RESTRAIN, BRACE, SUPPORT ALL MECHANICAL SYSTEMS AND PIPING SYSTEMS ACCORDING TO THE STANDARDS AND GUIDELINES ESTABLISHED BY SMACNA IN THEIR GUIDE FOR SEISMIC RESTRAINS FOR MECHANICAL SYSTEMS AND PLUMBING SYSTEMS.
- THE PERSON WITH OVERALL RESPONSIBILITY FOR CONSTRUCTION OR THE PERSON RESPONSIBLE FOR THE INSTALLATION OF REGULATED MANUFACTURED DEVICES SHALL POST, OR MAKE AVAILABLE WITH THE BUILDING PERMIT(S) ISSUED FOR THE BUILDING, THE INSTALLATION CERTIFICATE(S) FOR MANUFACTURED DEVICES REGULATED BY THE APPLIANCE STANDARDS. SUCH INSTALLATION CERTIFICATE(S) SHALL BE MADE AVAILABLE TO THE ENFORCEMENTS AGENCY FOR ALL APPROPRIATE INSPECTIONS. THESE CERTIFICATES SHALL:
  - IDENTIFY FEATURES REQUIRED TO VERIFY COMPLIANCE WITH THE APPLIANCE STANDARDS;
  - INCLUDE A STATEMENT INDICATING THAT THE INSTALLED DEVICES CONFORM TO THE APPLIANCE STANDARDS AND THE REQUIREMENTS FOR SUCH DEVICES GIVEN IN THE PLANS AND SPECIFICATIONS APPROVED BY LOCAL ENFORCEMENT AGENCY;
  - STATE THE BUILDING PERMIT NUMBER UNDER WHICH THE CONSTRUCTION OR INSTALLATION WAS PERFORMED.
- THE BUILDER SHALL PROVIDE THE BUILDING OWNER OR THE PERSON(S) RESPONSIBLE FOR BUILDING MAINTENANCE (IN CASE OF MULTI-TENANT OR CENTRALLY OPERATED BUILDINGS) AT OCCUPANCY THE FOLLOWING:
  - OPERATING INFORMATION: A LIST OF THE HEATING, COOLING, WATER HEATING AND LIGHTING SYSTEMS AND FEATURES, MATERIALS, COMPONENTS AND MECHANICAL DEVICES, CONSERVATION OR SOLAR DEVICES INSTALLED IN THE BUILDING AND INSTRUCTIONS ON HOW TO USE THEM EFFICIENTLY.
  - MAINTENANCE INFORMATION: REQUIRED ROUTINE MAINTENANCE ACTION SHALL BE CLEARLY STATED AND INCORPORATED ON A READILY ACCESSIBLE LABEL. THE LABEL MAY BE LIMITED TO IDENTIFYING THE MAINTENANCE MANUAL.
- ALL EQUIPMENT SHALL BE INSTALLED IN STRICT ACCORDANCE WITH THE EQUIPMENT MANUFACTURER'S INSTRUCTIONS. MAINTENANCE LABEL SHALL BE ATTACHED TO ALL MECHANICAL EQUIPMENT AND A MAINTENANCE MANUAL SHALL BE PROVIDED FOR THE OWNER'S USE.
- THE THERMOSTATIC CONTROLS FOR HVAC SYSTEMS SHALL MEET THE FOLLOWING REQUIREMENTS AS APPLICABLE:
  - EACH SPACE CONDITIONING SYSTEM SHALL BE CONTROLLED BY AN INDIVIDUAL THERMOSTATIC CONTROL.
  - THERMOSTATIC CONTROLS SHALL BE CAPABLE OF BEING SET LOCALLY BY ADJUSTMENT OR SELECTION OF SENSORS;
    - DOWN TO 55°F OR LOWER TO CONTROL HEATING AND
    - UP TO 85°F OR HIGHER TO CONTROL COOLING AND
    - BOTH A & B CONDITIONS TO CONTROL BOTH HEATING AND COOLING.
  - TO CONTROL BOTH HEATING AND COOLING, THE THERMOSTATIC CONTROLS SHALL BE CAPABLE OF PROVIDING A TEMPERATURE RANGE OR DEAD BAND OF AT LEAST 5°F WITHIN WHICH THE SUPPLY OF HEATING AND COOLING ENERGY TO THE ZONE IS SHUT OFF OR REDUCED TO A MINIMUM.
- ALL DUCTS SHALL BE INSTALLED AND INSULATED IN COMPLIANCE WITH SECTIONS 601, 603 AND 604 OF THE LATEST ADOPTED IMC.
- ALL SUBMITTED AND APPROVED ALTERNATE MECHANICAL EQUIPMENT, MATERIAL AND/OR CONTROL SYSTEM SHALL BE COORDINATED BY THE MECHANICAL AND GENERAL CONTRACTORS. ANY ADDITIONAL EQUIPMENT WEIGHTS AND ELECTRICAL LOADS, ALTERNATE ROOF OR STRUCTURAL OPENINGS SHALL BE REVIEWED AND INSTALLED BY THE MECHANICAL CONTRACTOR WITH HIS OWN EXPENSES AND RESPONSIBILITIES.

**NEW - SPLIT SYSTEM INDOOR FAN COIL**

UNIT NO.	MANUFACTURER & MODEL NO.	NOM. CAP. TONS	SERVICE	MATCHING OUTDOOR UNIT	AIR QUANTITY (CFM)	OSA	EXTERNAL S.P. (IN. WG.)	COIL DATA				ELECTRICAL			OPERATING WEIGHTS (LBS.)	REMARKS	
								FACE AREA (SQ. FT.)	ROWS	E.A.T. D.B. (°F)	E.A.T. W.B. (°F)	HP	VOLTAGE V / PH / HZ	MCA			MOCP
FC 1	CARRIER FV4C006	5.0	USH	HP 1	1,950	400	0.80	7.4	3	80	67	3/4	230/1/60	14.0	15.0	207#	FACTORY FURNISHED CONDENSATE OVERFLOW SWITCH, PROGRAMMABLE T'STAT, ECONOMIZER, CONDENSATE PUMP
FC 2	CARRIER FV4C006	4.0	USH	HP 2	1,500	450	0.80	7.4	3	80	67	3/4	230/1/60	14.0	15.0	207#	OUTSIDE VALUES MATCH T-24. SHT. MT24.2 MCH-03-E
FC 3	CARRIER 40RU0408	7.5	USH	HP 3	3,000	600	0.80	8.3	4	80	67	3.0	230/3/60	14.0	20.0	485#	FACTORY FURNISHED CONDENSATE OVERFLOW SWITCH, PROGRAMMABLE T'STAT, ECONOMIZER, CONDENSATE PUMP PROVIDE ALTERNATE MOTOR. OUTSIDE VALUES MATCH T-24. SHT. MT24.2 MCH-03-E

**NEW - SPLIT SYSTEM OUTDOOR HEAT PUMP UNIT**

UNIT NO.	MANUFACTURER & MODEL NO.	NOM. CAP. TONS	SERVICE	MATCHING INDOOR UNIT	COOLING CAPACITY MBH		AMBIENT TEMPERATURE (°F)	E.E.R.	HEATING INTEGRATED-MBH	ELECTRICAL		OPERATING WEIGHTS (LBS.)	REMARKS
					SENSIBLE	TOTAL				MINIMUM CIRCUIT AMPS	MAXIMUM FUSE AMPS		
HP 1 (SPLIT SYS.)	CARRIER 25HCE60	5.0	USH	FC 1	60.0	65.0	95.0	11.0	66.0	21.5	30.0	230-3-60	212
HP 2 (SPLIT SYS.)	CARRIER 25HCE48	4.0	USH	FC 2	60.0	65.0	95.0	11.0	66.0	14.5	25.0	230-3-60	197
HP 3 (SPLIT SYS.)	CARRIER 38AU0408	7.5	USH	FC 3	65.0	55.0	95.0	11.0	66.0	40.0/40.0	60.0/60.0	230-3-60	483

**NEW-ROOFTOP AIR CONDITIONING UNIT SCHEDULE - HEAT PUMP**

MARK	SERVES	MANUFACTURER & MODEL NO.	NOMINAL TONS	AIR QUANTITIES (CFM)			O.S.A.	E.S.P.	COOLING CAPACITY		(EER) (SEER)	HEATING INTEGRATED	ELEC. DATA	MCA	MOCP	-----	FILTERS	WGHT. (lbs.)	REMARKS
				SUPPLY	RETURN	RETURNS			TOTAL	SENSIBLE									
RTU 1	USH	CARRIER 50VR60	5	1,900	1,500	400	.8"		50,000 BTUH	40,000 BTUH	12.0	25.0 MBH	230/1/60	44.8	60.0			511#	PROGRAMMABLE T'STAT W/ LOCKING COVER, SMOKE DETECTOR, ROOF CURB, ECONOMOZER, PROVIDE STRUCTURAL CALCULATIONS. OUTSIDE VALUES MATCH T-24. SHT. MT24.2 MCH-03-E, EXISTING CURB, SMOKE DETECTOR

**PLAN CHECK NOTES**

- PENETRATIONS IN WALLS REQUIRING PROTECTED OPENINGS MUST BE FIRESTOPPED WITH AN APPROVED 3M FIRE BARRIER SEALANT ICOC AND UL APPROVED PER 713.3. A. COPPER OR FERROUS PIPES OR CONDUITS MAY PENETRATE THE WALLS OR PARTITIONS, PROVIDED THEY ARE FIRESTOPPED. B. OPENINGS FOR STEEL ELECTRICAL OUTLET BOXES NOT EXCEEDING 16 SQUARE INCHES ARE PERMITTED, PROVIDED OPENINGS DO NOT EXCEED AN AGGREGATE AREA OF MORE THAN 100 SQUARE INCHES FOR ANY 100 SQUARE FEET OF WALL OR PARTITIONS. OUTLET BOXES ON OPPOSITE SIDES OF WALLS OR PARTITIONS MUST BE SEPARATED BY A HORIZONTAL DISTANCE OF 24 INCHES. C. WHERE WALLS ARE PENETRATED BY OTHER MATERIALS OR WHERE LARGER OPENINGS ARE REQUIRED THAN PERMITTED IN (B) ABOVE, THEY MUST BE QUALIFIED BY TESTS CONDUCTED IN ACCORDANCE WITH SECTION 703.
- CONSTRUCTION OR WORK FOR WHICH A PERMIT IS REQUIRED SHALL BE SUBJECT TO INSPECTION BY THE BUILDING OFFICIAL AND SUCH CONSTRUCTION OR WORK SHALL REMAIN ACCESSIBLE AND EXPOSED FOR INSPECTION PURPOSES UNTIL APPROVED. INSPECTIONS CAN BE REQUESTED BY CALLING THE INSPECTION LINE AT 562-570-6105.
- HEATING, VENTILATION AND AIR-CONDITIONING SYSTEMS OF ALL STRUCTURES SHALL BE DESIGNED AND INSTALLED FOR EFFICIENT UTILIZATION OF ENERGY IN ACCORDANCE WITH THE CALIFORNIA ENERGY CODE.
- APPLIANCES, APPURTENANCES AND EQUIPMENT REQUIRED BY THE CMC SHALL BE LISTED AND LABELED FOR THE APPLICATION IN WHICH THEY ARE INSTALLED AND USED (CMC SECTIONS 301.2, 302.1, AND 303.1)
- LABELING SHALL BE IN ACCORDANCE WITH THE PROCEDURES SET FORTH IN CMC 307.0.
- THE VENTILATION AIR DISTRIBUTION SYSTEM SHALL BE PROVIDED WITH MEANS TO ADJUST THE SYSTEM TO ACHIEVE AT LEAST THE MINIMUM VENTILATION AIRFLOW RATE AS REQUIRED BY THE CMC SECTION 403. VENTILATION SYSTEMS SHALL BE BALANCED BY AN APPROVED METHOD. SUCH BALANCING SHALL VERIFY THAT THE VENTILATION SYSTEM IS CAPABLE OF SUPPLYING AND EXHAUSTING THE AIRFLOW RATES REQUIRED BY CMC SECTIONS 403.2. SUCH AIR BALANCE REPORTS SHALL BE PROVIDED TO THE INSPECTOR AT TIME OF INSPECTION. AIR BALANCE REPORTS MAY BE REQUESTED BY THE INSPECTOR DURING ANNUAL INSPECTIONS TO ENSURE ONGOING COMPLIANCE WITH CITY REQUIREMENTS, AND WHEN ISSUES OR CONCERNS REGARDING ODORS ARE BROUGHT TO THE ATTENTION OF THE CITY.
- WHEN CARBON DIOXIDE IS STORED, USED, OR GENERATED IN A BUILDING, A CONTINUOUS VENTILATION SYSTEM SHALL BE PROVIDED AS REQUIRED BY THE CFC SECTION 5308.2.
- ALL MECHANICAL EQUIPMENT AND SYSTEMS INSTALLED AS PART OF PROJECT SHALL COMPLY WITH ALL REQUIREMENTS OF THE 2016 CMC AND THE 2016 CBC, 2016 CALIFORNIA GREEN BUILDING STANDARDS CODE AND 2016 CALIFORNIA BUILDING ENERGY EFFICIENCY STANDARDS.
- ALL DUCTWORK FOR HEATING AND COOLING SYSTEM OR EVAPORATE COOLING SYSTEM SHALL BE CONDUCTED THROUGH DUCT SYSTEMS CONSTRUCTED OF METAL AS SET FORTH IN SMACNA HVAC DUCT CONSTRUCTION STANDARD - METAL AND FLEXIBLE. FACTORY MADE AIR DUCTS SHALL BE APPROVED FOR THE USE INTENDED OR SHALL COMPLY WITH THE 2013 CMC REFERENCED STANDARDS CHAPTER 17 (CMC 602.1).
- THE REQUIRED SERVICE DISTANCE FROM THE MECHANICAL EQUIPMENT TO SCREENING, PARAPETS, WALLS AND OTHER EQUIPMENT SHALL BE A MINIMUM OF 30"x30" ON THE SERVICE SIDE OF THE EQUIPMENT, OR AS REQUIRED BY THE MANUFACTURER'S INSTALLATION INSTRUCTIONS, IF THE INSTRUCTIONS REQUIRE A GREATER CLEARANCE. (CMC SECTION 304.1)
- EQUIPMENT AND APPLIANCES SHALL BE ACCESSIBLE FOR SERVICE, INSPECTION REPAIR AND REPLACEMENT WITHOUT REMOVING PERMANENT CONSTRUCTION. SUFFICIENT CLEARANCE SHALL BE MAINTAINED TO PERMIT CLEANING, REPLACEMENT OF FILTERS, BLOWERS, MOTOR CONTROLS AND LUBRICATION OF MOVING PARTS. 30" OF CLEARANCE IN DEPTH, WIDTH, AND HEIGHT SHALL BE PROVIDED TO SERVE THE APPLIANCE OR EQUIPMENT. (CMC 304.1)
- OUTSIDE AIR FOR HEATING OR COOLING SYSTEM SHALL NOT BE TAKEN FROM CLOSER THAN 10'-0" FROM AN APPLIANCE VENT OUTLET, VENT OPENING OF A PLUMBING SYSTEM, OR THE DISCHARGE OUTLET OF EXHAUST FAN, UNLESS THE OUTLET IS 3'-0" ABOVE THE OUTSIDE AIR INLET. (CMC 314.3)
- REFRIGERANT CONTAINING PORTIONS OF A SYSTEM THAT ARE FIELD ERECTED SHALL BE TESTED AND PROVED TIGHT TO THE AUTHORITY HAVING JURISDICTION AFTER COMPLETE INSTALLATION AND BEFORE OPERATION. THE HIGH LOW SIDES OF EACH SYSTEM SHALL BE TESTED AND PROVED TIGHT AT NOT LESS THAN THE LOWER OF THE PRESSURE IN CMC TABLE 1124.2 OR THE SETTING THE PRESSURE RELIEF DEVICE (CMC 1124.2)
- ONE OF THE FOLLOWING METHODS IS REQUIRED TO COMPLY WITH MECH-3 VENTILATION REQUIREMENTS
  - AIR BALANCING: ALL SPACE CONDITIONING AND VENTILATION SYSTEMS SHALL BE BALANCED TO THE QUANTITIES SPECIFIED IN THESE PLANS, IN ACCORDANCE WITH THE NATIONAL ENVIRONMENTAL BALANCING BUREAU (NEBB), PROCEDURAL STANDARDS (1983), OR ASSOCIATED AIR BALANCE COUNCIL, (AABC, NATIONAL STANDARDS (1986)
  - OUTSIDE AIR CERTIFICATION: THE SYSTEM SHALL PROVIDE THE MINIMUM OUTSIDE AIR AS SHOWN ON THE MECHANICAL DRAWINGS, AND SHALL BE MEASURED AND CERTIFIED BY THE INSTALLING LICENSED C-20 MECHANICAL CONTRACTOR. (AIR BALANCING SHALL COMPLY TO CGSBC 5.410.1)

**MECHANICAL LEGEND**

SYMBOL	DESCRIPTION	ABBREV.
	SUPPLY DUCT	S.
	RETURN AIR DUCT	R.
	EXHAUST AIR DUCT	E.
	CEILING DIFFUSER 1-2-3 OR 4 WAY THROW	C.D.
	CEILING REGISTER	C.R.
	ACCESS PANEL	A.P.
	FIRE DAMPER	F.D.
	THERMOSTAT	
	SENSOR	
	SMOKE DETECTOR	
	CO2 SENSOR	
	GENERAL CONTRACTOR	G.C.
	POINT OF CONNECTION TO EXISTING	POC
	CUBIC FEET PER MINUTE	CFM

**NEW EXHAUST FAN SCHEDULE**

TAG	MFGR. MODEL#	SERVES	CFM	S.P.	RPM	WATTS	ELECTRICAL	WEIGHT	REMARKS
EF 1	GRENNHECK SP A200	RESTROOM	68	.75	900	56.1	120/1/60	24 LBS.	INTERLOCK W/LIGHT SWITCH
EF 2	GRENNHECK SP A200	RESTROOM	68	.75	900	56.1	120/1/60	24 LBS.	INTERLOCK W/LIGHT SWITCH
EF 3	GRENNHECK SP A200	RESTROOM	68	.75	900	56.1	120/1/60	24 LBS.	INTERLOCK W/LIGHT SWITCH
EF 4	GRENNHECK SP A200	RESTROOM	68	.75	900	56.1	120/1/60	24 LBS.	INTERLOCK W/LIGHT SWITCH
EF 5	GRENNHECK SP A200	RESTROOM	68	.75	900	56.1	120/1/60	24 LBS.	INTERLOCK W/LIGHT SWITCH
EF 6	GRENNHECK SP A200	JANITOR	68	.75	900	56.1	120/1/60	24 LBS.	INTERLOCK W/LIGHT SWITCH

**AIR DEVICE SCHEDULE**

SYMBOL	MAKE/MODEL	DESCRIPTION	FACE/TYPE	REMARKS
(A)	TITUS TDC	SUPPLY LINEAR DIFFUSER	T-BAR 24"x24"	NECK SIZE ON DRAWINGS
(B)	TITUS 50F	RETURN GRILLE	T-BAR 24"x24"	NECK SIZE ON DRAWINGS 1/2"x1/2"x1/2" DUCT PAINTED BLACK IN THE INSIDE
(C)	TITUS TDC	SUPPLY LINEAR DIFFUSER	SURFACE MTD. 12"x12"	NECK SIZE ON DRAWINGS
(D)	TITUS 50F	RETURN GRILLE	T-BAR 12"x12"	NECK SIZE ON DRAWINGS 1/2"x1/2"x1/2" DUCT PAINTED BLACK IN THE INSIDE

NOTE: 1. SEE PLANS FOR NECK SIZES OF AIR DEVICES

AIR DEVICE LEGEND:

	SUPPLY DIFFUSER		EXHAUST REGISTER
	RETURN GRILLE/TRANSFER GRILLE		SUPPLY/RETURN LINEAR

JUN 06 2019

**GENERAL BUILDING REQUIREMENTS**

- ALL CONSTRUCTION AND REMODELING WORK MUST BE PERFORMED BY CA LICENSED CLASS A OR CLASS B CONTRACTORS. ALL BUILDING TRADES WORK MUST BE PERFORMED BY A STATE OF CALIFORNIA LICENSED CONTRACTOR(S).
- BUILDING CODES AND STANDARDS ARE AS FOLLOWS:
  - 2016 CALIFORNIA BUILDING CODE (CBC)
  - 2016 CALIFORNIA EXISTING BUILDING CODE (CEB)
  - 2016 CALIFORNIA MECHANICAL CODE (CMC)
  - 2016 CALIFORNIA PLUMBING CODE (CPC)
  - 2016 CALIFORNIA FIRE CODE (CFC)
  - 2016 CALIFORNIA ELECTRICAL CODE (CEC)
  - 2016 CALIFORNIA ENERGY CODE

ISSUE DATE

XXXX

CONCENTRA CONSULTANTS INC. REGISTERED PROFESSIONAL ENGINEER No. M 28203 EXP. 6/30/19 MECHANICAL STATE OF CALIFORNIA

3100 W. WARNER AVE, SUITE 100 SANTA ANA, CA 92704

PROJECT NO. 18E 30043

DRAWN/REVIEWED RJM/TB


DATE/ISSUE TBD

SHEET TITLE MECHANICAL COVER SHEET

SHEET NO. M-0.0

401 33001 RECHECK





**MECHANICAL FLOOR PLAN**  
SCALE: 3/16"=1'-0"

**MECHANICAL GENERAL NOTES**



1. REMOVE ALL EXISTING AIR DISTRIBUTION AND DISPOSE OF PROPERLY.
2. CONTRACTOR TO VERIFY ALL SITE CONDITIONS PRIOR TO BID AND INSTALLATION.

**MECHANICAL KEY NOTES**

<p>1 PROVIDE M.V.D. FOR ALL SUPPLY DUCTWORK TO SUPPLY GRILLES FOR BALANCING.(TYPICAL THRU-OUT)</p> <p>2 18"x16" LINED SUPPLY AND RETURN AIR DUCT UP TO RTU-1. NEW 5-TON UNIT ON ROOF. DUCTWORK SHALL BE ROUTED UP THRU 2ND LEVEL FLOOR AT AREA SHOWN WHERE EXISTING STAIRS ARE TO BE REMOVED AND A SHAFT FOR THESE DUCTS SHALL BE ADDED. PROVIDE TURNING VANES FOR ALL 90° TURNS UP TO ROOF LEVEL.</p> <p>3 INSTALL NEW EXHAUST FAN AND TIE INTO EXISTING EXHAUST DUCT TO EXTERIOR OF BUILDING.</p> <p>4 PROVIDE REFRIGERANT LINES UP TO HEAT PUMP ON ROOF. CONTRACTOR TO VERIFY IN FIELD EXACT ROUTING.</p> <p>5 PROVIDE SMOKE DETECTOR. UNIT TO SHUT DOWN UPON DETECTION OF SMOKE WITH TEST STATION PER CMC 2016.</p>	<p>6 PROVIDE 12"Ø OSA DUCT UP THRU ROOF TO APPROVED TERMINATION WITH BACK DRAFT DAMPER AND M.V.D. CFM TO MATCH T-24.</p> <p>7 PROVIDE CONDENSATE DRAIN TO APPROVED RECEPTOR BY PLUMBER.</p>
---	---

CSG CONSULTANTS  
THESE PLANS AND DETAILS ARE APPROVED  
THE APPROVAL OF THESE PLANS SHALL NOT BE CONSTRUED TO BE A PERMIT FOR ANY VIOLATION OF ANY CODE OR ORDINANCE  
JUN 06 2019  
BY: *[Signature]*  
THESE PLANS SHALL BE ON THE JOB FOR ALL REGISTERED INSTRUCTIONS

ISSUE	DATE
Δ	XXXX



CONCENTRA  
3100 W. WARNER AVE, SUITE 100  
SANTA ANA, CA 92704

PROJECT NO. 18E 30043
DRAWN/REVIEWED RJM/TB
DATE/ISSUE TBD
SHEET TITLE MECHANICAL FLOOR PLAN
SHEET NO. M-1.0




PHASE 4



PHASE 3

PHASE 2

PHASE 1



ISSUE	DATE
Δ	XXXX



CONCENTRA  
3100 W. WARNER AVE. SUITE 100  
SANTA ANA, CA 92704

CSG CONSULTANTS  
THESE PLANS AND DETAILS ARE APPROVED  
THE APPROVAL OF THESE PLANS SHALL NOT BE CONSTRUED TO BE A PERMIT FOR ANY VIOLATION OF ANY CODE OR ORDINANCE  
JUN 06 2019

**MECHANICAL GENERAL NOTES**

- EXISTING ROOF ACCESS PER CMC 94.10.3.
- AIR CONDITIONING REFRIGERATION SERVICE PORTS LOCATED OUTDOORS SHALL BE FITTED WITH LOCKING TYPE TAMPER RESISTANT CAP OR SHALL BE PROTECTED FROM UNAUTHORIZED ACCESS BY A MEANS ACCEPTABLE TO THE BUILDING DEPARTMENT PER CMC SECTION 1106.1.4.
- ROOFTOP EQUIPMENT SHALL BE LOCATED A MINIMUM OF 10 FEET FROM THE EDGE OF THE ROOF PER SECTION C.M.C. THE DISTANCE MAY BE LESS THAN 10 FEET BASED ON THE C.B.C REQUIREMENTS, BUT NOT LESS THAN 6 FEET, IF IT CAN BE SHOWN THAT THE PARAPET IS AT LEAST 30 INCHES HIGH OR A GUARD 30 INCHES HIGH IS PROVIDED PER CODE. IF THE DISTANCE FROM THE EDGE OF THE ROOF IS LESS THAN 6 FEET, 2010 C.M.C. SHALL APPLY AND IF THE PARAPET IS LESS THAN 42 INCHES HIGH A GUARD RAIL AT LEAST 42 INCHES HIGH INSTALLED AT THE EDGE OF THE ROOF WOULD MEET THE REQUIREMENTS.  
C.M.C. MINIMUM 6'-0" FROM EDGE OF ROOF OR 42" GUARDS OR PARAPETE ON EXPOSED SIDE.



**MECHANICAL FLOOR PLAN**

SCALE: 1/4"=1'-0"


**STRUCTURAL NOTES**

- ALL NEW ROOFTOP UNITS ARE LIGHTER IN WEIGHT THAN THE NEW UNITS
- EXCEPTION RTU-1: THE WEIGHT IS WITHIN 5% OF THE EXISTING WEIGHTS.

**MECHANICAL KEY NOTES**

- REMOVE PACKAGE UNIT AND PROVIDE NEW SPLIT SYSTEM HEAT PUMP.
- ROOFTOP UNIT N.I.C. EXISTING UNIT TO REMAIN. UNIT SERVING 2ND LEVEL STORAGE AREA.
- RTU-1 - REMOVE AND REPLACE UNIT SAME LOCATION INSIDE EQUIPMENT SCREEN(DOWN DISCHARGE), PROVIDE TURNING VANES AT EACH 90° TURN CONNECT EXISTING 3/4" CONDENSATE DRAIN TO EXISTING APPROVED RECEPTOR PER CPC 2013 BY PLUMBER. VERIFY ROOF CURB MATCHES EXISTING UNIT. 4 TON TO 5 TON.
- EXISTING WOOD FRAMED SCREEN TO REMAIN.
- DUCTWORK ON ROOF TO BE REMOVED AND DISPOSED OF PROPERLY. ROOF OPENINGS TO PATCHED AND WATER PROOFED.

PROJECT NO.	18E 30043
DRAWN/REVIEWED	RJM/TB
DATE/ISSUE	TBD
SHEET TITLE	MECHANICAL ROOF PLAN
SHEET NO.	M-2



NOTE: FOR ADDITIONAL INFORMATION REFER TO THE LATEST EDITION OF SMACNA


**TABLE 4-1 - RECTANGULAR DUCT HANGERS - MINIMUM SIZE**

MAXIMUM HALF OF DUCT PERIMETER	PAIR AT 10 FT. SPACING		PAIR AT 8 FT. SPACING		PAIR AT 5 FT. SPACING		PAIR AT 4 FT. SPACING	
	STRAP	WIRE/ROD	STRAP	WIRE/ROD	STRAP	WIRE/ROD	STRAP	WIRE/ROD
$\frac{P}{2} = 30"$	1" x 22 ga.	10 ga. (.135")	1" x 22 ga.	10 ga. (.135")	1" x 22 ga.	12 ga. (.106")	1" x 22 ga.	12 ga. (.106")
$\frac{P}{2} = 72"$	1" x 18 ga.	3/8"	1" x 20 ga.	1/4"	1" x 22 ga.	1/4"	1" x 22 ga.	1/4"
$\frac{P}{2} = 96"$	1" x 16 ga.	3/8"	1" x 18 ga.	3/8"	1" x 20 ga.	3/8"	1" x 22 ga.	1/4"
$\frac{P}{2} = 120"$	1 1/2" x 16 ga.	1/2"	1" x 16 ga.	3/8"	1" x 18 ga.	3/8"	1" x 20 ga.	1/4"
$\frac{P}{2} = 168"$	1 1/2" x 16 ga.	1/2"	1 1/2" x 16 ga.	1/2"	1" x 16 ga.	3/8"	1" x 18 ga.	3/8"
$\frac{P}{2} = 192"$	-	1/2"	1 1/2" x 16 ga.	1/2"	1" x 16 ga.	3/8"	1" x 18 ga.	3/8"
$\frac{P}{2} = 193"$ up	SPECIAL ANALYSIS REQUIRED							

DO NOT SUPPORT/ATTACH FROM DECK ABOVE TYP. ALL TRADES


RECTANGULAR DUCT HANGER ATTACHMENT DETAIL

SCALE NONE 1



DUCT THRU ROOF DETAIL

SCALE NONE 2




**MINIMUM HANGER SIZES FOR ROUND DUCT**

DIA.	MAXIMUM SPACING	WIRE DIA.	STRAP
10" dn	12'	One 12 ga.	1" x 22 ga.
11-18"	12'	Two 12 ga. or One 8 ga.	1" x 22 ga.
19-24"	12'	Two 10 ga.	1" x 20 ga.
25-36"	12'	Two 8 ga.	1" x 20 ga.
37-50"	12'	-	Two 1" x 20 ga.
51-60"	12'	-	Two 1" x 18 ga.
61-84"	12'	-	Two 1" x 16 ga.

FOR ADDITIONAL INFORMATION REFER TO THE LATEST EDITION OF SMACNA

ROUND DUCT HANGER ATTACHMENT DETAIL


SCALE NONE 3



- NOTES:
1. TYPICAL FOR NON-INSULATED PIPE AND CONDUIT.
  2. TYPICAL FOR MASONRY OR CONCRETE WALL.
  3. FIRE RATED WALLS MUST BE SEALED WITH APPROPRIATE FIRE RETARDED CAULKING PER CODE.
  4. WHERE PIPING IS EXPOSED AT FINISH WALLS, FLUSH MOUNT SLEEVE AND PROVIDE ESCUTCHEON PLATE.
  5. DUCT THRU WALL SHALL BE SIMILAR.
  6. WALL PENETRATION IN ACCORDANCE WITH C.B.C.


PIPE PENETRATION THRU WALLS

SCALE NONE 4




AIR DEVICE MOUNTING DETAIL

SCALE NONE 5




ROOFTOP A/C UNIT DETAIL

SCALE NONE 6




ROOFTOP A/C UNIT DETAIL

SCALE NONE 7



AIR DEVICE MOUNTING DETAIL

SCALE NONE 8



CONDENSATE DRAIN DETAIL

SCALE NONE 9



**A. MECHANICAL COMPLIANCE DOCUMENTS & WORKSHEETS** (check box if worksheet is included)

For detailed instructions on the use of this and all Energy Efficiency Standards compliance forms, refer to the 2016 Nonresidential Manual Note: The Enforcement Agency may require all forms to be incorporated into the building plans.

YES	NO	Comp. Doc./Worksheet #	Title
<input type="checkbox"/>	<input type="checkbox"/>	NRCC-MCH-01-E (Part 1 of 3)	Certificate of Compliance, Declaration, Required on plans for all submittals.
<input type="checkbox"/>	<input type="checkbox"/>	NRCC-MCH-01-E (Part 2 of 3)	Certificate of Compliance, Required Acceptance Tests (MCH-02-A to 11-A), Required on plans for all submittals.
<input type="checkbox"/>	<input type="checkbox"/>	NRCC-MCH-01-E (Part 3 of 3)	Certificate of Compliance, Required Acceptance Tests (MCH-12-A to 18-A), Required on plans where applicable.
<input type="checkbox"/>	<input type="checkbox"/>	NRCC-MCH-02-E (Part 1 of 2)	Mechanical Dry Equipment Summary is required for all submittals with Central Air Systems. It is optional on plans.
<input type="checkbox"/>	<input type="checkbox"/>	NRCC-MCH-02-E (Part 2 of 2)	Mechanical Ventilation and Reheat is required for all submittals with multiple zone heating and cooling systems. It is optional on plans.
<input type="checkbox"/>	<input type="checkbox"/>	NRCC-MCH-03-E	Mechanical Ventilation and Reheat is required for all submittals with multiple zone heating and cooling systems. It is optional on plans.
<input type="checkbox"/>	<input type="checkbox"/>	NRCC-MCH-07-E (Part 1 of 2)	Power Consumption of Fans, Required on plans where applicable.
<input type="checkbox"/>	<input type="checkbox"/>	NRCC-MCH-07-E (Part 2 of 2)	Power Consumption of Fans, Declaration, Required on plans where applicable.

**B. MECHANICAL HVAC ACCEPTANCE FORMS** (check box for required compliance documents)

Test Performed By: \_\_\_\_\_

Designer: \_\_\_\_\_

This compliance document is to be used by the designer and attached to the plans. Listed below are all the acceptance tests for HVAC systems. The designer is required to check the applicable boxes for all acceptance tests that apply and list all equipment that requires an acceptance test. All equipment of the same type that requires a test, list the equipment description and the number of systems.

Installing Contractor: \_\_\_\_\_

The contractor who installed the equipment is responsible to either conduct the acceptance test themselves or have a qualified entity run the test for them. If more than one person has responsibility for the acceptance testing, each person shall sign and submit the Certificate of Acceptance applicable to the portion of the construction or installation for which they are responsible.

Enforcement Agency: \_\_\_\_\_

Plancheck - The NRCC-MCH-01-E compliance document is not considered a completed document and is not to be accepted by the building department unless the correct boxes are checked. Inspector - Before occupancy permit is granted all newly installed process systems must be tested to ensure proper operations.

Test Description	MCH-02-A	MCH-03-A	MCH-04-A	MCH-05-A	MCH-06-A	MCH-07-A	MCH-08-A	MCH-09-A	MCH-10-A	MCH-11-A	
Equipment Requiring Testing or Verification	# of Units	Outdoor Air	Single Zone Unitary	Air Distribution Ducts	Economizer Controls	Demand Control Ventilation (DCV)	Supply Fan VAV	Valve Leakage Test	Supply Water Temp. Reset	Hydronic System Variable Flow Control	Automatic Demand Shed Control
A.O. SMITH (E)	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Carrier 25 HCE	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Carrier 25 HCE	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Carrier 50 50VF	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Carrier 38 AUC	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

**C. MECHANICAL HVAC ACCEPTANCE FORMS** (check box for required compliance documents)

Test Performed By: \_\_\_\_\_

Designer: \_\_\_\_\_

This compliance document is to be used by the designer and attached to the plans. Listed below are all the acceptance tests for HVAC systems. The designer is required to check the applicable boxes for all acceptance tests that apply and list all equipment that requires an acceptance test. All equipment of the same type that requires a test, list the equipment description and the number of systems.

Installing Contractor: \_\_\_\_\_

The contractor who installed the equipment is responsible to either conduct the acceptance test themselves or have a qualified entity run the test for them. If more than one person has responsibility for the acceptance testing, each person shall sign and submit the Certificate of Acceptance applicable to the portion of the construction or installation for which they are responsible.

Enforcement Agency: \_\_\_\_\_

Plancheck - The NRCC-MCH-01-E compliance document is not considered a completed document and is not to be accepted by the building department unless the correct boxes are checked. Inspector - Before occupancy permit is granted all newly installed process systems must be tested to ensure proper operations.

Test Description	MCH-12-A	MCH-13-A	MCH-14-A	MCH-15-A	MCH-16-A	MCH-17-A	MCH-18-A
Equipment Requiring Testing or Verification	# of Units	Fault Detection & Diagnostics for DX Units	Automatic Fault Detection & Diagnostics for Air & Zone	Distributed Energy Storage DX AC Systems	Thermal Energy Storage (TES) Systems	Supply Air Temperature Reset	Condenser Water Reset Controls
A.O. SMITH (E)	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Carrier 25 HCE	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Carrier 25 HCE	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Carrier 50 50VF	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Carrier 38 AUC	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**DOCUMENTATION AUTHOR'S DECLARATION STATEMENT**

I certify that this Certificate of Compliance documentation is accurate and complete.

Documentation Author Name: Tony Bul  
 Signature: \_\_\_\_\_  
 Date Signed: 12/18/2018

Company: Q3 Engineers Inc.  
 Address: 17162 Gothard Street  
 City/State/Zip: Huntington Beach, CA 92647  
 Phone: 714-465-5200 x104

**RESPONSIBLE PERSON'S DECLARATION STATEMENT**

I certify the following under penalty of perjury, under the laws of the State of California:

- The information provided on this Certificate of Compliance is true and correct.
- I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer).
- The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations.
- The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application.
- I will ensure that a completed signed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy.

Responsible Designer Name: Tony Bul  
 Signature: \_\_\_\_\_  
 Date Signed: 12/18/2018  
 License: M28203  
 Phone: 714-465-5200

**A. Equipment Tags and System Description - Dry Systems**

MANDATORY MEASURES	F-24 Sections	HP-1	HP-2	RTU-1
Heating Equipment Efficiency <sup>1</sup>	110.1 or 110.2(a)			
Cooling Equipment Efficiency <sup>2</sup>	110.1 or 110.2(a)			
HVAC or Heat Pump Thermostats	110.2(b), 110.2(c)			
Furnace Standby Loss Control	110.2(d)			
Low Leakage AHUs	110.2(f)			
Ventilation <sup>3</sup>	120.1(b)			
Demand Control Ventilation <sup>4</sup>	120.1(c)			
Occupant Sensor Ventilation Control <sup>5</sup>	120.1(c)(1), 120.2(e)			
Shutoff and Reset Controls <sup>6</sup>	120.2(a)			
Outdoor Air and Exhaust Damper Control	120.2(f)			
Isolation Zones	120.2(g)			
Automatic Demand Shed Controls	120.2(h)			
Economizer FTD	120.2(i)			
Duct Insulation	120.4			

**PRESCRIPTIVE MEASURES**

Equipment is sized in conformance with 140.4(a & b)	Y	Y/N	Y	Y/N	Y	Y/N
Supply Fan Pressure Control						
Simultaneous Heat/Cool <sup>7</sup>						
Economizer						
Heat and Cool Air Supply Reset						
Electric Resistance Heating <sup>8</sup>						
Duct Leakage Sealing and Testing <sup>9</sup>						

**Notes:**

- Provide equipment tags (e.g. AHU 1 to 10) and system description (e.g. Single Duct VAV reheat) as appropriate. Multiple units with common requirements can be grouped together.
- Provide references to plans (i.e. Drawing Sheet Numbers) and/or specifications (including Section name/number and relevant paragraphs) where each requirement is specified. Enter "N/A" if the requirement is not applicable to this system.
- The referenced plans and specifications must include all of the following information: equipment tag, equipment nominal capacity, Title 24 minimum efficiency requirements, and actual rated equipment efficiencies. Where multiple efficiency requirements are applicable (e.g. full- and part-load) include all. Where appliance standards apply (110.1), identify where equipment is required to be listed per Title 20 1601 et seq.
- Identify where the ventilation requirements are documented for each central HVAC system. Include references to both central unit schedules and sequences of operation. If one or more spaces is naturally ventilated identify where this is documented in the plans and specifications. Multiple zone central air systems must also provide a MCH-03-E compliance document.
- If one or more spaces has demand controlled ventilation identify where it is specified including the sensor specifications and the sequence of operation.
- If one or more space has occupant sensor ventilation control identify where it is specified including the sensor specifications and the sequence of operation.
- If the system is DDC identify the sequences for the system start/stop, optimal start, setback (if required) and setup (if required). For all systems identify the specification for the thermostats and time clocks (if applicable).
- Identify where the heating, cooling and deadband airflows are scheduled for this system. Include a reference to the specification of the zone controls. Provide a MCH-03-E compliance document.
- Enter N/A if there is no electric heating. If the system has electric heating indicate which exception to 140.4(g) applies.
- If duct leakage sealing and testing is required, a MCH-04-A compliance document must be submitted.

**A. Equipment Tags and System Description - Dry Systems**

MANDATORY MEASURES	F-24 Sections	HP-3
Heating Equipment Efficiency <sup>1</sup>	110.1 or 110.2(a)	
Cooling Equipment Efficiency <sup>2</sup>	110.1 or 110.2(a)	
HVAC or Heat Pump Thermostats	110.2(b), 110.2(c)	
Furnace Standby Loss Control	110.2(d)	
Low Leakage AHUs	110.2(f)	
Ventilation <sup>3</sup>	120.1(b)	
Demand Control Ventilation <sup>4</sup>	120.1(c)	
Occupant Sensor Ventilation Control <sup>5</sup>	120.1(c)(1), 120.2(e)	
Shutoff and Reset Controls <sup>6</sup>	120.2(a)	
Outdoor Air and Exhaust Damper Control	120.2(f)	
Isolation Zones	120.2(g)	
Automatic Demand Shed Controls	120.2(h)	
Economizer FTD	120.2(i)	
Duct Insulation	120.4	

**PRESCRIPTIVE MEASURES**

Equipment is sized in conformance with 140.4(a & b)	Y	Y/N	Y/N	Y/N
Supply Fan Pressure Control				
Simultaneous Heat/Cool <sup>7</sup>				
Economizer				
Heat and Cool Air Supply Reset				
Electric Resistance Heating <sup>8</sup>				
Duct Leakage Sealing and Testing <sup>9</sup>				

**Notes:**

- Provide equipment tags (e.g. AHU 1 to 10) and system description (e.g. Single Duct VAV reheat) as appropriate. Multiple units with common requirements can be grouped together.
- Provide references to plans (i.e. Drawing Sheet Numbers) and/or specifications (including Section name/number and relevant paragraphs) where each requirement is specified. Enter "N/A" if the requirement is not applicable to this system.
- The referenced plans and specifications must include all of the following information: equipment tag, equipment nominal capacity, Title 24 minimum efficiency requirements, and actual rated equipment efficiencies. Where multiple efficiency requirements are applicable (e.g. full- and part-load) include all. Where appliance standards apply (110.1), identify where equipment is required to be listed per Title 20 1601 et seq.
- Identify where the ventilation requirements are documented for each central HVAC system. Include references to both central unit schedules and sequences of operation. If one or more spaces is naturally ventilated identify where this is documented in the plans and specifications. Multiple zone central air systems must also provide a MCH-03-E compliance document.
- If one or more spaces has demand controlled ventilation identify where it is specified including the sensor specifications and the sequence of operation.
- If one or more space has occupant sensor ventilation control identify where it is specified including the sensor specifications and the sequence of operation.
- If the system is DDC identify the sequences for the system start/stop, optimal start, setback (if required) and setup (if required). For all systems identify the specification for the thermostats and time clocks (if applicable).
- Identify where the heating, cooling and deadband airflows are scheduled for this system. Include a reference to the specification of the zone controls. Provide a MCH-03-E compliance document.
- Enter N/A if there is no electric heating. If the system has electric heating indicate which exception to 140.4(g) applies.
- If duct leakage sealing and testing is required, a MCH-04-A compliance document must be submitted.

CSG CONSULTANTS  
 THESE PLANS AND DETAILS ARE APPROVED  
 THE APPROVAL OF THESE PLANS SHALL NOT BE CONSTRUED TO BE A PERMIT FOR ANY VIOLATION OF ANY CODE OR ORDINANCE.  
 JUN 06 2019  
 BY: \_\_\_\_\_  
 THESE PLANS SHALL BE ON THE JOB FOR ALL REQUESTED INSPECTIONS.

ISSUE DATE  
 XXXX

QUALITY AND INNOVATION IN DESIGN SOLUTIONS  
 10000 W. WARNER AVE., SUITE 100  
 SANTA ANA, CA 92704  
 (714) 261-1111

REGISTERED PROFESSIONAL ENGINEER  
 TONY BUL  
 No. M 28203  
 EXP. 6/30/19  
 MECHANICAL  
 STATE OF CALIFORNIA

PROJECT NO.  
 18E 30043

DRAWN/REVIEWED  
 RJM/TB

DATE/ISSUE  
 TBD

SHEET TITLE  
 MECHANICAL COMPLIANCE FORMS

SHEET NO.  
 MT24.1

STATE OF CALIFORNIA  
**HVAC DRY & WET SYSTEM REQUIREMENTS**  
 CECS-NRCC-MCH-02-E (Revised 01/16) CALIFORNIA ENERGY COMMISSION  
**CERTIFICATE OF COMPLIANCE** NRCC-MCH-02-E  
 HVAC Dry & Wet System Requirements (Page 2 of 3)  
 Project Name: Concentra Date Prepared: 12/18/2018

**B. Equipment Tags and System Description - Wet Systems**  
**MANDATORY MEASURES** T-24 Sections Reference to the Requirements in the Contract Documents  
 Heating Hot Water Equipment Efficiency 110.1  
 Cooling Chilled and Condenser Water Equipment Efficiency 110.1, 140.4(i)  
 Open and Closed Circuit Cooling Towers conductivity or flow based controls 110.2(e) 1  
 Open and Closed Circuit Cooling Towers Maximum Achievable Cycles of Concentration (155) 110.2(e) 2  
 Open and Closed Circuit Cooling Towers Flow Meter with analog output 110.2(e) 3  
 Open and Closed Circuit Cooling Towers Overflow Alarm 110.2(e) 4  
 Open and Closed Circuit Cooling Towers Efficient Draft Eliminators 110.2(e) 5  
 Pipe Insulation 120.3

**PRESCRIPTIVE MEASURES**  
 Cooling Tower Fan Controls 140.4(h)(1), 140.4(h)(5) Y Y/N Y/N Y/N  
 Cooling Tower Flow Controls 140.4(h)(3)  
 Centrifugal Fan Cooling Towers 140.4(h)(4)  
 Air-Cooled Chiller Limitation 140.4(i)  
 Variable Flow System Design 140.4(k)  
 Chiller and Boiler Isolation 140.4(l)  
 CHW and HWHP Reset Controls 140.4(m)  
 WHPH Isolation Valves 140.4(n)  
 VSD on CHW, CW & WHP Pumps >5HP 140.4(o)  
 DP Sensor Location 140.4(p)

Notes:  
 1. Provide equipment tags (e.g. CH 1 to 3) or system description (e.g. CHW loop) as appropriate. Multiple units with common requirements can be grouped together.  
 2. Provide references to plans (i.e. Drawing Sheet Numbers) and/or specifications (including Section name/number and relevant paragraphs) where each requirement is specified. Enter "N/A" if the requirement is not applicable to this system.  
 3. The referenced plans and specifications must include all of the following information: equipment tag, equipment nominal capacity, Title 24 minimum efficiency requirements, and actual rated equipment efficiencies. Where multiple efficiency requirements are applicable (e.g. full and part-load) include all. For chillers operating at non-standard efficiencies provide the kW values. For chillers also note whether the efficiencies are Path A or Path B.  
 4. Identify if cooling towers have propeller fans. If towers use centrifugal fans document which exception is used.  
 5. If air-cooled chillers are used, document which exceptions have been used to comply with 140.4(i) and the total installed design capacity of the air-cooled chillers in the chilled water plant.  
 6. Identify the existence of a completed MCH 06 E when open or closed circuit cooling towers are specified to be installed, otherwise enter "N/A".

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

STATE OF CALIFORNIA  
**HVAC SYSTEM REQUIREMENTS**  
 CECS-NRCC-MCH-02-E (Revised 01/16) CALIFORNIA ENERGY COMMISSION  
**CERTIFICATE OF COMPLIANCE** NRCC-MCH-02-E  
 HVAC Wet System Requirements (Page 3 of 3)  
 Project Name: Concentra Date Prepared: 12/18/2018

**DOCUMENTATION AUTHOR'S DECLARATION STATEMENT**  
 1. I certify that this Certificate of Compliance documentation is accurate and complete.  
 Documentation Author Name: Tony Bui Documentation Author Signature: [Signature]  
 Company: Q3 Engineers Inc. Signature Date: 12/18/2018  
 Address: 17162 Gothard Street CA/EES Certification Identification (if applicable):  
 City/State/Zip: Huntington Beach, CA 92647 Phone: 714-465-5200 x104

**RESPONSIBLE PERSON'S DECLARATION STATEMENT**  
 I certify the following under penalty of perjury, under the laws of the State of California:  
 1. The information provided on this Certificate of Compliance is true and correct.  
 2. I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer).  
 3. The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations.  
 4. The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application.  
 5. I will ensure that a completed signed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy.

Responsible Designer Name: Tony Bui Responsible Designer Signature: [Signature]  
 Company: Q3 Inc. Date Signed: 12/18/2018  
 Address: 17162 Gothard Street License: M28203  
 City/State/Zip: Huntington Beach, CA 92647 Phone: 714-465-5200

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

STATE OF CALIFORNIA  
**MECHANICAL VENTILATION AND REHEAT**  
 CECS-NRCC-MCH-03-E (Revised 05/16) CALIFORNIA ENERGY COMMISSION  
**CERTIFICATE OF COMPLIANCE** NRCC-MCH-03-E  
 Mechanical Ventilation & Reheat (Page 1 of 2)  
 Project Name: Concentra Date Prepared: 12/18/2018

**A. Mechanical Ventilation and Reheat**

ACTUAL DESIGN INFO FROM EQUIPMENT SCHEDULES, ETC.	AREA BASE										OCCUPANCY BASE		MINIMUM	VAV Reheat Primary AT CFM		VAV Downblast Primary AT CFM					
	01	02	03	04	05	06	07	08	09	10	11	12		13	14	15	16	17	18	19	20
Zone 1																					
										1,870	0.15	261	8.4	15.0	140						
															281						
																<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail					
																	<input type="checkbox"/> Pass <input type="checkbox"/> Fail				
																		<input type="checkbox"/> Pass <input type="checkbox"/> Fail			
																			<input type="checkbox"/> Pass <input type="checkbox"/> Fail		
																				<input type="checkbox"/> Pass <input type="checkbox"/> Fail	
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail
																					<input type="checkbox"/> Pass <input type="checkbox"/> Fail



STATE OF CALIFORNIA  
**REQUIRED ACCEPTANCE TESTS**  
 CECS-NRCC-MCH-04-E (Revised 01/16)  
 CALIFORNIA ENERGY COMMISSION  
 NRCC-MCH-04-E  
 Required Acceptance Tests  
 Project Name: Concentra Date Prepared: 12/18/2018 (Page 2 of 3)

**Designer:**  
 This compliance document is to be used by the designer and attached to the plans. Listed below are all the acceptance tests for mechanical systems. The designer is required to check the applicable boxes by all acceptance tests that apply and list all equipment that require an acceptance test. If all equipment of a certain type requires a test, list the equipment description and the number of systems. The NA number designates the Section in the Appendix of the Nonresidential Reference Appendices Manual that describes the test. Since this compliance document will be part of the plans, completion of this section will allow the responsible party to budget for the scope of work appropriately.

**Enforcement Agency:**  
 Systems Acceptance. Before occupancy permit is granted for a newly constructed building or space, or a new space-conditioning system serving a building or space is operated for normal use, all control devices serving the building or space shall be certified as meeting the Acceptance Requirements for Code Compliance.

**Systems Acceptance.** Before occupancy permit is granted. All newly installed HVAC equipment must be tested using the Acceptance Requirements. The NRCC-MCH-04-E compliance document is not considered a completed document and is not to be accepted by the building department unless the correct boxes are checked. The equipment requiring testing, person performing the test (Example: HVAC installer, TAB contractor, controls contractor, PE in charge of project) and what Acceptance test must be submitted to the building department that certifies plans, specifications, installation certificates, and operating and maintenance information meet the requirements of Section 10-100.2(a) and Title 24 Part 6. The building inspector must receive the properly filled out and signed compliance documents before the building can receive final occupancy.

Test Description	MCH-02-A	MCH-03-A	MCH-04-A	MCH-05-A	MCH-06-A	MCH-07-A	MCH-11-A	MCH-12-A	MCH-14-A	MCH-15-A	Test Performed By:
Equipment Requiring or Verification	Outdoor Air	Single Zone Units	Air Distribution Ducts	Economizer Controls	Demand Control Ventilation (DCV)	Supply Fan VAV	Automatic Demand Shed Control	FDD for Packaged DX Units	Distributed Energy Storage DX AC Systems	Energy Management Control System	
Carrier 25 H	1	✓	✓								
Carrier 25 H	1	✓	✓								
Carrier 50 S	1	✓	✓								
Carrier 39 A	1	✓	✓								

STATE OF CALIFORNIA  
**REQUIRED ACCEPTANCE TESTS**  
 CECS-NRCC-MCH-04-E (Revised 01/16)  
 CALIFORNIA ENERGY COMMISSION  
 NRCC-MCH-04-E  
 Required Acceptance Tests  
 Project Name: Concentra Date Prepared: 12/18/2018 (Page 3 of 3)

**DOCUMENTATION AUTHOR'S DECLARATION STATEMENT**  
 1. I certify that this Certificate of Compliance documentation is accurate and complete.  
 Documentation Author Name: Tony Bui  
 Signature Date: 12/18/2018  
 Company: Q3 Engineers Inc.  
 Address: 17162 Gothard Street  
 City/State/Zip: Huntington Beach, CA 92647  
 Phone: 714-465-5200 x104

**RESPONSIBLE PERSON'S DECLARATION STATEMENT**  
 I certify the following under penalty of perjury, under the laws of the State of California:  
 1. The information provided on this Certificate of Compliance is true and correct.  
 2. I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer).  
 3. The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations.  
 4. The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application.  
 5. I will ensure that a completed signed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy.

Responsible Designer Name: Tony Bui  
 Signature Date: 12/18/2018  
 Company: Q3 Inc.  
 Address: 17162 Gothard Street  
 City/State/Zip: Huntington Beach, CA 92647  
 Phone: 714-465-5200

STATE OF CALIFORNIA  
**REQUIREMENTS FOR PACKAGED SINGLE ZONE UNITS**  
 CECS-NRCC-MCH-05-E (Revised 01/16)  
 CALIFORNIA ENERGY COMMISSION  
 NRCC-MCH-05-E  
 Requirements for Packaged Single-Zone Units  
 Project Name: Concentra Date Prepared: 12/18/2018 (Page 1 of 2)

Equipment Tag(s)	T-24 Sections	HP-1 Requirement	As Scheduled	HP-2 Requirement	As Scheduled	RTU-1 Requirement	As Scheduled
Heating Equipment Efficiency	110.1 or 110.2(a)	7.70 HSPF	8.00 HSPF	7.70 HSPF	8.00 HSPF	7.70 HSPF	8.00 HSPF
Cooling Equipment Efficiency	110.1 or 110.2(a)	13 SEER	14.0 SEER	13 SEER	14.0 SEER	13 SEER	14.0 SEER
Thermostats	110.2(b), 110.2(c)	Setback	Setback	Setback	Setback	Setback	Setback
Furnace Standby Loss Control	110.2(d)	N/A	N/A	N/A	N/A	N/A	N/A
Low Leakage AHU Ventilation	120.1(b)	NR	140	NR	113	NR	57
Demand Control Ventilation	120.1(c)	NR	No	NR	No	NR	No
Occupant Sensor Ventilation Control	120.1(c)(5), 120.2(a)(3)	Req	Programmable	Req	Programmable	Req	Programmable
Shutoff and Reset Controls	120.2(f)	Req	Auto	Req	Auto	Req	Auto
Outdoor Air and Exhaust Damper Control	120.2(f)	Req	Auto	Req	Auto	Req	Auto
Automatic Demand Shed Controls	120.2(h)	NR	none	NR	none	NR	none
Economizer FDD	120.2(i)	NR	none	NR	none	NR	none
Duct Insulation	120.4	R-8	R-8.0	R-8	R-8.0	R-8	R-8.0

**PRESCRIPTIVE MEASURES**  
 Equipment is sized in conformance with 140.4(a & b)  
 140.4(a & b) 58,748 Btu/hr 42,227 Btu/hr 41,370 Btu/hr 39,888 Btu/hr 51,717 Btu/hr 42,227 Btu/hr  
 Economizer 140.4(e) NR No Economizer 44,407 Btu/hr 66,941 Btu/hr 44,087 Btu/hr 43,931 Btu/hr  
 Electric Resistance Heating 140.4(f) No No No No No No  
 Duct Leakage Sealing and Testing 140.4(g) NR No NR No NR No

Notes:  
 1. Provide equipment tags (e.g. AC1 or AC1 to 10). Multiple units of the same make and model with the same application and accessories can be grouped together.  
 2. Enter the following information as appropriate: Unit Manufacturer; Unit Model Number (including all accessories); Description of the unit (e.g. gas-pak or heat pump; rated heating capacity (enter "N/A" if no heating); and, rated cooling capacity (enter "N/A" if no cooling). For unit capacities include the units (e.g. kWh or tons).  
 3. For each requirement, enter the minimum requirement from the Standard in the left column (under "Standard Requirement"). In the right column (under "As Scheduled") enter the value for the units as specified.  
 4. Where there is more than one requirement (e.g. full and part load efficiency) enter both with the appropriate labels (e.g. COP and IER).  
 5. In the left column identify the thermostatic requirements from the standard (e.g. programmable setback thermostat or heat pump with electric heat). In the right column indicate the capabilities of the thermostat as scheduled.  
 6. If the unit has a furnace which is rated at >225,000 Btu/h of capacity, indicate the rated standby loss and ignition source (e.g. ID). If there is no furnace or the unit is rated for <225,000 Btu/h indicate "N/A".  
 7. In the left column, enter both the required ventilation value from Table 120.1A and for the number of occupants times 15 cfm/person. In the right column enter the actual minimum ventilation as scheduled. If the space is naturally ventilated enter "N/A" in the left column and "the space is naturally ventilated" in the right column.  
 8. If the space is required to have either DCV or Occupant Sensor Ventilation Control indicate "required" in the left column (otherwise indicate "N/A" in the left column). If either DCV or Occupant Sensor Ventilation Control is provided indicate "provided" in the right column (otherwise indicate "N/A" in the right column).  
 9. In the left column indicate the required time controls from the standard. In the right column identify the device that provides this functionality (e.g. EMS or programmable timeclock).  
 10. Enter N/A if there is no electric heating. If the system has electric heating indicate which exception to 140.4(g) applies.  
 11. If duct leakage sealing and testing is required, a MCH-04-A compliance document must be submitted.

STATE OF CALIFORNIA  
**REQUIREMENTS FOR PACKAGED SINGLE ZONE UNITS**  
 CECS-NRCC-MCH-05-E (Revised 01/16)  
 CALIFORNIA ENERGY COMMISSION  
 NRCC-MCH-05-E  
 Requirements for Packaged Single-Zone Units  
 Project Name: Concentra Date Prepared: 12/18/2018 (Page 1 of 2)

Equipment Tag(s)	T-24 Sections	HP-3 Requirement	As Scheduled	Requirement	As Scheduled	Requirement	As Scheduled
Heating Equipment Efficiency	110.1 or 110.2(a)	4.20 COP	4.20 COP				
Cooling Equipment Efficiency	110.1 or 110.2(a)	12.0 EER	13.0 EER				
Thermostats	110.2(b), 110.2(c)	Setback	Setback				
Furnace Standby Loss Control	110.2(d)	N/A	N/A				
Low Leakage AHU Ventilation	120.1(b)	NR	191				
Demand Control Ventilation	120.1(c)	NR	No				
Occupant Sensor Ventilation Control	120.1(c)(5), 120.2(a)(3)	Req	Programmable				
Shutoff and Reset Controls	120.2(f)	Req	Auto				
Outdoor Air and Exhaust Damper Control	120.2(f)	Req	Auto				
Automatic Demand Shed Controls	120.2(h)	NR	none				
Economizer FDD	120.2(i)	NR	none				
Duct Insulation	120.4	R-8	R-8.0				

**PRESCRIPTIVE MEASURES**  
 Equipment is sized in conformance with 140.4(a & b)  
 140.4(a & b) 52,979 Btu/hr 31,269 Btu/hr  
 Economizer 140.4(e) Req No Economizer 66,523 Btu/hr 59,333 Btu/hr  
 Electric Resistance Heating 140.4(f) No No  
 Duct Leakage Sealing and Testing 140.4(g) NR No

Notes:  
 1. Provide equipment tags (e.g. AC1 or AC1 to 10). Multiple units of the same make and model with the same application and accessories can be grouped together.  
 2. Enter the following information as appropriate: Unit Manufacturer; Unit Model Number (including all accessories); Description of the unit (e.g. gas-pak or heat pump; rated heating capacity (enter "N/A" if no heating); and, rated cooling capacity (enter "N/A" if no cooling). For unit capacities include the units (e.g. kWh or tons).  
 3. For each requirement, enter the minimum requirement from the Standard in the left column (under "Standard Requirement"). In the right column (under "As Scheduled") enter the value for the units as specified.  
 4. Where there is more than one requirement (e.g. full and part load efficiency) enter both with the appropriate labels (e.g. COP and IER).  
 5. In the left column identify the thermostatic requirements from the standard (e.g. programmable setback thermostat or heat pump with electric heat). In the right column indicate the capabilities of the thermostat as scheduled.  
 6. If the unit has a furnace which is rated at >225,000 Btu/h of capacity, indicate the rated standby loss and ignition source (e.g. ID). If there is no furnace or the unit is rated for <225,000 Btu/h indicate "N/A".  
 7. In the left column, enter both the required ventilation value from Table 120.1A and for the number of occupants times 15 cfm/person. In the right column enter the actual minimum ventilation as scheduled. If the space is naturally ventilated enter "N/A" in the left column and "the space is naturally ventilated" in the right column.  
 8. If the space is required to have either DCV or Occupant Sensor Ventilation Control indicate "required" in the left column (otherwise indicate "N/A" in the left column). If either DCV or Occupant Sensor Ventilation Control is provided indicate "provided" in the right column (otherwise indicate "N/A" in the right column).  
 9. In the left column indicate the required time controls from the standard. In the right column identify the device that provides this functionality (e.g. EMS or programmable timeclock).  
 10. Enter N/A if there is no electric heating. If the system has electric heating indicate which exception to 140.4(g) applies.  
 11. If duct leakage sealing and testing is required, a MCH-04-A compliance document must be submitted.

STATE OF CALIFORNIA  
**REQUIREMENTS FOR PACKAGED SINGLE ZONE UNITS**  
 CECS-NRCC-MCH-05-E (Revised 01/16)  
 CALIFORNIA ENERGY COMMISSION  
 NRCC-MCH-05-E  
 Requirements for Packaged Single-Zone Units  
 Project Name: Concentra Date Prepared: 12/18/2018 (Page 2 of 2)


**DOCUMENTATION AUTHOR'S DECLARATION STATEMENT**  
 1. I certify that this Certificate of Compliance documentation is accurate and complete.  
 Documentation Author Name: Tony Bui  
 Signature Date: 12/18/2018  
 Company: Q3 Engineers Inc.  
 Address: 17162 Gothard Street  
 City/State/Zip: Huntington Beach, CA 92647  
 Phone: 714-465-5200 x104

**RESPONSIBLE PERSON'S DECLARATION STATEMENT**  
 I certify the following under penalty of perjury, under the laws of the State of California:  
 1. The information provided on this Certificate of Compliance is true and correct.  
 2. I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer).  
 3. The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations.  
 4. The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application.  
 5. I will ensure that a completed signed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy.

Responsible Designer Name: Tony Bui  
 Signature Date: 12/18/2018  
 Company: Q3 Inc.  
 Address: 17162 Gothard Street  
 City/State/Zip: Huntington Beach, CA 92647  
 Phone: 714-465-5200

**ZONE LOAD SUMMARY**  
 Project Name: Concentra Date: 12/18/2018  
 System Name: HP-1 Floor Area: 1,870

ZONE NAME	SYSTEM NAME	Mult.	ZONAL SYSTEM				COOLING PEAK				HEATING PEAK						
			CFM	Sensible	Latent	Heating	OA CFM	Peak kW	CFM	Sensible	Latent	CFM	Sensible				
Zone 1		1.0															
			TOTALS	0	0	0	140	Jun 2 PM	42.947	2,865			38,357				



CONCENTRA  
 3100 W. WARNER AVE, SUITE 100  
 SANTA ANA, CA 92704

PROJECT NO.  
18E 30043

DRAWN/REVIEWED  
RJM/TB

DATE/ISSUE  
TBD

DATE/ISSUE  
TBD

SHEET TITLE  
MECHANICAL COMPLIANCE FORMS

SHEET TITLE  
MECHANICAL COMPLIANCE FORMS

SHEET NO.  
MT24.3

SHEET NO.  
MT24.3

CSG CONSULTANTS  
 THESE PLANS AND DETAILS ARE APPROVED  
 THE APPROVAL OF THESE PLANS SHALL NOT BE CONSTRUED TO BE A PERMIT FOR ANY VIOLATION OF ANY CODE OR ORDINANCE  
 JUN 06 2019  
 BY: [Signature]  
 THESE PLANS SHALL BE ON THE JOB FOR ALL REQUESTED INSPECTIONS.



**ZONE LOAD SUMMARY**

Project Name: **Concentra** Date: **12/18/2018**  
 System Name: **HP-2** Floor Area: **582**

ZONE NAME	SYSTEM NAME	ZONAL SYSTEM					COOLING PEAK				HEATING PEAK		
		Mult.	CFM	Sensible	Latent	Heating	OA CFM	Peak Hr	CFM	Sensible	Latent	CFM	Sensible
Zone 2		1.0					44	Jul 5 PM	3,165	47,659	582	490	28,237
<b>TOTALS</b>		0	0	0	0	44	Jul 5 PM	47,659	582	490	28,237		

EnergyPro 7.1 by EnergySoft User Number: 30164 ID: 18E 30046 (BLOCK LOAD) Page 19 of 21

**ZONE LOAD SUMMARY**

Project Name: **Concentra** Date: **12/18/2018**  
 System Name: **RTU-1** Floor Area: **756**

ZONE NAME	SYSTEM NAME	ZONAL SYSTEM					COOLING PEAK				HEATING PEAK		
		Mult.	CFM	Sensible	Latent	Heating	OA CFM	Peak Hr	CFM	Sensible	Latent	CFM	Sensible
Zone 3		1.0					37	Jun 2 PM	1,481	30,496	1,132	849	35,897
<b>TOTALS</b>		0	0	0	0	37	Jun 2 PM	30,496	1,132	849	35,897		

EnergyPro 7.1 by EnergySoft User Number: 30164 ID: 18E 30046 (BLOCK LOAD) Page 20 of 21

**ZONE LOAD SUMMARY**

Project Name: **Concentra** Date: **12/18/2018**  
 System Name: **HP-3** Floor Area: **2,550**

ZONE NAME	SYSTEM NAME	ZONAL SYSTEM					COOLING PEAK				HEATING PEAK		
		Mult.	CFM	Sensible	Latent	Heating	OA CFM	Peak Hr	CFM	Sensible	Latent	CFM	Sensible
Zone 4		1.0					191	Jun 2 PM	2,312	48,230	3,938	719	35,828
<b>TOTALS</b>		0	0	0	0	191	Jun 2 PM	48,230	3,938	719	35,828		

EnergyPro 7.1 by EnergySoft User Number: 30164 ID: 18E 30046 (BLOCK LOAD) Page 21 of 21



CSG CONSULTANTS  
 THESE PLANS AND DETAILS ARE  
**APPROVED**  
 THE APPROVAL OF THESE PLANS SHALL NOT  
 BE CONSIDERED TO BE A PERMIT FOR ANY  
 VIOLATION OF ANY CODE OR ORDINANCE

JUN 06 2019

BY: *[Signature]*  
 THESE PLANS SHALL BE ON THE JOB  
 FOR ALL REQUESTED INSPECTIONS.

ISSUE DATE

XXXX



CONCENTRA  
 3100 W, WARNER AVE, SUITE 100  
 SANTA ANA, CA 92704

PROJECT NO.  
18E 30043

DRAWN/REVIEWED  
RJM/TB

DATE/ISSUE  
TBD

SHEET TITLE  
MECHANICAL  
COMPLIANCE  
FORMS

SHEET NO.  
MT24.4



## GENERAL NOTES

1. BEFORE COMMENCEMENT OF WORK, THE CONTRACTOR SHALL VERIFY THE EXACT LOCATIONS, ELEVATIONS AND CHARACTERISTICS OF ALL UTILITIES AND PIPING, AND SHALL IMMEDIATELY NOTIFY THE ARCHITECT OF ANY DISCREPANCIES.
2. EXACT LOCATIONS AND MOUNTING HEIGHTS OF PLUMBING FIXTURES SHALL BE OBTAINED FROM THE ARCHITECTURAL DRAWINGS.
3. SEE ARCHITECTURAL DRAWINGS FOR HANDICAP FIXTURE LOCATIONS AND MOUNTING HEIGHTS. INSULATE ALL EXPOSED WATER AND DRAIN PIPING BELOW LAVATORIES AND SINKS WITH TUBERO LAVOARD 2 INSULATION KIT AND OFFSET P-TRAP TO WALL. ALL WATER CLOSET FLUSHING LEVERS SHALL BE TO THE WIDE SIDE OF THE STALL.
4. ALL PLUMBING WORK SHALL BE INSTALLED SO AS TO AVOID INTERFERENCE WITH ELECTRICAL AND MECHANICAL EQUIPMENT AND STRUCTURAL FRAMING.
5. ALL VALVES, UNIONS, ETC. TO BE SAME SIZE AS PIPE UNLESS OTHERWISE INDICATED ON DRAWINGS.
6. UNIONS SHALL BE PROVIDED AND INSTALLED AFTER EACH SCREW-TYPE VALVE AND PRIOR TO EQUIPMENT CONNECTIONS.
7. TRAPS FOR ALL LAVATORIES AND SINKS SHALL TRAP STRAIGHT BACK TO WALL WITH ALL REQUIRED OFFSETS HAPPENING WITHIN THE WALL.
8. ALL WORK AND MATERIAL SHALL BE PERFORMED AND INSTALLED IN COMPLIANCE WITH THE FOLLOWING CODES AS ADOPTED AND AMENDED BY THE INSPECTING AUTHORITY. NOTHING IN THESE DRAWINGS IS TO BE CONSTRUED TO PERMIT WORK NOT CONFORMING TO THESE CODES OR OTHERS APPLICABLE TO THIS PROJECT:  
 2016 CALIFORNIA BUILDING CODE  
 2016 CALIFORNIA MECHANICAL CODE  
 2016 CALIFORNIA PLUMBING CODE  
 2016 CALIFORNIA ELECTRICAL CODE  
 2016 CALIFORNIA ENERGY CODE  
 CITY OF SANTA ANA MUNICIPAL CODE
9. BEFORE FABRICATION OR INSTALLATION THIS CONTRACTOR SHALL VERIFY EXACT LOCATIONS OF ALL MECHANICAL EQUIPMENT AND EQUIPMENT PROVIDED UNDER ANOTHER SECTION OF SPECIFICATIONS. EXACT ROUGH-IN LOCATIONS AND REQUIREMENTS SHALL BE COORDINATED IN FIELD.
10. ALL UNDERGROUND IRON, COPPER OR STEEL PIPING LOCATED BOTH INSIDE AND OUTSIDE OF BUILDING SHALL BE ENCASED WITH A MINIMUM 10 MIL. POLYETHYLENE PLASTIC SLEEVE SEALED WATER TIGHT WITH POLYVINYL CHLORIDE TAPE.
11. HOT WATER HEATERS SHALL BE INSULATED TO A MINIMUM THERMAL RESISTANCE VALUE OF R-6 OR GREATER.
12. ALL POINTS OF CONNECTION SHALL BE COORDINATED WITH THE GENERAL CONTRACTOR PRIOR TO BID.
13. ALL WASTE AND VENT PIPING SHALL SLOPE AT 2% UNLESS OTHERWISE INDICATED.
14. ALL VALVES, TRAP PRIMER, WATER HAMMER ARRESTERS OR OTHER EQUIPMENT SHOWN IN WALLS OR ABOVE NON-ACCESSIBLE CEILINGS SHALL BE INSTALLED BEHIND AN ACCESS PANEL.
15. THESE DRAWINGS SHALL BE READ IN CONJUNCTION WITH AND BE CONSIDERED TO BE A PART OF SEPARATE AND COMPLETE MECHANICAL SPECIFICATIONS.
16. THE CONTRACTOR SHALL BE RESPONSIBLE FOR PATCHING AND REPAIRING ALL PAVED AREAS WHICH ARE EXCAVATED AND/OR DAMAGED BY HIS OPERATIONS. IN ADDITION, THE CONTRACTOR SHALL RESTORE TO THEIR ORIGINAL CONDITION ALL PLANTED AREAS DAMAGED BY HIS OPERATIONS.
17. ALL PATCHING AND REPAIRING OF CONCRETE PAVINGS AND/OR WALKS SHALL BE UNDER ANOTHER SECTION OF THE SPECIFICATIONS.
18. ALL CONNECTIONS TO EXISTING SERVICES SHALL BE MADE SUCH THAT INTERRUPTION TIME WILL BE AS SHORT AS POSSIBLE. THE CONTRACTOR SHALL GIVE THE OWNER'S REPRESENTATIVE SUFFICIENT NOTICE OF SUCH INTERRUPTION AND THE ACTUAL SHUT DOWN TIME SHALL BE AT A TIME DESIGNATED BY THE OWNER'S REPRESENTATIVE.
19. ALL EXISTING PIPING DAMAGED DURING EXCAVATION SHALL BE REPAIRED WITH MATERIALS TO MATCH EXISTING BY THE CONTRACTOR.
20. ALL EXISTING PIPING AND EQUIPMENT THAT IS REMOVED SHALL BE DISPOSED OF AS DIRECTED BY THE OWNER'S REPRESENTATIVE.
21. ALL CUTTING OF EXISTING PAVINGS, WALKS AND/OR FLOORS SHALL BE BY MACHINE SAW CUTTING. HOLES FOR PIPES IN CONCRETE WALLS OR FLOORS SHALL BE DONE BY CORE DRILLING EQUIPMENT.
22. CAP AND ABANDON ALL EXISTING WASTE PIPING BELOW FLOOR EXCEPT INDICATED TO BE REUSED. ROUTER AND CLEAN ALL EXISTING WASTE PIPING TO BE REUSED.
23. EXISTING PIPING ABOVE CEILING AND IN EXISTING WALLS BEING DEMOLISHED, THAT IS NOT BEING REUSED, SHALL BE REMOVED. COORDINATE EXTENT OF DEMOLITION WITH THE ARCHITECT AND THE GENERAL CONTRACTOR.
24. ALL HOT WATER PIPING SHALL BE INSULATED IN ACCORDANCE WITH SECTION 123, TABLE 1-G OF THE TITLE 24 REGULATIONS.
25. ALL PLUMBING FIXTURE VENTS TO TERMINATE A MIN. OF 12 INCHES FROM ANY VERTICAL SURFACE AND 10 FEET FROM ANY OUTSIDE AIR INTAKES.
26. ALL CLEANOUTS SHALL BE INSTALLED WHERE READILY ACCESSIBLE. THE CONTR SHALL COORDINATE ALL CLEANOUT LOCATIONS WITH EQUIPMENT, CABINETS, ETC., AND THE ARCHITECT PRIOR TO ANY INSTALLATION.
27. ALL PLUMBING FIXTURES AND EQUIPMENT SHALL BE CERTIFIED BY THE CALIFORNIA STATE ENERGY COMMISSION TO COMPLY WITH EFFICIENCY STANDARDS PER SECTION 2-5314(A) OF THE TITLE-24 REGULATIONS.
28. ALL PIPING INTO STEM WALLS AND FOOTINGS SHALL BE DOUBLE HALF LAP WRAPPED WITH 1/8" THICK "ARMOFLEX" INSULATION. THE CONTRACTOR SHALL ALSO PROVIDE BLOCKED OUT AREAS IN STEM WALL AND FOOTING. ALL PIPING SHALL AVOID THE LOWER 8" OF THE FOOTING.
29. SEISMIC BRACING AND ANCHORAGE REQUIREMENTS ARE AS FOLLOWS:  
 A) ALL MECHANICAL EQUIPMENT SHALL BE BRACED OR ANCHORED TO RESIST A HORIZONTAL FORCE ACTING IN ANY DIRECTION USING THE FOLLOWING CRITERIA:  
 1. FIXED EQUIP. ON GRADE 20% OF OPERATING WEIGHT  
 FIXED EQUIP. ON STRUCTURE 30% OF OPERATING WEIGHT  
 2. FOR FLEXIBLY MOUNTED EQUIPMENT USE 4 X THE ABOVE VALUES.  
 SIMULTANEOUS VERTICAL FORCE - USE 1/3 X HORIZONTAL FORCE.  
 3. FOR I = 1.15 INCREASE THE ABOVE VALUES BY 15%.  
 B) WHERE ANCHORAGE DETAILS ARE NOT SHOWN ON THE DRAWINGS, THE FIELD INSTALLATION SHALL BE SUBJECT TO THE APPROVAL OF THE MECHANICAL ENGINEER AND THE FIELD REPRESENTATIVE OF THE LOCAL AUTHORITY HAVING JURISDICTION.  
 C) THE SEISMIC BRACING AND ANCHORAGE OF PIPING AND EQUIPMENT SHALL BE IN ACCORDANCE WITH THE REQUIREMENTS OF THE "GUIDE-LINES FOR SEISMIC RESTRAINTS OF MECHANICAL SYSTEMS AND PLUMBING SYSTEMS" PUBLISHED BY SMACNA AND APPROVED BY THE LOCAL AUTHORITY HAVING JURISDICTION.
30. ALL BRACING OF PIPING SHALL BE INSTALLED IN ACCORDANCE WITH SMACNA GUIDELINES AS APPROVED BY LOCAL AUTHORITY HAVING JURISDICTION.
31. WHERE BRACING DETAILS ARE NOT SHOWN ON THE DRAWINGS OR IN THE GUIDELINES, THE FIELD INSTALLATION SHALL BE SUBJECT TO THE APPROVAL OF THE ARCHITECT, MECHANICAL ENGINEER AND THE LOCAL AUTHORITY HAVING JURISDICTION.
32. A COPY OF THE GUIDELINES PUBLISHED BY SMACNA AND APPROVED BY LOCAL AUTHORITY SHALL BE PROVIDED BY THE CONTRACTOR AND KEPT ON THE JOB AT ALL TIMES.
33. ALL REQUIRED CLEANOUTS SHALL BE INSTALLED AS PER SECTION 707.0 AND 719.0 OF THE CALIFORNIA PLUMBING CODE.
34. ALL HOSE BIBBS SHALL BE EQUIPPED WITH AN APPROVED NON-REMOVABLE VACUUM BREAKER.
35. NEW OR REPAIRED POTABLE WATER SYSTEMS SHALL BE DISINFECTED PRIOR TO USE ACCORDING TO THE METHOD SET IN SECTION 609.9 OF THE CALIFORNIA PLUMBING CODE.
36. ACCESSIBLE WATER HAMMER ARRESTERS SHALL BE INSTALLED FOR QUICK-ACTING VALVES. LOCATION AND METHOD OF INSTALLATION SHALL COMPLY WITH THE MANUFACTURER'S RECOMMENDATION.
37. DIELECTRIC UNIONS SHALL BE USED AT ALL POINTS OF CONNECTION WHERE THERE IS A DISSIMILARITY OF METALS.
38. THESE DRAWINGS ARE DIAGRAMMATIC TO THE EXTENT THAT BRANCHES, SIZING, AND GENERAL ROUTING ARE SHOWN AS REQUIRED FOR PROPER SIZING AND FUNCTION OF PIPING SYSTEMS. PIPING LAYOUT IS INDICATED IN A MANNER TO PROVIDE CLARITY OF SIZING AND CONFIGURATION, AND IS NOT INTENDED TO PORTRAY ACTUAL INSTALLED CONDITIONS. NOT ALL VALVES, FITTINGS, PIPING SPECIALTIES AND COMPONENTS ARE SHOWN. CONTRACTOR MAY MAKE MINOR VARIATIONS TO ROUTING SHOWN AS REQUIRED FOR PROPER INTERFACE WITH STRUCTURE AND IN COORDINATION WITH OTHER TRADES PROVIDED THAT DIAGRAMMATIC CONFIGURATION IS ADHERED TO, INCLUDING BRANCH AND MAIN PIPE SIZES AND ORDER OF CONNECTION TO PLUMBING FIXTURES AND OUTLETS. ALL PIPING SHALL BE INSTALLED WITHIN CONCEALED LOCATIONS UNLESS NOTED OTHERWISE.

## LEGEND

SYMBOL	ABBREVIATION	DESCRIPTION
— S OR W —	S OR W	SOIL OR WASTE (ABOVE GRADE)
— S OR W —	S OR W	SOIL OR WASTE (BELOW GRADE)
— (E)W —	(E)W	EXISTING SOIL OR WASTE
— IW —	IW	INDUSTRIAL WASTE
— GW —	GW	GREASE WASTE
— V —	V	SANITARY VENT
— (E)V —	(E)V	EXISTING SANITARY VENT
— CD —	CD	CONDENSATE DRAIN
— CW —	CW	COLD WATER
— (E)CW —	(E)CW	EXISTING COLD WATER
— HW —	HW	HOT WATER
— (E)HW —	(E)HW	EXISTING HOT WATER
— FCO —	FCO	FLOOR CLEANOUT
— WCO —	WCO	WALL CLEANOUT
— BV —	BV	BALL VALVE
— GV —	GV	GATE VALVE
— CV —	CV	CHECK VALVE
— GC —	GC	GAS COCK
— VTR —	VTR	VENT THRU ROOF
— POC —	POC	POINT OF DISCONNECTION/CONNECTION
— (E) —	(E)	EXISTING TO BE REMOVED
— FSR —	FSR	FIRE SPRINKLER RISER
— I.E. —	I.E.	INVERT ELEVATION

## SHEET INDEX

SHEET NO.	DESCRIPTION
P-0.0	PLUMBING GENERAL NOTES, LEGEND, SCOPE OF WORK, AND PIPE SCHEDULE.
P-0.1	PLUMBING WATER PRESSURE CALCULATION AND FIXTURE SCHEDULE.
P-1.0	PLUMBING SW & V PIPING PLAN
P-1.1	PLUMBING SW & V DIAGRAM PLAN
P-2.0	PLUMBING CW & HW PIPING PLAN
P-2.1	PLUMBING CW & HW DIAGRAM
PT24-1	PLUMBING TITLE 24

## PLUMBING RENOVATION NOTES:

1. RENOVATION WORK BY DEMOLISHING SOME PLUMBING FIXTURES (REFER TO ARCH DWG A-1.0. REPLACE PLUMBING FIXTURES.
2. RECONNECT NEW 4" SW TO REPLACED WATER CLOSETS. EXTEND 4" SW & 2" V FOR NEW WATER CLOSET.
3. RECONNECT NEW 2" SW TO REPLACED LAVATORIES. EXTEND 2" SW & 1 1/2" V FOR NEW FIXTURES AS REQUIRED.
4. RECONNECT NEW 2" SW TO REPLACED SERVICE SINKS. EXTEND 2" SW & 1 1/2" V FOR NEW FIXTURES AS REQUIRED.
5. RECONNECT NEW 2" SW TO REPLACED KITCHEN SINKS IN BREAK ROOM. EXTEND 2" SW & 1 1/2" V FOR NEW FIXTURES AS REQUIRED.
6. CONNECT NEW 3/4" CW & HW TO NEW WATER HEATER.
7. EXTEND 1" HW TO PLUMBING FIXTURES.
8. KEEP 4" SW AT SLOPE 2%.
9. NO CHANGE TO EXISTING CONDENSATE LINES CONNECT TO EXISTING HVAC UNIT.

## PIPE SCHEDULE

SEE GENERAL NOTES FOR ADDITIONAL REQUIREMENTS

SERVICE	LOCATION	MATERIAL
DOMESTIC WATER	COLD WATER	TYPE "L" COPPER TUBING W/ WROUGHT COPPER SWEAT FITTINGS
	HOT WATER	SAME AS ABOVE W/ 1" THICK MANVILLE MICRO-LOCK INSULATION
SANITARY WASTE	ABOVE FLOOR	NO-HUB CAST IRON W/ "TYLER" WIDE BODY S.S. COUPLINGS
	BELOW FLOOR	SOH 40, ABS COMPLY WITH ASTM 2321-88
SANITARY VENT	CONCEALED	NO-HUB CAST IRON W/ "TYLER" 2-BAND S.S. COUPLINGS
	EXPOSED	NO-HUB CAST IRON W/ "TYLER" 2-BAND S.S. COUPLINGS
CONDENSATE DRAIN	ABOVE FLOOR	TYPE "M" COPPER TUBING W/ WROUGHT COPPER SWEAT FITTINGS

CSG CONSULTANTS  
 THESE PLANS AND DETAILS ARE  
**APPROVED**  
 THE APPROVAL OF THESE PLANS SHALL NOT  
 BE CONSTRUED TO BE A PERMIT FOR ANY  
 VIOLATION OF ANY CODE OR ORDINANCE

JUL 02 2019

BY: *[Signature]*  
 THESE PLANS SHALL BE ON THE JOB  
 FOR ALL REQUESTED INSPECTIONS.


30140437

DESIGNER	DATE	NO.	REV.	BY
CONTR. TYPE				
CODE EDITION				
FLOOD ZONE				
FLOOD ZONE CALL OUT				

RECEIVED  
 JUN 26 2019  
 CSG CONSULTANTS INC

ISSUE	DATE
1. PC CMT	4/24/19
2. PC CMT	6/14/19

QUALITY AND RELIANCE  
 DESIGN SOLUTIONS  
 10000 BRIDGE BLVD  
 SUITE 100  
 SANTA ANA, CA 92705  
 PHONE: 714.241.1111  
 FAX: 714.241.1112



**RECEIVED**  
 PROJECT NO. 18E 30046  
 3100 W. WARNER AVE., SUITE 100  
 JUN 25 2019  
 SANTA ANA, CA 92705  
 of Santa Ana

PROJECT NO. 18E 30046
DRAWN/REVIEWED RJM/TB
DATE/ISSUE TBD
SHEET TITLE PLUMBING GENERAL NOTES & LEGENDS
SHEET NO. <b>P-0.0</b>

30140437 Rck

WATER PIPE SIZING CALCULATION	
JOB NAME : US HEALTHWORKS MEDICAL GROUP	
ADDRESS : 3100 W. WARNER AVE., SANTA ANA, CA 92704	
DATE : 1/23/2018	
PRESSURE AVAILABLE:	
MINIMUM = 85 P.S.I.	METER SIZE = 1 1/2 INCHES
MAXIMUM = 90 P.S.I.	PRV SETTING = 75 P.S.I.
	MAX. VELOCITY = 8 F.P.S.
A) PRESSURE LOSS FROM WATER METER TO BUILDING:	
1. METER LOSS	4 P.S.I.
2. PRESSURE LOSS THRU BACKFLOW DEVICE:	6 P.S.I.
3. STATIC HEIGHT: 10 FT. x 0.43	4.3 P.S.I.
4.	-- P.S.I.
5.	-- P.S.I.
6. TOTAL LOSSES: (ADD #1 THRU #5)	14.30 P.S.I.
B) PRESSURE LOSSES IN BUILDING:	
1. STATIC LOSS 15 FT. X 0.43	6.5 P.S.I.
2. PRESSURE REQUIRED AT FARTHEST FIXTURE	30.0 P.S.I.
3. OTHER LOSSES	-- P.S.I.
4. TOTAL LOSSES	36.5 P.S.I.
C) UNIFORM FRICTION LOSS CALCULATION	
1. TOTAL PRESSURE LOSS (A6 + B4)	50.82 P.S.I.
2. PRESSURE AVAILABLE FOR FRICTION = (MIN. PRESS. - C1)	29.18 P.S.I.
3. DEVELOPED LENGTH OF SYSTEM	250 FT.
4. EQUIVALENT LENGTH OF SYSTEM = (C3 x 1.3)	325 FT.
5. UNIFORM FRICTION HEAD LOSS = (C2 x 100)/C4	8.9 P.S.I./100 FT.

PIPE SIZE	1/2"	3/4"	1"	1 1/4"	1 1/2"	2"	2 1/2"	3"
GPM	--	--	--	30	44	77	118	--
FT (FU)	3	10	24	54	103	254	455	--
FV (FU)	0	0	0	13	35	132	329	--
HW (5F/S)	3	8	16	28	46	119	--	--

- NOTES:
- SAN. WASTE WILL BE CONNECTED TO (1) EXISTING 4" & (1) 6" SW UNDERGROUND
  - EXISTING CW SUPPLIED TO BUILDING BY 1 1/2" WATER METER
  - HOT WATER SUPPLY IN THE BUILDING BY ELECTRICAL WATER HEATER

#### PIPES TESTING PARAMETERS

**WASTE AND VENT PIPE:**  
EACH SECTION SHALL BE FILLED WITH WATER, BUT NO SECTION SHALL BE TESTED WITH LESS THAN 10 FEET HEAD OF WATER. THE WATER SHALL BE KEPT IN THE SYSTEM, OR IN THE PORTION UNDER TEST, FOR NOT LESS THAN 15 MINUTES BEFORE INSPECTION STARTS.

**WATER PIPE:**  
UPON COMPLETION OF A SECTION OR OF THE ENTIRE HOT AND COLD WATER SUPPLY SYSTEM, IT SHALL BE TESTED AND PROVIDE TIGHT UNDER WATER PRESSURE NOT LESS THAN THE WORKING PRESSURE UNDER WHICH IT IS TO BE USED. THE WATER USE FOR TEST SHALL BE OBTAINED FROM A POTABLE SOURCE OF SUPPLY. EXCEPT FOR PLASTIC PIPING, A 50 LBS AIR PRESSURE SHALL BE PERMITTED TO BE SUBSTITUTED TO THE WATER TEST. IN EITHER METHOD OF TEST, THE PIPING SHALL WITHSTAND THE TEST WITHOUT LEAKING FOR A PERIOD OF NOT LESS THAN 15 MINUTES. (CPC 609.4)

PLUMBING SCHEDULES							DESCRIPTION
ITEM	FIXTURE	CW	HW	W	TRAP	VENT	
WC-1	WATER CLOSET	1"	--	4"	INTER.	2"	KOHLER MODEL K-4199 FLOOR MOUNTED ELONGATED, COMFORT HEIGHT, VITREOUS CHINA WHITE, 1 1/2" INLET SPUD, POLISHED CHROME TRIP LEVER, CLASS FIVE FLUSHING SYSTEM, 1.28 GPF COMPLY TO CAL GREEN CODE SECTION 5.303.2.3
WC-2	WATER CLOSET	1 1/2"	--	4"	INTER.	2"	AMERICAN STANDARD MODEL MADERA FLOWISE DUAL FLUSH, VITREOUS CHINA WHITE, 1 1/2" INLET SPUD, WITH TOUCHLESS FLUSHVALVE KOHLER MODEL K-10674-SV-CP/WAVE DC 1.5 V, AA BATTERIES, 1.28 GPF. $\Delta$ COMPLY TO CAL GREEN CODE SECTION 5.303.2.3
LV-1	LAVATORY	1/2"	1/2"	2"	1 1/2"	1 1/2"	AMERICAN STANDARD "COMRADE" #0124-024 ADA COMPLY, LAVATORY WITH CENTER FAUCET HOLE, WHITE VITREOUS CHINA, FRONT OVERFLOW W/ CHICAGO HYTRONIC GOOSENECK SINK FAUCET DUAL BEAM INFRARED SENSOR MODEL $\Delta$ 116.123.AB.1. 0.5 GPM AT 60 PSI. COMPLY TO CAL GREEN CODE SECTION 5.303.2.3
SS-1	SINK SERVICE	3/4"	3/4"	2"	1 1/2"	2"	ELKAY #LRAD191865PD, SINGLE BOWL, 18 GAUGE SS SELF RIMMING 19X18X6.5 DEEP, TOP MOUNT SINK WITH PERFECT DRAIN, CHICAGO FAUCET HYTRONIC GOOSE NECK W/ DUAL BEAM INFRARED SENSOR MODEL 116.123.AB.1. CONTROL 1.8 GPM. PER CAL GREEN CODE SECTION 5.303.2.3
SS-2	SINK (BREAK ROOM)	3/4"	3/4"	2"	1 1/2"	2"	ELKAY LUSTERTONE S.S., EQUAL TO DOUBLE BOWL #LRAD0292265, 3 HOLES PUNCHE, 18 GAUGE SS SELF RIMMING 29X22X6.5 DEEP. DELTA CLASSIC FAUCET #300 SINGLE HANDLE, DECK MOUNT FAUCET WITH INTEGRAL SPRAY. COMPLY TO CAL GREEN CODE SECTION 5.303.2.3. 0.5 GPM AT 60 PSI. $\Delta$
MS-1	MOP SINK	3/4"	3/4"	2"	1 1/2"	2"	MOP SINK, FLORESTONE, MODEL 2424, MOLDED MOP RECEPTOR 24X24X10 WITH INTEGRAL DRAIN, S.S DRAIN GRID AND CHROME STRAINER. UTILITY FAUCET BY FIAT PRODUCTS MODEL 830-AA, EXPOSED YOKE WALL MOUNT UTILITY FAUCET 8" CENTER W/ VACUUM BREAKERWALL BRACE, INTEGRAL STOPS & PAIL HOOK, CHROME FINISH W/ OPTIONAL #889-CC, WALL MOUNT 24" W/ MOP BRACKET. 11.2 GPM AT 60 PSI. $\Delta$
WH-1	HOT WATER HEATER	1"	1"	--	--	--	A.O. SMITH 40 GAL TANK MODEL DEL-40D-4, 4000W DUAL ELEMENTS, RECOVERY 22 GPH AT 70°F RISE, CIRCULATION PUMP, TEMP. PRESSURE RELIEF VENT, SEISMIC STRAP, WITH P&T DRAIN TO NEAREST FLOOR SINK/RECEPTOR & VACUUM BREAKER
EI-1	EXPANSION TANK	--	--	--	--	--	AMTROL THERM-X-TROL ST-5, 13 LBS, 8" DIA. X 13 HT., VOLUME 2 GAL. MAX OPERATING 200°F, PRESS. 150 PSI
TP-1	TRAP PRIMER	1/2"	--	--	--	--	PRECISION PLUMBING PRODUCTS, PR-500, 1/2" CW PIPE TO FLOOR DRAIN, WITH DISTRIBUTION UNIT AS REQUIRED.
ED-1	FLOOR DRAIN	--	--	2"	2"	2"	JR SMITH 2005-P, POLISH NICKEL BRONZE COVER WITH TRAP PRIMER CONNECTION
TP-1	TRAP PRIMER	1/2"	--	--	--	--	PRECISION PLUMBING PRODUCTS, PR-500, 1/2" CW PIPE TO FLOOR DRAIN, WITH DISTRIBUTION UNIT AS REQUIRED.

- NOTES:
- SHOWER AND TUB SHOWER COMBINATIONS SHALL BE PROVIDED WITH INDIVIDUAL CONTROL VALVES OF THE PRESSURE BALANCE, THERMOSTATIC OR COMBINATION PRESSURE BALANCE/THERMOSTATIC MIXING VALVE TYPE. HANDLE POSITION STOPS SHALL BE ADJUSTED TO DELIVER A MAXIMUM MIXED WATER SETTING OF 120°F WITH A DEVICE THAT CONFORMS TO ASSE 1016

- NOTES:
- PER CPC 407.3 REQUIREMENT CONTRACTOR TO PROVIDE & INSTALL CONTROLS TO LIMIT THE WATER TEMPERATURE TO 120°F FOR ALL FAUCETS LV-1.

PLUMBING FIXTURES CALC.								
ITEM	MARK	TYPE (RESIDENCE)	FIXTURE PER RM.	DRAIN FIXT. UNIT (DFU)	DFU	CW FIXT. UNIT (CWFU)	CWFU	HWFU
1	WC-1	WATER CLOSET	4	3	12	2.5	10	
1	WC-2	WATER CLOSET	1	6	6	10	10	
2	LV-1	LAVATORY	3	1	3	1	3	2.25
3	SS-1	SERVICE SINK	5	2	10	2	10	7.5
4	KS-1	KITCHEN SINK	1	2	2	3	3	2.25
5	MS-1	MOP SINK	1	2	2	2	2	1.5
TOTAL :					35		38	14

38 CWFU = 42 GPM FLUSH VALVE



- NOTE:
- SAN. WASTE WILL BE CONNECTED TO (1) EXISTING 4" SW UNDERGROUND
  - EXISTING CW SUPPLIED TO BUILDING BY 1 1/2" WATER METER

MOP SINK FLOW RATE	
PRESSURE (PSI)	FLOW RATE (GPM)
20	6.1
40	8.9
60	11.2
80	13.1

CSG CONSULTANTS  
THESE PLANS AND DETAILS ARE APPROVED  
THE APPROVAL OF THESE PLANS SHALL NOT BE CONSTRUED TO BE A PERMIT FOR ANY VIOLATION OF ANY CODE OR ORDINANCE  
JUL 02 2019

BY: *[Signature]*  
THESE PLANS SHALL BE ON THE JOB FOR ALL REQUESTED INSPECTIONS.

ISSUE	DATE
1. PC CMT	4/24/19
2. PC CMT	6/14/19



CONCENTRA  
3100 W. WARNER AVE., SUITE 100  
SANTA ANA, CA 92704

PROJECT NO.  
18E 30046


DRAWN/REVIEWED  
RJM/TB

DATE/ISSUE  
TBD


SHEET TITLE  
PLUMBING  
SCHEDULES &  
CALCULATION

SHEET NO.  
P-0.1





PLUMBING - SW & V PIPING PLAN  
 SCALE: 1/4" = 1'-0"





KEYED NOTES

- ① (E) 4" SW UNDER 4TH FLOOR NEAR RESTROOM AREA. CONTRACTOR TO FIELD VERIFY FOR EXACT LOCATION PRIOR CONNECTION.
- ② (N) UNDER FLOOR SW PIPING.

CSG CONSULTANTS  
 THESE PLANS AND DETAILS ARE  
**APPROVED**  
 THE APPROVAL OF THESE PLANS SHALL NOT  
 BE CONSTRUED TO BE A PERMIT FOR ANY  
 VIOLATION OF ANY CODE OR ORDINANCE  
 JUL 02 2019  
 BY: *[Signature]*  
 THESE PLANS SHALL BE ON THE JOB  
 FOR ALL REQUESTED INSPECTIONS.

ISSUE	DATE
1 PC CMT	4/24/19
2 PC CMT	6/14/19





CONCENTRA  
 3100 W. WARNER AVE., SUITE 100  
 SANTA ANA, CA 92704

PROJECT NO. 18E 30046
DRAWN/REVIEWED RJM/TB
DATE/ISSUE TBD
SHEET TITLE
SHEET NO. <b>P-1.0</b>

ISSUE	DATE
1 PC CMT	4/24/19
2 PC CMT	6/14/19

QUALITY AND RELIANCE  
DESIGN SOLUTIONS  
SAN ANTONIO, TEXAS  
TEL: 214-222-2488  
FAX: 214-222-2489




CONCENTRA  
3100 W. WARNER AVE, SUITE 100  
SANTA ANA, CA 92704

PROJECT NO. 18E 30046
DRAWN/REVIEWED RJM/TB
DATE/ISSUE TBD
SHEET TITLE PLUMBING SW & V DIAGRAM
SHEET NO. P-1.1

**KEYED NOTES**

- 1 (E) 4" SW UNDER 4TH FLOOR NEAR RESTROOM AREA. CONTRACTOR TO FIELD VERIFY FOR EXACT LOCATION PRIOR CONNECTION.
- 2 (N) UNDER FLOOR SW PIPING.




**NOTES:**  
 - FOR 2" PIPE: MIN. 18" CLEAR SPACE REQUIRED FOR CLEAN OUT  
 - FOR PIPE GREATER THAN 2": MIN. 24" CLEAR SPACE REQUIRED FOR CLEAN OUT

**PLUMBING - SW & V PIPING PLAN**  
 SCALE: N.T.S.  
 A  
 P-1.1  
 N

**CSG CONSULTANTS**  
 THESE PLANS AND DETAILS ARE  
**APPROVED**  
 THE APPROVAL OF THESE PLANS SHALL NOT  
 BE CONSTRUED TO BE A PERMIT FOR ANY  
 VIOLATION OF ANY CODE OR ORDINANCE  
 JUL 02 2019  
 BY: [Signature]  
 THESE PLANS SHALL BE ON THE JOB  
 FOR ALL REQUESTED INSPECTIONS.





NOTE: CONTRACTOR TO FIELD VERIFY FOR PIPE SIZE AND EXACT LOCATION PRIOR CONNECTING (N) CW PIPE .

CSG CONSULTANTS  
 THESE PLANS AND DETAILS ARE APPROVED  
 THE APPROVAL OF THESE PLANS SHALL NOT BE CONSTRUED TO BE A PERMIT FOR ANY VIOLATION OF ANY CODE OR ORDINANCE  
 JUL 02 2019



BY: *[Signature]*  
 THESE PLANS SHALL BE ON THE JOB FOR ALL REQUESTED INSPECTIONS.

PLUMBING - CW & HW PIPING PLAN  
 SCALE: 1/4" = 1'-0"  
 A  
 P-2.0  
 N

KEYED NOTES

- ① (E) 1 1/2" CW ABOVE CEILING. CONTRACTOR TO FIELD VERIFY FOR EXACT LOCATION AND ELEVATION
- ② (N) 1 1/2" CW ABOVE CEILING.
- ③ (N) 1" HW ABOVE CEILING.
- ④ (N) 3/4" CW DN. INSIDE WALL TO NEW WATER CLOSET WC-1.
- ⑤ (N) 1/2" CW & HW DN. INSIDE WALL TO NEW LAVATORY LV-1.
- ⑥ (N) 3/4" CW & HW DN. INSIDE WALL TO NEW MOP SINK MS-1.
- ⑦ (N) 3/4" CW & HW DN. INSIDE WALL TO NEW KITCHEN SINK SS-1.
- ⑧ (N) 3/4" CW & HW DN. AND CONN. TO NEW WATER HEATER WH-1.

ISSUE	DATE
1 PC CMT	4/24/19
2 PC CMT	6/14/19



CONCENTRA  
 3100 W. WARNER AVE, SUITE 100  
 SANTA ANA, CA 92704

PROJECT NO.  
 18E 30046

DRAWN/REVIEWED  
 RJM/TB

DATE/ISSUE  
 TBD



SHEET TITLE  
 PLUMBING  
 CW & HW  
 PIPING PLAN

SHEET NO.  
 P-2.0

### KEYED NOTES


- ① (E) 1 1/2" CW ABOVE CEILING. CONTRACTOR TO FIELD VERIFY FOR EXACT LOCATION AND ELEVATION
- ② (N) 1 1/2" CW ABOVE CEILING.
- ③ (N) 1" HW ABOVE CEILING.
- ④ (N) 3/4" CW DN. INSIDE WALL TO NEW WATER CLOSET WC-1.
- ⑤ REDUCE TO 1/2" CW & HW DN. INSIDE WALL TO NEW LAVATORY LV-1.
- ⑥ (N) 3/4" CW & HW DN. INSIDE WALL TO NEW MOP SINK MS-1.
- ⑦ (N) 3/4" CW & HW DN. INSIDE WALL TO NEW KITCHEN SINK SS-1.
- ⑧ (N) 3/4" CW & HW DN. AND CONN. TO NEW WATER HEATER WH-1.

CSG CONSULTANTS  
 THESE PLANS AND DETAILS ARE APPROVED  
 THE APPROVAL OF THESE PLANS SHALL NOT BE CONSTRUED TO BE A PERMIT FOR ANY VIOLATION OF ANY CODE OR ORDINANCE  
 JUL 02 2019  
 BY: *[Signature]*  
 THESE PLANS SHALL BE ON THE JOB FOR ALL REQUESTED INSPECTIONS.



CONCENTRA  
 3100 W. WARNER AVE, SUITE 100  
 SANTA ANA, CA 92704


PROJECT NO. 18E 30046
DRAWN/REVIEWED RJM/TB
DATE/ISSUE TBD
SHEET TITLE PLUMBING CW & HW DIAGRAM
SHEET NO. <b>P-2.1</b>



PLUMBING - CW & HW PIPING PLAN  
 SCALE: N.T.S.  
 P-2.1

NOTE: CONTRACTOR TO FIELD VERIFY FOR PIPE SIZE AND EXACT LOCATION PRIOR CONNECTING (N) CW PIPE .






ISLAND SINK DETAIL

SCALE: NONE


4



VENT THRU ROOF DETAIL

SCALE: NONE


3



CONDENSATE CONNECTION TO AC UNIT ON ROOF DETAIL

SCALE: NONE

2



WALL CLEAN-OUT DETAIL


SCALE: NONE

1

NOT USED

NOT USED

NOT USED





ELECTRIC WATER HEATER DETAIL

SCALE: NONE

5

CSG CONSULTANTS  
THESE PLANS AND DETAILS ARE APPROVED  
THE APPROVAL OF THESE PLANS SHALL NOT BE CONSTRUED TO BE A PERMIT FOR ANY VIOLATION OF ANY CODE OR ORDINANCE  
JUL 02 2019  
BY: *[Signature]*  
THESE PLANS SHALL BE ON THE JOB FOR ALL REQUESTED INSPECTIONS.

QUALITY ASSURANCE  
DESIGN SOLUTIONS  
PLUMBING  
MECHANICAL  
ELECTRICAL  
PAINT



CONCENTRA  
3100 W. WARNER AVE, SUITE 100  
SANTA ANA, CA 92704

PROJECT NO.  
18E 30046

DRAWN/REVIEWED  
RJM/TB

DATE/ISSUE  
TBD

SHEET TITLE  
PLUMBING  
DETAILS

SHEET NO.  
P-3.0

STATE OF CALIFORNIA  
**WATER HEATING SYSTEM GENERAL INFORMATION**  
 CEC-NRCC-PLB-01-E (REVISED 01/16) CALIFORNIA ENERGY COMMISSION  
**CERTIFICATE OF COMPLIANCE** NRCC-PLB-01-E  
 Water Heating System General Information (Page 1 of 2)  
 Project Name: **Concentra TI** Date Reported: **04-29-2019**

**A. GENERAL INFORMATION/SYSTEM INFORMATION**

01 Water Heater System Name:	A.O. Smith Water Heater
02 Water Heater System Configuration:	
03 Water Heater System Type:	Electric
04 Building Type:	Commercial
05 Total Number of Water Heaters in Systems:	1
06 Central DHW Distribution Type:	
07 Dwelling Unit DHW Distribution Type:	

**B. WATER HEATER INFORMATION**  
 Each water heater type requires a separate compliance document.

01 Water Heater Type:	Commercial - Grade
02 Fuel Type:	Electrical
03 Manufacture Name:	A.O. Smith Manufacture
04 Model Number:	DEL-40D-4
05 Number of identical Water Heaters:	0
06 Installed Water Heater System Efficiency:	0.92 Uniform Energy Factor
07 Required Minimum Efficiency:	
08 Standby Loss Percent or Standby Loss Total:	
09 Rated Input:	
10 Pilot Energy:	
11 Water Heater Tank Storage Volume:	40 Gal
12 Exterior Insulation on Water Heater:	2" insulation blanket
13 Volume of Supplemental Storage:	
14 Internal Insulation on Supplemental Storage:	
15 Exterior Insulation on Supplemental Storage:	

**C. PLUMBING COMPLIANCE FORMS & WORKSHEETS**  
 Check box if worksheet is included.  
 For detailed instructions on the use of this and all Energy Standards compliance documents, refer to the 2016 Nonresidential Manual  
 Note: The Enforcement Agency may require all compliance documents to be incorporated onto the building plans.

YES	NO	Doc/Worksheet #	Title
<input checked="" type="checkbox"/>	<input type="checkbox"/>	NRCC-PLB-01-E	Certificate of Compliance, Declaration. Required on plans for all submittals.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	NRCL-PLB-01-E	Certificate of Installation. Required on plans for all submittals.
<input type="checkbox"/>	<input type="checkbox"/>	NRCL-PLB-02-E	Certificate of Installation, required on central systems in high-rise residential, hotel/motel application.
<input type="checkbox"/>	<input type="checkbox"/>	NRCL-PLB-03-E	Certificate of Installation, required on single dwelling unit systems in high-rise residential, hotel/motel application.
<input type="checkbox"/>	<input type="checkbox"/>	NRCL-PLB-21-H	Certificate of Installation, required on HERS verified central systems in high-rise residential, hotel/motel application.
<input type="checkbox"/>	<input type="checkbox"/>	NRCL-PLB-22-H	Certificate of Installation, required on HERS verified single dwelling unit systems in high-rise residential, hotel/motel application.
<input type="checkbox"/>	<input type="checkbox"/>	NRCL-STH-01-E	Certificate of Installation, required on any solar water heating.

STATE OF CALIFORNIA  
**WATER HEATING SYSTEM GENERAL INFORMATION**  
 CEC-NRCC-PLB-01-E (REVISED 01/16) CALIFORNIA ENERGY COMMISSION  
**CERTIFICATE OF COMPLIANCE** NRCC-PLB-01-E  
 Water Heating System General Information (Page 2 of 2)  
 Project Name: **Concentra TI** Date Reported: **04-29-2019**



**DOCUMENTATION AUTHOR'S DECLARATION STATEMENT**  
 I certify that this Certificate of Compliance documentation is accurate and complete.  
 Documentation Author Name: **Tony Bui** Documentation Author Signature: *Tony Bui*  
 Company: \_\_\_\_\_ Signature Date: **4/29/2019**  
 Address: **17162 Gothard Street** CEAH/HERS Certification Identification # (if applicable): \_\_\_\_\_  
 City/State/Zip: **Huntington Beach, CA 92646** Phone: **714-465-5200x104**

**RESPONSIBLE PERSON'S DECLARATION STATEMENT**  
 I certify the following under penalty of perjury, under the laws of the State of California:  
 1. The information provided on this Certificate of Compliance is true and correct.  
 2. I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer).  
 3. The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations.  
 4. The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations plans and specifications submitted to the enforcement agency for approval with this building permit application.  
 5. I will ensure that a completed signed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy.

Responsible Designer Name: **Tony Bui** Responsible Designer Signature: *Tony Bui*  
 Company: \_\_\_\_\_ Date Signed: **4/29/2019**  
 Address: **17162 Gothard Street** License: \_\_\_\_\_  
 City/State/Zip: **Huntington Beach, CA 92646** Phone: **714-465-5200x104**

CSG CONSULTANTS  
 THESE PLANS AND DETAILS ARE  
**APPROVED**  
 THE APPROVAL OF THESE PLANS SHALL NOT  
 BE CONSTRUED TO BE A PERMIT FOR ANY  
 VIOLATION OF ANY CODE OR ORDINANCE  
 JUL 02 2019  
 BY: *[Signature]*  
 THESE PLANS SHALL BE ON THE JOB  
 FOR ALL REQUESTED INSPECTIONS.

ISSUE	DATE
1 PC CMT	4/24/19
2 PC CMT	6/14/19



CONCENTRA  
 3100 W. WARNER AVE., SUITE 100  
 SANTA ANA, CA 92704

PROJECT NO. 18E 30046
DRAWN/REVIEWED RJM/TB
DATE/ISSUE TBD
SHEET TITLE PLUMBING TITLE 24
SHEET NO. <b>PT24-1</b>