



KEY NOTES

- ◇ PROVIDE A 12" DEPTH AS REQUIRED CONCRETE PULLBOX. PROVIDE STEEL BOLT DOWN COVER ENGRAVED "FIRE ALARM".
- ◇ 1" C. WITH (2) 1/2" NPL. AQUASEAL CABLES, WESTPEN #AQ3245.
- ◇ (1) 1" C. WITH NEW (2) 1/2" NPL. AQUASEAL CABLES, WESTPEN #AQ3245. PROVIDE (1) 1" C.O.
- ◇ CUT (E) CONDUIT AND CAP UNDERGROUND.
- ◇ 1" C.O. TO/TROM (E) F.A. PULL BOX.
- ◇ PROVIDE CONDUIT CONNECTION (1" C.O.) TO (E) WALL MOUNTED F.A. BOX.
- ◇ 10" SQ. NEMA 3R PULL BOX, 412" ABOVE FINISHED GROUND. PROVIDE SUPPORT AND SECURE TO (E) STEEL POST.

GENERAL NOTES

1. FOR UNDER GROUND MULTI-CONDUIT REQUIREMENTS, SEE DETAIL #4, SHEET E6.0

PBWSI
ARCHITECTS

234 East Colorado Boulevard
Suite 700
Pasadena, California 91101

T: 626 432 5000
F: 626 432 5010
www.pbwsi.com

Consultant:

TTG STRUCTURAL MECHANICAL ELECTRICAL CIVIL
TIAO TAYLOR & GAINES
801 Via Platanos, Suite 400
Orange, California 92764
Phone: 909 477 8615 Fax: 909 477 8618
www.ttgc.com Project No. 0011.006.00

Project Title:

Palos Verdes HS
CLASSROOM BUILDING 3
600 Cloyden Road
Palos Verdes Estates
California 90274

KEY PLAN

ADDENDUM 1	05.22.12
BD SET	04.24.12
USA SUBMITTAL	07.22.11
NSR CD	05.31.11
DESIGN DEVELOPMENT	03.17.11

Mark Date Description

Issues/Revisions



Approvals:

EXERCISE STAMP
OFFICE OF THE STATE ARCHITECT
OFFICE OF REGULATION SERVICES
APPL. 03-114031
EX. 12-31-2013
NO. 114031

PROJECT NO: 10021.00
CAD Desg. File:
Drawn By: AS
Checked By: RP
©Copyright 2012 PBWSI Architects. All reserved. No part of this document may be reproduced, stored, or transmitted in any form or by any means, without the prior written permission of the architect.

Sheet Title:

SITE FIRE ALARM PLAN

Sheet Number:

E1.2

SITE FIRE ALARM PLAN